

POINT ATKINSON, BC, Canada

WMO: 710370

Lat: 49.3304N

Lon: 123.2646W

Elev: 14

StdP: 101.16

Time Zone: -8.00 (NAP)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-1.8	-0.3	-12.7	1.3	2.3	-9.1	1.7	1.4	16.8	9.1	15.5	9.0	2.1	80	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	24.3	17.6	23.1	17.6	22.0	17.3	18.6	22.3	18.0	21.4	17.5	20.8	2.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	12.1	21.1	16.4	11.7	20.5	15.8	11.3	19.9	52.8	22.6	50.9	21.6	49.2	20.9	20.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.4	9.7	DB	-3.3	28.5	2.7	2.5	-5.3	30.3	-6.9	31.8	-8.4	33.3	-10.4	35.1	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.8	6.1	6.5	8.0	10.5	14.0	16.4	19.1	19.2	16.2	11.7	8.3	5.8		
	DBStd	5.44	3.02	2.65	2.44	2.50	2.61	2.49	2.24	1.98	2.17	2.23	2.93	3.01		
	HDD10.0	523	123	99	70	23	2	0	0	0	0	9	65	133		
	HDD18.3	2466	378	331	321	236	137	69	17	13	71	204	301	389		
	CDD10.0	1194	3	2	8	37	124	191	281	286	185	63	13	2		
	CDD18.3	97	0	0	0	0	2	11	39	40	6	0	0	0		
	CDH23.3	101	0	0	0	0	2	14	54	27	2	0	0	0		
	CDH26.7	10	0	0	0	0	1	2	7	1	0	0	0	0		
(14) Wind	WSAvg	3.5	3.6	3.3	4.0	3.7	3.4	3.5	3.3	3.1	3.0	3.4	3.8	3.7		
(15) Precipitation	PrecAvg	1932	276	181	174	127	94	77	53	62	82	218	290	284		
	PrecMax	2315	455	347	317	252	137	130	99	273	185	373	501	354		
	PrecMin	1605	165	44	69	44	32	30	11	15	25	72	154	192		
	PrecStd	195	68	69	49	53	29	31	23	63	42	75	91	48		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	13.0	14.6	19.0	22.6	25.1	27.2	25.6	23.2	18.1	15.6	13.7		
		MCWB	10.6	9.5	10.3	12.8	14.2	17.4	16.8	17.9	17.3	14.0	12.3	9.0		
	2%	DB	12.2	11.5	13.1	16.6	20.0	22.6	24.7	24.0	21.3	16.5	14.1	11.8		
		MCWB	10.4	9.6	9.6	11.3	14.0	16.9	18.0	17.6	16.5	14.5	11.9	9.0		
	5%	DB	11.1	10.6	12.1	15.1	18.5	20.8	23.2	22.9	20.1	15.6	13.0	10.5		
		MCWB	9.2	8.7	9.1	11.2	14.0	16.3	17.8	17.8	16.1	13.6	11.2	8.6		
	10%	DB	10.0	9.7	11.2	13.8	17.4	19.6	22.0	21.9	19.0	14.7	12.0	9.5		
		MCWB	8.3	7.9	8.6	10.4	13.7	15.6	17.5	17.4	15.6	12.7	10.5	7.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	10.2	11.4	13.2	16.2	18.7	19.5	19.5	18.6	15.2	13.0	10.1		
		MCDB	11.4	11.3	13.0	16.3	19.1	23.0	23.1	23.3	22.6	16.3	14.3	12.0		
	2%	WB	9.0	9.2	9.9	12.1	15.2	17.6	18.7	18.6	17.3	14.5	11.6	8.7		
		MCDB	9.9	10.2	11.8	14.9	18.1	21.2	22.3	22.0	20.5	15.6	13.0	10.0		
	5%	WB	8.2	8.2	9.1	11.1	14.5	16.6	18.0	18.0	16.5	13.3	10.7	8.0		
		MCDB	9.2	9.2	11.0	14.0	17.4	20.2	21.6	21.2	19.2	14.4	12.1	9.1		
	10%	WB	7.4	7.6	8.4	10.1	13.9	15.8	17.4	17.5	15.4	12.1	9.9	7.2		
		MCDB	8.5	8.6	10.2	12.4	16.7	19.3	20.8	20.7	17.7	13.5	11.1	8.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.4	3.6	4.0	4.7	4.7	4.6	4.8	4.5	4.0	3.6	3.5	3.2		
		MCDBR	4.1	4.3	4.9	6.4	6.3	6.2	6.2	5.5	5.3	4.3	4.1	4.1		
	5% WB	MCWBR	3.2	3.3	3.8	4.0	3.7	3.6	3.4	3.1	3.1	3.2	3.5	3.7		
		MCWBR	4.2	4.1	5.2	5.8	5.5	5.8	5.7	5.0	5.0	4.1	4.5	4.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.318	0.311	0.331	0.363	0.384	0.364	0.360	0.363	0.346	0.336	0.321	0.305		
		taud	2.412	2.480	2.445	2.382	2.365	2.444	2.480	2.487	2.538	2.542	2.496	2.439		
	Ebn at Noon	Ebn at Noon	732	845	883	885	876	895	894	875	858	804	730	698		
		Edh at Noon	65	76	93	110	117	109	103	98	85	72	60	56		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.84	1.70	2.53	3.95	5.20	5.56	6.24	5.30	3.65	2.00	0.99	0.67		
	RadStd	RadStd	0.14	0.26	0.36	0.44	0.46	0.69	0.57	0.43	0.33	0.29	0.19	0.11		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (63 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page