

PORT HAWKESBURY, NS, Canada

WMO: 710410

Lat: 45.657N

Lon: 61.373W

Elev: 377

StdP: 14.50

Time Zone: -4.00 (NAA)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.3	6.1	-4.4	4.4	4.9	-1.1	5.2	7.6	33.9	22.9	31.7	20.3	12.0	290	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.0	81.6	69.6	78.8	67.6	75.9	66.4	71.8	78.2	70.3	75.5	68.8	73.4	10.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.7	110.8	74.6	68.4	105.7	73.3	67.1	100.9	71.8	35.8	78.5	34.5	75.5	33.2	73.4	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.2	24.1	21.1	DB	-4.2	87.3	3.2	2.1	-6.5	88.8	-8.3	90.1	-10.1	91.3	-12.4	92.8	(4)
(5)			WB	-4.9	74.0	3.1	1.0	-7.1	74.7	-8.9	75.2	-10.7	75.8	-12.9	76.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.8	24.1	22.7	27.5	37.4	47.6	55.3	65.3	65.7	59.3	48.8	39.3	31.0		
	DBStd	16.68	8.74	9.07	8.45	7.70	7.10	6.56	5.60	4.74	6.77	6.85	7.99	8.49		
	HDD50	3844	803	763	699	389	135	19	0	0	5	107	334	590		
	HDD65	7920	1268	1183	1162	829	542	297	64	49	196	504	772	1054		
	CDD50	1580	0	0	1	10	60	179	475	488	285	69	13	0		
	CDD65	181	0	0	0	0	2	7	74	71	26	1	0	0		
	CDH74	1031	0	0	0	0	41	67	457	357	108	1	0	0		
	CDH80	154	0	0	0	0	8	5	78	49	14	0	0	0		
	WSAvg	10.0	11.8	11.9	11.5	10.5	9.3	8.7	7.6	7.5	8.7	10.0	11.2	11.7		
	PrecAvg	61.7	5.5	4.4	4.9	4.8	3.9	4.1	3.6	4.5	4.2	5.6	6.7	6.6		
(15) Precipitation	PrecMax	86.9	14.3	6.7	12.3	8.9	8.3	9.2	9.1	9.4	8.3	8.6	17.9	11.6		
	PrecMin	49.7	1.1	1.6	1.2	0.7	1.0	1.9	0.7	1.0	0.7	1.3	2.2	3.1		
	PrecStd	8.6	2.4	1.4	2.4	2.4	1.9	1.8	2.0	2.2	1.9	2.0	3.2	2.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.0	51.7	59.8	64.4	79.0	80.4	85.8	84.7	81.8	70.1	63.4	56.4		
		MCWB	50.6	50.7	52.3	54.3	63.7	65.8	71.6	70.2	71.2	65.2	60.9	54.9		
	2%	DB	46.5	46.3	47.6	59.2	71.5	75.4	82.1	80.8	77.0	66.3	60.2	51.5		
		MCWB	45.8	44.9	45.2	53.9	60.1	63.2	69.9	69.9	68.2	62.5	58.3	50.4		
	5%	DB	40.6	40.1	42.5	54.8	65.0	71.4	79.0	77.9	73.4	63.0	56.8	47.1		
		MCWB	39.3	38.5	39.3	51.1	57.5	61.4	67.9	67.9	66.2	59.9	54.7	45.9		
	10%	DB	36.1	35.6	38.3	50.2	60.2	67.6	76.0	75.2	70.1	60.4	52.1	43.1		
		MCWB	34.8	34.0	35.5	47.2	53.4	60.3	66.6	66.3	65.5	56.8	49.8	42.3		
	0.4%	WB	50.3	50.3	52.3	59.1	66.7	70.0	73.7	73.5	72.4	67.8	61.4	55.1		
		MCDB	50.5	51.7	60.0	61.9	78.3	75.9	82.4	81.4	78.9	69.3	62.8	56.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.1	44.7	45.5	55.2	62.7	66.4	72.0	71.5	70.2	63.3	58.6	50.5		
		MCDB	46.7	45.3	47.7	57.5	67.8	71.4	79.5	76.9	74.4	65.0	59.8	51.3		
	5%	WB	39.5	38.6	40.4	51.7	58.9	63.3	70.4	70.0	68.4	60.7	54.9	45.9		
		MCDB	40.1	39.5	42.1	53.2	63.1	69.0	76.1	75.1	71.7	63.1	56.3	46.6		
	10%	WB	35.1	34.1	35.9	47.2	54.7	60.5	68.7	68.4	66.5	57.6	50.4	42.1		
		MCDB	35.8	35.3	37.7	50.0	58.6	66.3	73.7	73.0	69.5	60.1	51.9	42.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.0	14.7	13.8	14.5	17.1	16.2	17.0	17.0	16.1	14.2	12.8	11.4		
		MCDBR	21.6	21.5	19.8	21.1	26.0	23.2	21.7	20.7	19.0	16.5	18.2	16.8		
		MCWBR	22.1	20.9	18.0	15.5	15.5	13.4	11.8	11.4	12.4	13.7	17.2	16.7		
	5% WB	MCDBR	20.7	21.9	19.0	18.7	22.6	19.6	17.5	16.9	16.2	15.6	17.5	16.2		
		MCWBR	21.4	21.8	18.2	16.5	15.8	12.8	10.3	10.4	11.6	14.3	17.6	17.0		
(40) Clear-Sky Solar Irradiance	taub		0.296	0.292	0.318	0.346	0.365	0.384	0.409	0.394	0.354	0.333	0.317	0.297		
	taud		2.452	2.459	2.433	2.431	2.431	2.410	2.379	2.417	2.502	2.542	2.518	2.485		
	Ebn at Noon		259	285	290	290	286	280	271	272	275	266	249	246		
	Edh at Noon		22	26	31	34	35	36	37	34	29	24	21	19		
(44) All-Sky Solar Radiation	RadAvg		375	651	1051	1323	1583	1693	1692	1532	1211	764	421	281		
	RadStd		27	65	71	103	158	148	114	103	86	68	49	20		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	N/A	N/A	N/A	N/A	+0.61	+0.90	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page