

PORT HAWKESBURY, NS, Canada

WMO: 710410

Lat: 45.657N

Lon: 61.373W

Elev: 115

StdP: 99.95

Time Zone: -4.00 (NAA)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.5	-14.4	-20.2	0.6	-15.1	-18.4	0.7	-13.6	15.2	-5.0	14.2	-6.5	5.4	290	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	27.5	20.9	26.0	19.8	24.4	19.1	22.1	25.7	21.3	24.1	20.4	23.0	4.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.8	23.7	20.2	15.1	22.9	19.5	14.4	22.1	65.4	25.8	62.3	24.2	59.4	23.0	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	10.8	9.5	-20.1	30.7	1.8	1.2	-21.4	31.6	-22.4	32.3	-23.4	32.9	-24.7	33.8		
(5)			-20.5	23.3	1.7	0.5	-21.7	23.7	-22.7	24.0	-23.7	24.3	-25.0	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-4.4	-5.1	-2.5	3.0	8.7	13.0	18.5	18.7	15.2	9.3	4.0	-0.6		
	DBStd	9.27	4.86	5.04	4.70	4.28	3.94	3.64	3.11	2.63	3.76	3.80	4.44	4.72		
	HDD10.0	2136	446	424	388	216	75	11	0	0	3	59	186	328		
	HDD18.3	4400	704	657	646	461	301	165	36	27	109	280	429	586		
	CDD10.0	878	0	0	1	6	33	99	264	271	158	38	7	0		
	CDD18.3	101	0	0	0	0	1	4	41	39	14	1	0	0		
	CDH23.3	573	0	0	0	0	23	37	254	198	60	1	0	0		
	CDH26.7	86	0	0	0	0	4	3	43	27	8	0	0	0		
(14) Wind	WSAvg	4.5	5.3	5.3	5.2	4.7	4.2	3.9	3.4	3.4	3.9	4.5	5.0	5.2		
(15) Precipitation	PrecAvg	1568	139	111	125	122	99	105	91	114	106	142	171	168		
	PrecMax	2206	363	170	312	225	211	233	232	240	211	219	455	294		
	PrecMin	1262	28	40	31	17	25	49	18	25	17	33	56	78		
	PrecStd	219	62	35	60	61	47	45	51	57	49	50	82	53		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	11.0	15.4	18.0	26.1	26.9	29.9	29.3	27.6	21.2	17.5	13.6		
		MCWB	10.3	10.4	11.3	12.4	17.6	18.8	22.0	21.2	21.8	18.4	16.0	12.7		
	2%	DB	8.1	7.9	8.7	15.1	21.9	24.1	27.9	27.1	25.0	19.0	15.7	10.9		
		MCWB	7.7	7.2	7.3	12.2	15.6	17.3	21.1	21.0	20.1	17.0	14.6	10.2		
	5%	DB	4.8	4.5	5.8	12.7	18.3	21.9	26.1	25.5	23.0	17.2	13.8	8.4		
		MCWB	4.1	3.6	4.1	10.6	14.2	16.3	20.0	19.9	19.0	15.5	12.6	7.7		
	10%	DB	2.3	2.0	3.5	10.1	15.7	19.8	24.4	24.0	21.2	15.8	11.2	6.2		
		MCWB	1.6	1.1	1.9	8.5	11.9	15.7	19.2	19.1	18.6	13.8	9.9	5.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	10.2	11.3	15.1	19.3	21.1	23.1	23.1	22.5	19.9	16.3	12.8		
		MCDB	10.3	11.0	15.5	16.6	25.7	24.4	28.0	27.4	26.1	20.7	17.1	13.4		
	2%	WB	7.8	7.1	7.5	12.9	17.1	19.1	22.2	22.0	21.2	17.4	14.8	10.3		
		MCDB	8.1	7.4	8.7	14.2	19.9	21.9	26.4	24.9	23.5	18.3	15.4	10.7		
	5%	WB	4.2	3.7	4.7	10.9	15.0	17.4	21.3	21.1	20.2	16.0	12.7	7.7		
		MCDB	4.5	4.2	5.6	11.8	17.3	20.6	24.5	23.9	22.1	17.3	13.5	8.1		
	10%	WB	1.7	1.2	2.1	8.4	12.6	15.8	20.4	20.2	19.2	14.2	10.2	5.6		
		MCDB	2.1	1.8	3.1	10.0	14.8	19.1	23.2	22.8	20.8	15.6	11.1	6.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	8.2	7.7	8.1	9.5	9.0	9.4	9.5	8.9	7.9	7.1	6.4		
		MCDBR	12.0	11.9	11.0	11.7	14.5	12.9	12.1	11.5	10.6	9.2	10.1	9.4		
	5% WB	MCWBR	12.3	11.6	10.0	8.6	8.6	7.5	6.5	6.3	6.9	7.6	9.6	9.3		
		MCWBR	11.5	12.2	10.5	10.4	12.6	10.9	9.7	9.4	9.0	8.7	9.7	9.0		
(40) Clear-Sky Solar Irradiance	taub	taub	0.296	0.292	0.318	0.346	0.365	0.384	0.409	0.394	0.354	0.333	0.317	0.297		
		taud	2.452	2.459	2.433	2.431	2.431	2.410	2.379	2.417	2.502	2.542	2.518	2.485		
	Ebn at Noon	Ebn at Noon	816	897	915	914	902	883	854	856	867	839	786	776		
		Edh at Noon	69	82	98	107	111	114	116	108	91	76	65	61		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.18	2.05	3.31	4.17	4.99	5.34	5.33	4.83	3.82	2.41	1.33	0.89		
	RadStd	RadStd	0.09	0.20	0.22	0.33	0.50	0.47	0.36	0.33	0.27	0.21	0.15	0.06		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	N/A	N/A	N/A	N/A	+0.34	+0.50	N/A	N/A	N/A	N/A

Nomenclature: See separate page