

DELTA BURNS BOG, BC, Canada

WMO: 710420

Lat: 49.1260N

Lon: 123.0025W

Elev: 3

StdP: 101.29

Time Zone: -8.00 (NAP)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-7.9	-5.9	-13.1	1.2	-1.9	-10.3	1.6	-3.8	4.4	6.7	3.9	6.4	0.4	0	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	28.3	19.3	26.6	18.6	24.9	17.9	20.0	26.8	19.2	25.4	18.4	24.0	1.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	12.5	22.4	16.7	11.9	21.7	15.9	11.3	20.9	57.1	26.8	54.4	25.5	51.9	24.2	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 3.5	3.0	2.4	-10.9	31.3	1.3	1.7	-11.8	32.5	-12.5	33.5	-13.3	34.5	-14.2	35.7		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	3.4	3.6	6.5	9.2	13.2	15.4	17.7	17.8	14.4	9.7	5.8	3.2		
	DBStd	5.99	3.41	3.69	2.61	2.22	2.40	2.35	2.01	1.88	2.34	2.49	3.42	3.38		
	HDD10.0	914	205	179	109	39	3	0	0	0	1	35	131	213		
	HDD18.3	3068	463	412	366	273	160	93	37	34	118	267	376	471		
	CDD10.0	927	0	1	3	16	102	162	238	241	133	26	4	1		
	CDD18.3	40	0	0	0	0	1	6	17	16	2	0	0	0		
	CDH23.3	734	0	0	0	5	38	104	264	266	57	0	0	0		
	CDH26.7	137	0	0	0	1	4	21	54	50	7	0	0	0		
(14) Wind	WSAvg	0.8	0.9	1.1	1.2	1.1	0.8	0.7	0.7	0.6	0.6	0.6	0.8	0.9		
(15) Precipitation	PrecAvg	1217	175	101	116	81	63	52	33	42	61	132	186	175		
	PrecMax	1493	295	222	252	176	101	102	75	172	171	285	351	271		
	PrecMin	910	92	13	28	15	0	4	1	5	6	14	73	75		
	PrecStd	152	53	45	44	36	26	27	19	38	40	63	67	52		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	12.9	18.2	23.1	26.7	29.4	30.3	30.4	27.5	19.7	14.7	12.0		
		MCWB	10.3	9.9	11.6	14.5	16.4	19.4	19.8	19.6	18.7	14.9	12.7	10.5		
	2%	DB	10.2	11.2	15.4	18.4	24.1	26.4	28.1	28.0	24.8	17.3	13.0	9.8		
		MCWB	9.2	9.2	10.0	11.8	16.0	18.3	19.2	19.6	17.5	13.7	11.6	8.9		
	5%	DB	9.2	10.0	13.3	16.1	22.0	23.7	26.2	26.3	22.7	15.6	11.9	8.7		
		MCWB	8.1	8.6	9.1	10.9	15.1	17.1	18.7	19.0	16.9	12.7	10.8	7.8		
	10%	DB	8.2	8.8	11.4	14.3	19.7	21.6	24.4	24.5	20.4	14.2	10.8	7.8		
		MCWB	7.3	7.4	8.6	9.9	14.1	15.9	17.7	18.3	15.7	12.0	9.7	7.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	11.2	12.8	15.0	18.0	20.3	20.8	20.9	20.1	16.6	13.4	11.1		
		MCDB	11.3	12.4	16.7	21.9	25.4	27.2	28.3	27.6	26.7	18.5	14.5	11.9		
	2%	WB	9.5	9.9	10.8	13.0	16.5	18.7	19.7	20.1	18.5	14.9	12.2	9.2		
		MCDB	9.9	10.4	13.5	17.5	22.8	25.3	26.9	26.6	23.3	16.3	12.8	9.8		
	5%	WB	8.4	8.8	9.8	11.6	15.4	17.3	18.8	19.3	17.4	13.4	11.2	8.1		
		MCDB	9.0	9.8	12.1	15.0	21.0	22.9	25.3	25.3	21.7	14.8	11.8	8.6		
	10%	WB	7.5	7.7	9.0	10.5	14.4	16.2	18.0	18.5	16.4	12.5	10.1	7.1		
		MCDB	8.1	8.6	11.0	13.2	19.0	20.9	23.8	24.0	19.7	13.9	10.8	7.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.5	8.9	9.8	11.4	11.1	12.7	12.8	11.3	8.8	7.4	6.0		
		MCDBR	6.9	8.6	12.8	14.2	16.6	15.9	16.8	16.5	16.4	11.1	7.3	5.5		
	5% WB	MCWBR	5.7	6.2	7.9	8.2	8.9	8.0	8.4	8.7	9.7	7.4	5.0	4.6		
		MCWBR	6.3	7.3	9.3	11.9	14.9	14.4	15.4	15.0	13.9	9.3	5.5	5.6		
(40) Clear-Sky Solar Irradiance	taub		0.321	0.316	0.332	0.366	0.392	0.365	0.363	0.367	0.350	0.338	0.323	0.311		
		taud	2.446	2.508	2.483	2.389	2.340	2.437	2.468	2.471	2.517	2.535	2.496	2.453		
	Ebn at Noon		735	843	885	882	868	894	891	872	854	803	730	696		
		Edh at Noon	64	75	90	109	120	109	105	100	86	72	60	56		
(44) All-Sky Solar Radiation	RadAvg		0.86	1.73	2.60	4.04	5.27	5.67	6.32	5.36	3.72	2.04	1.02	0.69		
	RadStd		0.14	0.26	0.35	0.43	0.45	0.66	0.54	0.41	0.33	0.28	0.19	0.10		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (70 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page