

OLD CROW, YT, Canada

WMO: 710440

Lat: 67.5679N

Lon: 139.8449W

Elev: 251

StdP: 98.34

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-46.6	-44.6	-51.4	0.0	-46.3	-49.0	0.0	-44.3	11.5	-21.6	10.4	-21.4	0.2	0	0.812

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	25.6	15.4	23.6	14.6	21.8	14.0	16.6	23.0	15.6	21.5	14.7	20.2	2.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.1	10.4	18.2	13.1	9.7	17.6	12.1	9.1	17.0	47.5	23.2	44.7	21.5	42.0	20.5	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	9.0	8.0	-47.0	28.9	2.6	1.5	-48.8	30.0	-50.3	30.8	-51.8	31.7	-53.6	32.8		
(5)			-46.9	18.5	2.3	1.4	-48.6	19.5	-50.0	20.3	-51.3	21.1	-53.0	22.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.4	-28.5	-25.1	-21.3	-8.9	4.3	13.3	15.0	10.8	4.2	-7.4	-20.9	-25.6
	DBStd	17.17	9.88	8.21	6.90	7.16	6.41	4.13	3.45	3.96	4.21	6.09	8.00	8.37
	HDD10.0	6714	1194	983	969	566	194	17	6	37	176	541	928	1102
	HDD18.3	9412	1453	1217	1228	816	434	157	111	234	424	799	1178	1361
	CDD10.0	356	0	0	0	0	18	114	159	62	2	0	0	0
	CDD18.3	12	0	0	0	0	0	4	7	1	0	0	0	0
	CDH23.3	186	0	0	0	0	6	65	91	24	0	0	0	0
	CDH26.7	19	0	0	0	0	0	6	11	2	0	0	0	0
Wind	WSAvg	2.8	2.0	2.2	2.8	3.5	3.7	3.3	3.1	3.0	2.9	2.9	2.0	2.3
Precipitation	PrecAvg	273	11	8	10	7	13	33	50	55	34	24	15	12
	PrecMax	332	30	19	29	24	29	63	108	103	62	41	36	27
	PrecMin	203	1	1	1	1	2	9	20	20	17	10	2	3
	PrecStd	31	7	4	6	5	6	16	17	18	10	8	7	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.1	-2.7	2.1	10.5	24.0	27.5	28.1	26.2	17.5	6.0	-1.7	-4.4
		MCWB	-3.4	-3.9	0.3	5.2	12.9	15.4	16.6	16.8	10.7	3.9	-2.4	-5.1
	2%	DB	-7.3	-7.1	-3.9	8.0	20.6	25.3	25.9	23.1	15.4	3.3	-4.6	-8.9
		MCWB	-7.8	-7.7	-5.2	3.7	11.5	14.5	16.1	15.1	9.7	1.9	-5.2	-9.3
	5%	DB	-12.3	-11.0	-7.4	5.3	17.7	23.3	23.8	20.2	13.2	1.5	-7.1	-11.9
		MCWB	-12.7	-11.5	-8.6	1.9	9.8	13.7	15.4	13.8	9.0	0.5	-7.6	-12.3
	10%	DB	-15.9	-14.2	-10.7	2.8	15.0	21.4	22.0	17.9	11.0	0.0	-9.7	-14.4
		MCWB	-16.3	-14.7	-11.5	0.2	8.4	13.0	14.7	12.7	7.9	-0.9	-10.3	-14.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.2	-3.6	0.3	5.6	13.7	17.5	18.2	17.4	11.7	4.3	-2.4	-5.0
		MCDB	-2.0	-2.5	2.0	10.1	22.1	24.7	25.0	23.8	15.8	5.7	-1.7	-4.5
	2%	WB	-7.9	-7.6	-5.1	3.8	11.9	15.5	17.0	15.8	10.4	2.1	-5.1	-9.2
		MCDB	-7.4	-6.9	-3.9	7.7	19.9	22.3	23.7	21.5	14.0	3.2	-4.4	-8.7
	5%	WB	-12.7	-11.4	-8.5	2.0	10.2	14.5	16.1	14.5	9.3	0.7	-7.5	-12.2
		MCDB	-12.4	-10.9	-7.4	5.0	17.0	21.3	22.0	19.1	12.6	1.5	-7.0	-11.8
	10%	WB	-16.2	-14.6	-11.5	0.2	8.7	13.6	15.3	13.3	8.2	-0.8	-10.2	-14.6
		MCDB	-15.9	-14.2	-10.6	2.7	14.6	19.9	20.8	17.0	10.9	0.0	-9.7	-14.2
Mean Daily Temperature Range	5% DB	MDBR	7.5	8.8	12.5	12.2	11.1	11.5	10.5	9.9	8.3	6.2	7.1	7.3
		MCDBR	10.3	10.3	14.8	13.6	15.6	14.3	14.2	14.1	13.4	7.1	7.6	9.3
		MCWBR	10.1	9.8	13.7	9.9	8.6	6.5	6.6	7.4	8.3	5.8	7.4	8.9
	5% WB	MCDBR	10.1	10.1	14.9	13.1	15.0	12.6	12.1	11.6	11.6	6.8	7.5	9.1
		MCWBR	9.9	9.8	13.6	9.6	8.3	6.2	6.3	6.5	7.6	5.6	7.3	8.9
Clear-Sky Solar Irradiance	taub	0.171	0.226	0.245	0.298	0.341	0.348	0.372	0.348	0.303	0.236	0.157	N/A	
	taud	1.904	2.143	2.266	2.211	2.351	2.410	2.373	2.460	2.522	2.300	1.933	N/A	
	Ebn at Noon	159	616	825	854	853	855	816	801	761	606	166	0	
	Edh at Noon	10	46	72	103	101	99	100	82	60	38	9	0	
All-Sky Solar Radiation	RadAvg	0.06	0.64	2.42	4.81	5.90	6.12	4.99	3.54	2.09	0.74	0.13	0.00	
	RadStd	0.00	0.04	0.10	0.17	0.43	0.55	0.36	0.31	0.21	0.09	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.31	N/A	N/A	N/A	N/A	N/A	-451	-468	N/A	N/A
(47) Regional (4 neighbors)		+0.86	N/A	N/A	N/A	N/A	N/A	-383	-406	N/A	N/A

Nomenclature: See separate page