

KOMAKUK BEACH, YT, Canada

WMO: 710460

Lat: 69.595N

Lon: 140.180W

Elev: 13

StdP: 101.17

Time Zone: -8.00 (NAP)

Period: 86-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.6	-36.9	-40.4	0.1	-36.6	-39.8	0.1	-36.3	24.3	-20.6	22.1	-21.0	3.3	270	1.102

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	18.6	13.7	15.8	12.1	13.6	10.9	14.1	18.3	12.5	15.6	11.0	13.4	6.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.7	8.6	15.7	10.5	7.9	14.5	9.3	7.3	12.9	39.6	18.4	35.4	15.8	31.7	13.5	20.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.8	16.3	14.1	-40.4	24.3	2.0	2.3	-41.9	26.0	-43.1	27.3	-44.2	28.7	-45.6	30.3		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.9	-24.5	-24.1	-23.8	-15.5	-4.4	4.5	8.5	6.8	1.6	-8.0	-18.0	-22.3
	DBStd	13.78	7.69	8.32	6.75	6.90	5.18	3.88	3.67	3.95	3.87	5.40	7.07	6.93
	HDD10.0	7296	1069	953	1048	764	448	172	73	116	254	558	839	1000
	HDD18.3	10287	1327	1187	1307	1014	706	414	306	359	503	817	1089	1258
	CDD10.0	51	0	0	0	0	0	7	26	16	2	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	7	0	0	0	0	0	1	2	4	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	6.2	7.5	7.3	6.6	6.3	6.2	5.5	5.0	4.8	5.2	5.8	6.9	7.2
Precipitation	PrecAvg	168	6	4	3	4	5	16	31	38	21	20	9	6
	PrecMax	276	19	17	13	16	26	46	114	87	65	59	47	17
	PrecMin	59	0	0	0	0	0	0	0	5	0	1	0	0
	PrecStd	56	5	4	3	4	6	15	22	23	15	15	10	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.4	-0.7	-1.0	2.2	7.5	20.2	22.1	22.2	16.9	5.9	2.0	-0.8
		MCWB	0.2	-1.0	-1.2	1.0	5.6	14.2	14.5	15.4	11.4	4.1	1.2	-1.0
	2%	DB	-5.2	-4.2	-6.9	-0.4	4.7	15.8	19.1	17.1	12.1	2.1	-2.2	-6.0
		MCWB	-5.6	-4.5	-7.1	-1.2	3.5	12.0	14.1	12.7	8.7	1.2	-2.7	-6.4
	5%	DB	-10.2	-7.9	-11.2	-3.2	2.8	12.7	16.5	14.5	8.7	0.2	-5.4	-9.2
		MCWB	-10.7	-8.3	-11.6	-3.6	1.8	9.9	12.9	11.5	6.8	-0.3	-5.8	-9.7
	10%	DB	-14.0	-12.0	-14.8	-5.8	1.4	10.2	14.1	12.3	6.4	-1.3	-8.4	-12.4
		MCWB	-14.5	-12.5	-15.1	-6.2	0.7	8.0	11.4	10.0	5.3	-1.7	-8.7	-12.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.3	-1.4	1.9	1.1	4.9	14.7	16.3	16.2	12.0	4.1	-0.9	-1.8
		MCDB	-0.9	-1.1	2.0	2.1	6.0	19.4	20.4	23.8	16.3	5.3	-0.8	-1.7
	2%	WB	-5.2	-3.8	-3.9	-1.2	2.9	12.0	14.6	13.4	8.8	1.8	-5.6	-6.6
		MCDB	-4.7	-3.4	-3.6	-0.8	3.8	15.5	18.7	16.9	12.3	2.7	-5.3	-6.2
	5%	WB	-9.2	-6.2	-9.9	-4.0	1.6	10.0	13.2	11.2	6.5	0.3	-9.8	-10.4
		MCDB	-8.8	-5.9	-9.5	-3.6	2.3	12.9	16.4	13.3	7.8	0.8	-9.5	-10.0
	10%	WB	-13.6	-10.4	-14.2	-6.6	0.5	8.0	11.8	10.0	4.8	-1.6	-12.5	-13.8
		MCDB	-13.1	-10.0	-13.9	-6.2	0.9	10.1	14.6	11.9	5.5	-1.2	-12.1	-13.4
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.7	6.0	6.4	4.7	6.4	7.3	6.4	5.0	5.2	6.0	5.9
		MCDBR	12.2	12.5	10.1	8.3	6.2	12.0	11.7	11.3	10.1	6.6	9.8	10.5
		MCWBR	9.5	10.5	11.1	7.6	4.5	8.1	6.9	8.2	6.6	6.1	10.5	11.1
	5% WB	MCDBR	9.7	11.0	12.2	7.3	4.9	11.1	10.5	11.3	8.2	6.4	8.6	10.8
		MCWBR	9.6	11.1	12.3	7.2	4.2	8.2	7.2	7.9	5.9	6.2	8.6	10.8
Clear-Sky Solar Irradiance	taub	0.169	0.205	0.252	0.310	0.346	0.357	0.380	0.347	0.303	0.224	N/A	N/A	
	taud	1.887	2.077	2.168	2.073	2.092	2.293	2.344	2.471	2.494	2.192	N/A	N/A	
	Ebn at Noon	29	566	772	814	825	833	795	788	729	528	0	0	
	Edh at Noon	3	39	74	113	127	108	100	79	57	34	0	0	
All-Sky Solar Radiation	RadAvg	0.01	0.39	2.01	4.31	5.96	6.19	4.91	3.15	1.73	0.53	0.00	0.00	
	RadStd	0.00	0.04	0.11	0.22	0.39	0.54	0.38	0.29	0.17	0.07	0.00	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.70	+1.20	N/A	N/A	N/A	N/A	-252	-251	N/A	N/A
(47)	Regional (6 neighbors)	+0.75	+0.94	N/A	N/A	N/A	N/A	-254	-274	N/A	N/A

Nomenclature: See separate page