

WAGER BAY, NU, Canada

WMO: 710490

Lat: 65.879N

Lon: 89.446W

Elev: 59

StdP: 14.66

Time Zone: -6.00 (NAC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-39.2	-36.4	-47.7	0.3	-39.0	-44.4	0.4	-36.4	51.8	-9.9	41.4	-22.0	5.4	300	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	67.8	54.8	63.3	52.8	59.9	51.0	55.8	64.9	53.5	60.0	51.4	57.7	11.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
51.4	56.4	58.6	49.3	52.2	56.5	47.0	47.9	54.6	23.7	65.2	22.3	60.2	21.1	57.7	63.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 45.8	36.8	30.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	-18.3	-21.7	-12.8	3.2	21.5	40.3	52.6	49.3	37.2	21.6	2.6	-10.7		
	DBStd	27.39	10.90	10.23	11.33	10.75	8.94	6.43	5.60	5.73	5.57	8.70	12.14	11.96		
	HDD50	13345	2118	2008	1947	1405	884	299	34	82	385	881	1421	1881		
	HDD65	18638	2583	2428	2412	1855	1349	742	386	485	835	1346	1871	2346		
	CDD50	184	0	0	0	0	0	7	116	61	0	0	0	0		
	CDD65	3	0	0	0	0	0	0	3	0	0	0	0	0		
	CDH74	33	0	0	0	0	0	0	18	15	0	0	0	0		
	CDH80	3	0	0	0	0	0	0	1	2	0	0	0	0		
	WSAvg	12.2	11.1	9.8	9.8	11.3	13.4	13.1	11.5	12.1	12.9	14.8	14.6	11.4		
	PrecAvg	11.0	0.4	0.4	0.6	0.7	0.7	1.0	1.4	1.9	1.5	1.1	0.7	0.6		
(15) Precipitation	PrecMax	16.3	1.3	0.8	1.6	1.8	1.7	2.4	3.6	3.9	2.7	2.2	1.7	1.0		
	PrecMin	6.0	0.1	0.1	0.1	0.1	0.2	0.2	0.5	0.7	0.6	0.3	0.1	0.1		
	PrecStd	2.4	0.3	0.2	0.4	0.4	0.4	0.5	0.7	0.7	0.6	0.5	0.4	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.0	8.5	17.6	31.7	42.1	64.3	76.4	75.4	53.7	37.5	31.0	30.3		
		MCWB	20.2	7.3	16.3	29.2	37.2	52.2	57.4	57.3	45.4	35.4	30.1	29.0		
	2%	DB	8.9	4.1	11.6	26.5	38.5	57.6	69.8	67.1	49.6	35.3	27.6	17.6		
		MCWB	8.0	3.3	10.2	24.6	34.7	48.4	56.7	53.6	43.8	33.7	26.8	16.5		
	5%	DB	3.1	-1.0	7.6	23.0	35.7	53.2	65.0	61.8	47.0	34.0	24.1	12.1		
		MCWB	2.3	-1.7	6.6	21.2	32.5	45.9	53.9	51.7	42.6	32.5	23.3	11.2		
	10%	DB	-2.1	-5.5	4.0	19.2	33.4	49.1	62.0	58.1	44.7	32.6	20.6	7.6		
		MCWB	-2.8	-6.0	3.1	17.4	31.0	42.9	52.5	50.2	41.1	31.1	19.7	6.8		
	0.4%	WB	20.7	6.2	16.4	28.9	37.4	51.7	59.6	56.9	47.2	35.9	29.8	29.2		
		MCDB	21.3	6.9	17.5	31.4	40.5	59.8	68.6	66.0	51.1	36.9	30.3	30.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	8.7	0.7	9.8	24.6	34.8	48.0	57.2	54.2	44.9	34.1	26.2	17.4		
		MCDB	9.4	1.4	10.8	26.4	37.5	55.9	67.4	60.2	48.5	35.0	26.8	18.3		
	5%	WB	3.0	-3.7	6.5	21.3	32.7	45.3	55.2	52.4	43.1	32.8	22.8	11.6		
		MCDB	3.6	-3.3	7.3	22.8	34.9	51.6	64.1	57.8	46.3	33.9	23.5	12.5		
	10%	WB	-1.9	-7.8	3.1	17.6	30.6	42.8	53.1	50.6	41.5	31.2	19.3	7.0		
		MCDB	-1.2	-7.4	4.0	19.3	33.0	48.0	60.0	56.1	44.5	32.5	20.3	7.8		
	5% DB	MDBR	10.7	10.7	14.4	15.7	12.5	11.4	14.3	11.8	8.6	8.3	10.7	10.9		
		MCDBR	13.5	13.4	15.9	17.1	13.3	18.3	19.7	19.4	12.4	7.4	13.7	13.3		
		MCWBR	13.2	13.5	14.4	15.1	9.2	9.3	9.0	8.9	8.5	6.8	13.9	12.7		
		MCWBR	13.4	13.7	15.3	16.1	11.5	15.3	16.1	13.3	11.3	7.3	13.9	12.8		
(35) Mean Daily Temperature Range	5% WB	MCWBR	13.2	13.4	14.5	14.6	9.3	9.3	9.2	8.4	8.4	7.2	14.0	12.5		
(40) Clear-Sky Solar Irradiance	taub		0.153	0.223	0.264	0.313	0.345	0.325	0.357	0.336	0.304	0.256	0.165	0.151		
		taud	1.891	2.121	2.163	2.065	2.063	2.363	2.410	2.462	2.452	2.174	1.906	1.902		
	Ebn at Noon		107	213	256	267	268	281	267	262	245	189	89	21		
		Edh at Noon	6	17	27	39	43	33	31	27	21	16	5	1		
(44) All-Sky Solar Radiation	RadAvg		30	225	768	1524	2023	1851	1639	1097	620	212	55	6		
	RadStd		3	20	44	62	111	179	156	99	59	32	6	0		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page