

PUNTZI MOUNTAIN, BC, CanadaWMO: **710500**Lat: **52.1144N**Lon: **124.1356W**Elev: **910**StdP: **90.86**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-33.4	-28.0	-36.6	0.1	-32.3	-31.7	0.2	-27.3	7.3	1.4	6.2	-0.1	0.2	0	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	29.4	14.6	27.3	13.8	25.2	13.1	15.5	26.6	14.6	24.9	13.8	23.3	2.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.9	9.7	16.1	10.7	8.9	15.5	9.5	8.3	15.2	46.2	26.7	43.7	24.9	41.3	23.5	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	5.9	5.0	-38.6	32.5	5.0	1.7	-42.2	33.7	-45.1	34.7	-47.9	35.6	-51.5	36.8		
(5)			-37.8	16.9	3.9	1.1	-40.6	17.7	-42.9	18.3	-45.1	19.0	-47.9	19.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.6	-10.9	-8.0	-2.2	3.4	8.6	12.0	15.0	14.4	9.9	3.5	-4.4	-11.2		
	DBStd	10.47	7.44	6.37	5.51	3.37	3.59	2.99	3.04	3.12	3.42	3.75	5.87	6.62		
	HDD10.0	3153	649	504	377	200	69	13	2	3	42	204	432	657		
	HDD18.3	5768	907	738	636	449	301	191	110	127	252	461	682	916		
	CDD10.0	438	0	0	0	1	27	73	157	139	40	2	0	0		
	CDD18.3	12	0	0	0	0	0	1	7	4	0	0	0	0		
	CDH23.3	884	0	0	0	2	38	97	371	312	63	2	0	0		
	CDH26.7	241	0	0	0	0	5	23	118	85	10	0	0	0		
(14) Wind	WSAvg	1.5	0.9	1.1	1.6	1.9	2.0	2.0	1.8	1.5	1.4	1.3	1.1	0.9		
(15) Precipitation	PrecAvg	918	104	66	75	55	51	69	50	52	61	96	128	109		
	PrecMax	1177	215	148	131	102	99	137	119	136	128	178	265	161		
	PrecMin	718	56	2	15	24	21	34	10	12	7	9	51	50		
	PrecStd	116	36	32	29	20	20	24	25	28	33	40	53	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	8.3	15.1	21.5	26.9	29.8	32.7	31.5	28.2	21.0	11.1	5.2		
		MCWB	2.6	2.9	7.1	9.9	12.0	14.2	15.9	15.5	13.7	11.1	6.1	1.9		
	2%	DB	3.4	5.9	11.0	16.9	23.9	26.1	29.8	29.1	25.2	16.7	7.2	2.5		
		MCWB	1.1	1.6	4.3	7.9	11.0	12.6	14.9	14.8	13.0	9.1	3.8	0.4		
	5%	DB	1.1	4.1	8.6	14.1	21.0	23.4	27.5	26.9	22.3	13.5	4.7	0.2		
		MCWB	-0.4	0.4	3.1	6.3	10.2	12.0	14.1	14.1	12.2	7.3	2.1	-1.2		
	10%	DB	-0.9	1.9	6.6	11.8	18.5	20.9	25.0	24.6	19.4	11.0	2.6	-1.9		
		MCWB	-2.0	-0.9	1.8	4.8	9.1	11.0	13.4	13.3	10.9	5.9	0.9	-2.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	3.5	7.4	10.2	12.9	14.8	16.9	16.8	14.8	11.5	6.4	2.3		
		MCDB	5.6	7.2	14.2	20.3	23.6	25.2	29.5	27.8	24.7	20.0	10.2	4.7		
	2%	WB	1.3	1.9	4.8	8.4	11.7	13.6	15.6	15.6	13.7	9.7	4.2	0.6		
		MCDB	3.0	5.4	10.1	15.8	21.7	23.6	27.0	26.6	23.3	15.5	6.7	2.3		
	5%	WB	-0.2	0.6	3.5	6.7	10.7	12.6	14.7	14.7	12.5	7.9	2.5	-1.1		
		MCDB	1.0	3.5	8.0	13.3	19.6	21.5	25.1	25.1	21.2	12.9	4.2	0.3		
	10%	WB	-2.0	-0.6	2.1	5.2	9.7	11.6	13.8	13.8	11.3	6.3	1.0	-2.9		
		MCDB	-0.8	1.7	6.1	10.8	17.3	19.6	23.3	23.1	18.6	10.3	2.4	-1.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	16.8	15.3	15.3	16.2	15.3	16.8	17.7	16.9	14.2	10.8	11.9		
		MCDBR	14.1	17.9	16.4	19.9	21.7	20.7	22.4	22.5	23.3	18.8	12.8	13.3		
		MCWBR	12.0	13.8	10.5	11.4	10.7	9.4	9.6	10.3	12.3	11.7	9.3	11.4		
		MCWBR	13.1	16.6	15.5	18.3	19.0	17.6	19.5	20.1	20.9	17.6	11.6	13.0		
(40) Clear-Sky Solar Irradiance	taub	taub	0.275	0.281	0.302	0.327	0.354	0.351	0.341	0.342	0.312	0.297	0.286	0.269		
		taud	2.350	2.437	2.446	2.414	2.374	2.417	2.492	2.483	2.566	2.569	2.427	2.325		
		Ebn at Noon	739	854	900	912	897	901	905	887	883	830	722	674		
		Edh at Noon	60	73	89	104	113	110	100	96	79	64	55	51		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.89	1.82	3.05	4.50	5.35	5.63	5.93	5.06	3.51	2.04	0.99	0.70		
		RadStd	0.08	0.18	0.24	0.35	0.39	0.47	0.56	0.26	0.33	0.21	0.11	0.07		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+67	N/A

Nomenclature: See separate page