

STORM HILLS, NT, Canada

WMO: 710520

Lat: 68.894N

Lon: 133.940W

Elev: 858

StdP: 14.25

Time Zone: -7.00 (NAM)

Period: 99-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -32.9	(c) -30.2	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 56.5	(k) -6.7	(l) 50.8	(m) 0.8	(n) 15.9	(o) 270	(p) 1.078

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 13.6	(c) 71.3	(d) N/A	(e) 67.9	(f) N/A	(g) 64.4	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 12.7	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 40.4	(b) 34.8	(c) 29.5	(e) -35.9	(f) 77.3	(g) 2.7	(h) 3.5	(i) -37.9	(j) 79.8	(k) -39.4	(l) 81.9	(m) -40.9	(n) 83.8	(o) -42.9	(p) 86.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	-10.5	-9.5	-8.9	7.2	27.0	46.1	51.5	46.8	36.1	20.0	0.5	-8.6
	DBStd	25.63	12.72	13.32	12.00	11.80	12.14	9.46	8.63	8.14	7.82	8.36	9.52	10.57
	HDD50	12457	1876	1667	1827	1283	716	185	89	160	422	932	1484	1816
	HDD65	17665	2341	2087	2292	1733	1177	568	425	563	868	1396	1934	2281
	CDD50	274	0	0	0	0	4	68	135	62	4	1	0	0
	CDD65	7	0	0	0	0	0	2	5	0	0	0	0	0
	CDH74	31	0	0	0	0	0	13	18	0	0	0	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	14.8	17.2	17.1	15.0	14.1	13.8	13.7	13.0	13.3	14.0	14.4	16.1	15.9
Precipitation	PrecAvg	9.4	0.4	0.4	0.5	0.4	0.5	1.0	1.6	1.6	1.2	0.9	0.6	0.5
	PrecMax	12.4	1.2	0.8	1.3	1.0	1.4	2.7	2.9	3.2	2.2	1.7	1.3	1.4
	PrecMin	7.1	0.0	0.0	0.0	0.0	0.0	0.1	0.4	0.5	0.3	0.2	0.0	0.1
	PrecStd	1.4	0.3	0.2	0.3	0.3	0.3	0.7	0.6	0.6	0.5	0.4	0.3	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	27.2	24.1	40.6	63.9	76.3	76.3	71.6	60.0	50.6	28.8	25.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	24.4	21.9	18.8	34.4	56.2	70.7	72.0	67.0	55.4	38.4	22.9	16.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	16.3	16.3	13.8	29.2	50.8	66.9	68.7	63.0	51.4	33.3	18.2	10.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	6.7	11.1	8.6	24.9	44.4	62.4	65.5	59.6	47.6	30.5	13.8	5.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	9.8	10.5	10.5	10.8	11.6	16.4	13.6	11.4	8.6	6.5	8.9	9.4
		MCDBR	17.5	15.8	15.6	13.9	21.2	21.1	17.5	15.9	15.2	8.6	11.5	16.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.153	0.205	0.241	0.292	0.329	0.330	0.349	0.324	0.288	0.225	0.151	N/A
	taud		1.909	2.116	2.243	2.192	2.308	2.464	2.459	2.542	2.560	2.216	1.919	N/A
	Ebn at Noon		27	192	257	270	272	276	265	261	243	178	22	0
	Edh at Noon		2	13	22	32	33	29	29	23	17	11	1	0
All-Sky Solar Radiation	RadAvg		8	148	664	1382	1853	1980	1584	1043	555	176	22	0
	RadStd		1	10	32	61	129	154	138	102	51	20	2	0

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (7 neighbors)		+1.87	+3.26	+3.69	N/A	N/A	N/A	-769	-760	N/A	N/A	

Nomenclature: See separate page