

CLINTON POINT, NU, Canada

WMO: 710530

Lat: 69.580N

Lon: 120.800W

Elev: 101

StdP: 100.12

Time Zone: -7.00 (NAM)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -37.8	(c) -36.0	(d) -38.6	(e) 0.1	(f) -35.1	(g) -37.6	(h) 0.1	(i) -34.2	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) 1.095

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 5.4	(c) 18.8	(d) 13.0	(e) 16.4	(f) 11.9	(g) 14.0	(h) 10.5	(i) 13.6	(j) 17.9	(k) 12.0	(l) 16.1	(m) 10.6	(n) 13.9	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.1	8.3	15.6	9.5	7.5	13.9	8.2	6.8	12.6	38.5	18.0	34.5	16.2	30.9	13.9	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-38.9	22.6	2.4	3.0	-40.6	24.7	-42.0	26.5	-43.3	28.2	-45.1	30.4
			-37.0	16.8	1.1	2.2	-37.7	18.4	-38.4	19.7	-39.0	20.9	-39.7	22.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.6	-26.3	-26.3	-23.4	-16.1	-6.0	3.7	7.9	6.2	1.4	-7.2	-19.4	-23.1
	DBStd	13.84	5.98	7.23	6.34	6.62	5.47	4.54	4.31	4.11	3.69	5.31	6.18	6.25
	HDD10.0	7587	1125	1017	1034	784	497	197	96	134	260	534	882	1028
	HDD18.3	10573	1383	1250	1292	1034	755	439	325	376	509	792	1132	1286
	CDD10.0	57	0	0	0	0	0	8	31	17	1	0	0	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	5	0	0	0	0	0	0	4	1	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	161	4	3	3	6	8	16	33	38	27	15	7	4
	PrecMax	291	13	13	17	22	23	47	84	106	54	30	20	12
	PrecMin	95	0	0	0	0	0	2	6	2	6	2	1	0
	PrecStd	46	3	3	4	6	7	12	22	23	12	8	5	3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.3	-5.9	-2.6	4.4	8.3	19.6	22.9	21.3	14.5	5.5	-2.8	-3.7
		MCWB	-6.8	-6.3	-3.2	2.4	5.8	13.3	16.3	14.0	10.2	3.8	-3.1	-4.3
	2%	DB	-9.4	-8.2	-7.7	-0.4	6.0	16.5	19.8	17.5	11.1	3.2	-5.7	-7.5
		MCWB	-9.7	-8.6	-8.1	-1.3	4.0	11.5	13.8	13.0	8.1	2.0	-6.3	-8.1
	5%	DB	-15.1	-10.8	-11.0	-3.6	3.7	13.2	17.4	15.2	8.4	1.4	-7.5	-10.6
		MCWB	-15.6	-11.1	-11.3	-4.2	2.3	9.8	12.3	11.4	6.4	0.4	-7.9	-11.0
	10%	DB	-18.1	-14.8	-13.9	-6.8	1.2	10.3	14.7	12.6	6.3	-0.7	-10.1	-13.4
		MCWB	-18.4	-15.2	-14.3	-7.3	0.4	7.7	11.1	10.2	4.8	-1.2	-10.5	-13.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-6.7	-6.3	-2.9	3.0	6.2	13.5	16.6	15.3	10.5	4.2	-3.2	-4.3
		MCDB	-6.4	-6.2	-2.3	4.2	7.9	18.2	22.4	20.5	14.1	5.5	-2.8	-3.7
	2%	WB	-9.5	-8.4	-8.0	-1.3	4.1	11.4	14.2	13.2	8.3	2.2	-6.2	-7.9
		MCDB	-9.2	-8.1	-7.7	-0.2	5.6	16.2	18.8	17.0	10.8	3.1	-5.8	-7.5
	5%	WB	-14.9	-10.7	-11.3	-4.1	2.3	9.7	12.5	11.5	6.7	0.5	-8.0	-11.0
		MCDB	-14.5	-10.3	-10.9	-3.4	3.6	13.1	16.7	14.6	8.4	1.3	-7.5	-10.6
	10%	WB	-18.3	-14.5	-14.2	-7.3	0.4	7.7	11.1	10.0	4.9	-1.0	-10.6	-13.8
		MCDB	-18.1	-14.0	-13.9	-6.9	1.2	10.1	14.8	12.9	6.0	-0.6	-10.2	-13.4
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.5	5.2	5.3	4.4	4.8	5.4	4.9	3.6	3.5	3.8	4.8
		MCDBR	9.3	9.1	8.1	8.1	7.5	9.8	9.3	9.6	7.5	4.8	4.9	7.3
		MCWBR	9.2	9.1	7.9	7.3	6.4	6.9	5.8	5.9	5.8	4.2	4.9	7.0
	5% WB	MCDBR	9.4	9.1	8.1	7.8	7.1	9.3	8.9	9.1	7.0	4.6	4.9	7.2
		MCWBR	9.3	9.1	7.9	7.3	6.2	6.8	6.4	6.2	5.6	4.1	5.0	6.9
Clear-Sky Solar Irradiance	taub	0.156	0.210	0.244	0.294	0.335	0.343	0.358	0.341	0.296	0.235	N/A	N/A	
	taud	1.890	2.032	2.198	2.124	2.126	2.312	2.355	2.460	2.504	2.142	N/A	N/A	
	Ebn at Noon	38	547	788	837	839	848	819	794	740	496	0	0	
	Edh at Noon	3	41	71	107	123	106	99	79	56	36	0	0	
All-Sky Solar Radiation	RadAvg	0.02	0.42	2.00	4.49	6.12	6.13	5.30	3.29	1.61	0.43	0.00	0.00	
	RadStd	0.00	0.05	0.12	0.20	0.46	0.48	0.39	0.36	0.20	0.07	0.00	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		+0.56	+1.21	+1.60	N/A	N/A	N/A	N/A	-222	N/A	N/A

Nomenclature: See separate page