

MOSSLEIGH AGCM, AB, Canada

WMO: 710570

Lat: 50.6725N

Lon: 113.3486W

Elev: 3166

StdP: 13.09

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-21.3	-15.8	-27.2	1.4	-20.9	-21.6	1.9	-15.5	25.6	37.2	24.8	36.8	5.9	190	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.9	85.6	60.5	82.2	59.8	79.0	58.9	64.9	77.4	62.9	76.5	61.2	74.9	9.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.4	88.1	70.9	58.0	80.8	68.4	55.9	74.8	65.9	31.7	77.3	30.1	76.0	28.8	75.2	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	21.8	19.2	-30.8	92.3	6.1	3.9	-35.2	95.2	-38.7	97.4	-42.2	99.6	-46.6	102.5		
(5)			-31.0	69.1	6.0	2.9	-35.4	71.1	-38.9	72.8	-42.3	74.5	-46.6	76.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.9	18.7	16.2	27.6	38.6	50.3	57.0	61.7	61.0	52.5	40.1	26.9	15.4		
	DBStd	20.08	14.53	15.32	14.34	9.12	7.87	5.63	4.79	5.62	8.29	9.33	13.74	14.97		
	HDD50	5239	971	947	697	353	95	9	0	2	67	326	699	1073		
	HDD65	9566	1436	1367	1161	793	458	248	122	148	378	773	1144	1538		
	CDD50	1204	0	0	1	11	104	217	364	342	143	18	4	0		
	CDD65	55	0	0	0	0	2	7	20	22	4	0	0	0		
	CDH74	2072	0	0	0	15	145	204	652	736	309	11	0	0		
	CDH80	541	0	0	0	1	21	39	171	226	82	1	0	0		
	WSAvg	8.8	9.0	9.0	7.7	9.6	9.1	9.2	7.6	7.6	7.9	10.0	9.5	9.2		
	PrecAvg	15.9	0.4	0.4	0.8	1.0	2.4	3.7	2.2	2.0	1.4	0.7	0.5	0.4		
(15) Precipitation	PrecMax	21.6	0.9	1.2	3.1	2.6	4.1	8.0	4.0	4.0	4.8	1.7	1.1	1.2		
	PrecMin	7.2	0.0	0.0	0.1	0.3	0.5	1.9	0.6	0.2	0.2	0.2	0.0	0.0		
	PrecStd	3.4	0.3	0.3	0.7	0.6	1.2	1.7	1.3	0.9	1.2	0.4	0.4	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.8	53.7	62.1	75.0	82.8	85.6	89.4	90.0	87.0	74.3	64.9	50.8		
		MCWB	40.5	42.0	45.4	50.8	55.3	63.2	63.6	60.6	57.7	52.0	47.9	40.7		
	2%	DB	44.6	45.4	57.0	67.5	78.2	79.3	84.9	85.5	82.1	67.7	56.2	45.2		
		MCWB	37.1	37.3	43.1	47.4	54.0	58.1	62.1	60.7	56.6	49.8	43.6	37.5		
	5%	DB	41.9	41.0	52.1	61.8	73.5	75.5	80.6	82.0	77.3	62.6	50.7	40.8		
		MCWB	35.7	34.0	40.0	44.4	52.1	57.1	62.3	60.1	55.7	47.5	40.8	34.3		
	10%	DB	39.2	36.9	47.0	56.5	68.7	72.2	77.4	78.0	71.8	57.6	45.8	37.4		
		MCWB	34.0	32.0	37.8	41.8	50.0	55.6	61.6	59.2	53.5	44.8	37.4	32.1		
	0.4%	WB	40.5	42.2	46.7	51.7	56.7	65.1	69.2	66.0	60.5	54.3	48.2	41.7		
		MCDB	48.4	52.9	59.6	72.3	77.4	78.4	79.6	78.0	79.5	70.5	64.3	49.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.6	37.6	43.5	48.1	54.9	61.5	66.0	63.6	58.0	51.0	44.5	37.6		
		MCDB	43.8	45.2	55.4	65.0	74.0	74.9	77.9	78.4	76.4	65.0	54.5	44.3		
	5%	WB	36.0	34.5	40.8	45.4	53.1	58.9	64.0	62.0	56.1	48.2	41.3	34.7		
		MCDB	41.6	40.2	50.5	60.4	71.0	71.6	76.2	77.3	73.8	60.9	50.2	40.4		
	10%	WB	34.0	32.0	37.9	42.5	51.1	56.9	62.3	60.2	54.3	45.5	38.0	32.1		
		MCDB	39.3	36.4	46.8	54.5	65.7	68.7	75.0	74.9	70.8	56.6	45.0	37.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.9	21.5	22.1	25.0	25.6	24.6	27.9	28.9	28.6	26.6	22.6	20.6		
		MCDBR	21.9	25.5	29.3	36.7	35.6	32.0	35.2	37.8	40.3	35.4	28.8	22.8		
		MCWBR	15.8	17.9	17.1	18.8	15.5	14.6	17.2	16.3	17.7	18.7	17.7	16.5		
		MCDBR	21.4	24.6	27.7	35.3	31.5	27.7	30.7	32.0	36.5	33.7	27.8	22.2		
	5% WB	MCWBR	15.7	17.8	16.9	18.6	13.9	14.1	16.6	15.4	16.7	18.3	17.6	16.3		
(40) Clear-Sky Solar Irradiance	taub		0.257	0.265	0.286	0.331	0.346	0.342	0.342	0.359	0.317	0.281	0.256	0.235		
	taud		2.401	2.458	2.462	2.344	2.359	2.412	2.427	2.369	2.461	2.533	2.488	2.423		
	Ebn at Noon		253	283	295	289	288	290	288	277	279	273	254	247		
	Edh at Noon		19	23	28	36	37	35	34	35	28	22	17	16		
(44) All-Sky Solar Radiation	RadAvg		379	694	1116	1528	1827	1994	2162	1732	1225	752	409	286		
	RadStd		29	65	84	108	128	125	107	114	116	86	37	25		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (78 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page