

MOSSLEIGH AGCM, AB, Canada

WMO: 710570

Lat: 50.6725N

Lon: 113.3486W

Elev: 965

StdP: 90.26

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-29.6	-26.6	-32.9	0.2	-29.4	-29.8	0.3	-26.4	11.4	2.9	11.1	2.7	2.7	190	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	29.8	15.9	27.9	15.4	26.1	15.0	18.3	25.2	17.2	24.7	16.2	23.8	4.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.8	12.6	21.6	14.4	11.5	20.2	13.3	10.7	18.9	55.8	25.2	52.1	24.5	49.0	24.0	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.7	8.6	DB	-34.9	33.5	3.4	2.2	-37.3	35.1	-39.3	36.4	-41.2	37.6	-43.7	39.2	(4)
(5)			WB	-35.0	20.6	3.3	1.6	-37.4	21.7	-39.4	22.7	-41.3	23.6	-43.7	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.9	-7.4	-8.8	-2.5	3.7	10.2	13.9	16.5	16.1	11.4	4.5	-2.9	-9.2	(6)	
	DBStd	11.16	8.07	8.51	7.97	5.07	4.37	3.13	2.66	3.12	4.61	5.18	7.63	8.32	(7)	
	HDD10.0	2911	539	526	387	196	53	5	0	1	37	181	388	596	(8)	
	HDD18.3	5314	798	759	645	441	254	138	68	82	210	429	636	854	(9)	
	CDD10.0	669	0	0	1	6	58	121	202	190	79	10	2	0	(10)	
	CDD18.3	31	0	0	0	0	1	4	11	12	2	0	0	0	(11)	
	CDH23.3	1151	0	0	0	8	81	113	362	409	172	6	0	0	(12)	
	CDH26.7	301	0	0	0	1	12	22	95	126	46	1	0	0	(13)	
(14) Wind	WSAvg	3.9	4.0	4.0	3.4	4.3	4.1	4.1	3.4	3.4	3.5	4.5	4.2	4.1	(14)	
(15) Precipitation	PrecAvg	404	10	11	21	25	61	93	55	50	36	18	13	10	(15)	
	PrecMax	549	24	30	78	66	105	204	102	102	122	44	28	31	(16)	
	PrecMin	183	0	0	2	7	12	49	15	4	4	6	1	0	(17)	
	PrecStd	87	8	8	18	14	30	44	32	23	30	11	9	10	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	12.1	16.7	23.9	28.2	29.8	31.9	32.2	30.5	23.5	18.3	10.5	(19)	
		MCWB	4.7	5.6	7.4	10.4	12.9	17.3	17.6	15.9	14.3	11.1	8.8	4.8	(20)	
	2%	DB	7.0	7.4	13.9	19.7	25.7	26.3	29.4	29.7	27.8	19.9	13.4	7.3	(21)	
		MCWB	2.9	2.9	6.2	8.6	12.2	14.5	16.7	16.0	13.7	9.9	6.5	3.0	(22)	
	5%	DB	5.5	5.0	11.2	16.5	23.0	24.2	27.0	27.8	25.2	17.0	10.4	4.9	(23)	
		MCWB	2.1	1.1	4.5	6.9	11.2	14.0	16.8	15.6	13.1	8.6	4.9	1.3	(24)	
	10%	DB	4.0	2.7	8.3	13.6	20.4	22.4	25.2	25.6	22.1	14.2	7.7	3.0	(25)	
		MCWB	1.1	0.0	3.2	5.4	10.0	13.1	16.5	15.1	11.9	7.1	3.0	0.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.7	5.7	8.2	10.9	13.7	18.4	20.7	18.9	15.9	12.4	9.0	5.4	(27)	
		MCDB	9.1	11.6	15.3	22.4	25.2	25.8	26.5	25.6	26.4	21.4	17.9	9.4	(28)	
	2%	WB	3.1	3.1	6.4	8.9	12.7	16.4	18.9	17.6	14.5	10.6	6.9	3.1	(29)	
		MCDB	6.6	7.4	13.0	18.3	23.3	23.8	25.5	25.8	24.7	18.3	12.5	6.8	(30)	
	5%	WB	2.2	1.4	4.9	7.4	11.7	15.0	17.8	16.6	13.4	9.0	5.2	1.5	(31)	
		MCDB	5.3	4.5	10.3	15.8	21.6	22.0	24.6	25.2	23.2	16.1	10.1	4.6	(32)	
	10%	WB	1.1	0.0	3.3	5.8	10.6	13.8	16.8	15.7	12.4	7.5	3.3	0.0	(33)	
		MCDB	4.0	2.5	8.2	12.5	18.7	20.4	23.9	23.9	21.6	13.7	7.2	3.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	11.9	12.3	13.9	14.2	13.7	15.5	16.1	15.9	14.8	12.6	11.5	(35)	
		MCDBR	12.2	14.2	16.3	20.4	19.8	17.8	19.5	21.0	22.4	19.7	16.0	12.7	(36)	
	5% WB	MCWBR	8.8	9.9	9.5	10.4	8.6	8.1	9.5	9.0	9.8	10.4	9.9	9.1	(37)	
		MCWBR	11.9	13.6	15.4	19.6	17.5	15.4	17.1	17.8	20.3	18.7	15.4	12.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.257	0.265	0.286	0.331	0.346	0.342	0.342	0.359	0.317	0.281	0.256	0.235	(40)	
		taud	2.401	2.458	2.462	2.344	2.359	2.412	2.427	2.369	2.461	2.533	2.488	2.423	(41)	
	Ebn at Noon		798	893	930	911	909	913	907	872	880	861	802	780	(42)	
		Edh at Noon	59	74	89	112	116	111	108	109	88	68	54	49	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.20	2.19	3.52	4.82	5.76	6.29	6.82	5.46	3.86	2.37	1.29	0.90	(44)	
	RadStd		0.09	0.20	0.27	0.34	0.40	0.39	0.34	0.36	0.36	0.27	0.12	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (78 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page