

CROKER RIVER, NU, CanadaWMO: **710590**Lat: **69.280N**Lon: **119.220W**Elev: **69**StdP: **100.49**Time Zone: **-7.00 (NAM)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-35.9	-34.4	N/A	N/A	N/A	N/A	N/A	N/A	20.6	-19.3	18.7	-19.2	5.8	120	1.087

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	21.5	N/A	18.7	N/A	16.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.0	14.4	12.5	DB	-37.7	25.0	1.7	2.6	-38.9	26.9	-39.9	28.4	-40.8	29.8	-42.1	31.7	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.4	-24.3	-25.2	-23.6	-15.7	-5.3	5.1	9.2	8.1	2.3	-6.5	-15.5	-22.1
	DBStd	13.74	6.13	5.95	5.98	6.02	5.65	4.73	4.62	4.31	3.89	4.48	5.15	5.57
	HDD10.0	7167	1063	987	1041	772	473	163	72	92	232	513	764	996
	HDD18.3	10116	1321	1220	1299	1022	731	397	284	320	481	771	1014	1254
	CDD10.0	96	0	0	0	0	0	15	48	31	2	0	0	0
	CDD18.3	3	0	0	0	0	0	0	2	1	0	0	0	0
	CDH23.3	31	0	0	0	0	0	7	14	10	0	0	0	0
	CDH26.7	2	0	0	0	0	0	1	1	1	0	0	0	0
(14) Wind	WSAvg	5.9	6.6	5.8	5.6	5.5	5.6	5.8	5.5	5.4	5.9	6.3	6.4	6.2
(15) Precipitation	PrecAvg	219	9	8	10	7	11	19	37	42	30	21	14	11
	PrecMax	272	25	28	39	17	30	38	90	95	65	37	40	28
	PrecMin	146	3	2	2	1	2	6	13	21	8	7	4	3
	PrecStd	35	5	6	7	4	7	8	14	18	12	8	8	5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-4.0	-7.1	-4.8	2.9	9.6	24.2	25.5	24.7	15.1	5.3	-0.1	-5.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	-9.0	-9.8	-8.9	-1.7	6.3	19.1	21.7	20.7	11.9	1.8	-3.6	-9.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-12.3	-13.2	-12.1	-4.5	4.1	15.7	19.1	17.5	9.7	0.3	-5.9	-11.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-15.7	-16.5	-14.7	-7.0	2.0	12.8	16.8	14.8	7.7	-0.8	-8.0	-14.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.2	6.4	6.7	5.6	6.5	7.0	6.1	4.3	4.6	5.5	5.6
		MCDBR	9.7	9.4	9.2	8.6	8.0	12.9	11.9	11.2	8.1	4.7	6.8	7.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.158	0.207	0.246	0.292	0.332	0.328	0.355	0.339	0.303	0.232	0.155	N/A
	taud		1.887	2.049	2.188	2.127	2.131	2.357	2.382	2.480	2.491	2.170	1.919	N/A
	Ebn at Noon		52	569	789	842	844	866	825	800	734	521	43	0
	Edh at Noon		4	42	73	108	122	101	96	78	58	36	3	0
(44) All-Sky Solar Radiation	RadAvg		0.02	0.46	2.12	4.59	6.31	6.33	5.31	3.35	1.60	0.44	0.06	0.00
	RadStd		0.00	0.04	0.10	0.21	0.50	0.52	0.41	0.34	0.17	0.06	0.01	0.00

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	+1.37	+1.60	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page