

NORDEGG, AB, Canada

WMO: 710600

Lat: 52.471N

Lon: 116.077W

Elev: 1332

StdP: 86.31

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-29.8	-26.0	-33.3	0.2	-29.7	-29.2	0.3	-25.4	7.6	3.4	6.4	2.8	0.9	280	0.652

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	26.6	13.7	24.6	13.3	22.7	12.6	15.7	22.4	14.7	21.4	13.7	20.4	2.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.5	11.4	17.3	12.3	10.5	16.2	11.2	9.7	15.4	49.0	22.7	45.8	21.4	42.8	20.3	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.4	4.6	DB	-35.3	29.7	2.7	1.7	-37.2	30.9	-38.8	32.0	-40.2	32.9	-42.2	34.2	(4)
(5)			WB	-35.6	17.7	2.2	1.3	-37.2	18.6	-38.5	19.3	-39.8	20.1	-41.4	21.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.6	-6.8	-6.9	-2.8	1.7	6.9	10.7	13.9	12.9	8.5	3.0	-3.0	-7.9	(6)	
	DBStd	9.56	8.43	7.57	7.01	4.73	4.22	3.22	3.09	3.28	4.30	4.92	6.67	7.67	(7)	
	HDD10.0	3044	519	474	396	251	114	28	4	11	79	222	389	556	(8)	
	HDD18.3	5758	778	708	654	499	354	230	140	170	296	476	639	814	(9)	
	CDD10.0	333	0	0	0	1	18	49	126	101	34	4	1	0	(10)	
	CDD18.3	5	0	0	0	0	0	1	3	1	0	0	0	0	(11)	
	CDH23.3	312	0	0	0	0	6	31	151	94	30	0	0	0	(12)	
	CDH26.7	51	0	0	0	0	0	4	29	15	3	0	0	0	(13)	
(14) Wind	WSAvg	1.7	1.9	1.7	2.0	1.9	1.8	1.7	1.6	1.5	1.5	1.6	1.8	1.7	(14)	
(15) Precipitation	PrecAvg	605	28	17	28	38	72	100	111	82	63	31	21	25	(15)	
	PrecMax	812	103	49	79	78	158	265	292	172	158	76	42	66	(16)	
	PrecMin	436	0	0	6	11	16	38	23	22	6	6	4	4	(17)	
	PrecStd	118	26	12	17	18	38	49	65	41	40	19	11	17	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	10.1	14.1	19.6	24.2	27.0	29.5	28.8	26.6	20.3	13.7	9.7	(19)	
		MCWB	3.4	2.5	4.7	8.2	10.5	13.1	14.5	14.2	12.7	9.8	5.7	3.6	(20)	
	2%	DB	7.7	7.6	10.5	15.7	21.7	23.5	27.1	25.7	23.4	16.3	10.8	6.9	(21)	
		MCWB	2.1	1.4	3.0	6.6	9.5	12.2	13.9	13.7	12.5	8.0	4.3	1.4	(22)	
	5%	DB	5.9	5.5	8.6	12.9	19.0	21.0	24.8	23.8	20.5	13.7	8.1	4.6	(23)	
		MCWB	1.0	0.2	2.2	4.9	9.0	11.0	14.1	13.4	11.4	6.8	2.8	0.0	(24)	
	10%	DB	3.9	3.2	6.5	10.2	16.3	18.8	22.5	21.6	17.2	11.1	5.7	2.4	(25)	
		MCWB	-0.2	-1.3	0.9	3.3	7.9	10.4	13.3	13.0	9.9	5.3	1.3	-1.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	3.2	5.2	8.6	11.7	15.4	17.4	17.0	14.7	10.6	6.5	4.0	(27)	
		MCDB	9.3	8.8	12.9	17.6	20.7	22.2	24.0	22.9	22.0	18.6	12.8	9.5	(28)	
	2%	WB	2.6	1.7	3.7	7.0	10.5	13.6	16.1	15.6	13.2	8.7	4.7	1.7	(29)	
		MCDB	7.2	7.0	9.4	14.7	19.0	20.0	22.8	22.2	21.0	15.1	10.0	6.2	(30)	
	5%	WB	1.2	0.3	2.4	5.4	9.5	12.3	15.0	14.6	11.9	7.2	3.1	0.3	(31)	
		MCDB	5.3	5.0	7.8	11.8	17.5	18.7	21.8	21.1	19.4	12.8	7.6	4.4	(32)	
	10%	WB	0.0	-1.1	1.2	3.9	8.4	11.3	14.0	13.5	10.6	5.7	1.6	-1.2	(33)	
		MCDB	3.8	2.8	6.2	9.5	15.9	17.2	20.7	20.0	17.0	10.4	5.4	2.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	12.6	12.3	11.9	12.8	12.7	13.9	14.0	13.2	11.9	10.3	10.3	(35)	
		MCDBR	11.1	13.0	14.0	16.7	18.6	17.2	18.8	18.9	19.3	16.1	11.9	11.2	(36)	
	5% WB	MCWBR	6.5	8.0	7.9	8.7	8.5	7.8	8.0	8.5	9.1	8.6	7.0	7.1	(37)	
		MCWBR	10.9	12.9	13.3	15.9	17.0	14.8	16.3	16.7	18.6	15.7	11.5	11.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.253	0.253	0.279	0.313	0.331	0.350	0.345	0.353	0.318	0.279	0.247	0.234	(40)	
		taud	2.478	2.553	2.506	2.421	2.424	2.394	2.453	2.403	2.496	2.594	2.551	2.469	(41)	
	Ebn at Noon		786	900	929	926	920	902	901	872	870	852	795	751	(42)	
		Edh at Noon	52	64	83	102	108	112	104	103	84	62	47	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.92	1.79	2.96	4.26	5.10	5.27	5.69	4.81	3.35	1.97	1.00	0.72	(44)	
	RadStd		0.07	0.15	0.24	0.39	0.40	0.42	0.41	0.30	0.38	0.21	0.08	0.06	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page