

INDIN RIVER, NT, Canada

WMO: 710614

Lat: 64.390N

Lon: 115.020W

Elev: 1000

StdP: 14.17

Time Zone: -7.00 (NAM)

Period: 91-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-51.7	-48.5	-56.0	0.2	-50.7	-52.4	0.3	-47.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	78.7	61.5	75.1	59.8	71.5	58.5	63.7	74.3	61.8	71.7	59.9	69.3	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.9	80.0	66.6	57.8	73.9	64.7	55.8	68.7	62.8	29.5	74.2	28.1	71.6	26.8	69.7	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-54.4	85.1	2.9	2.7	-56.5	87.0	-58.2	88.6	-59.8	90.1	-62.0	92.0		
(5)			-54.4	66.9	2.9	2.5	-56.5	68.7	-58.2	70.2	-59.8	71.6	-62.0	73.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	-22.2	-16.0	-6.6	12.2	33.8	51.6	58.7	53.4	41.5	24.1	3.0	-12.7		
	DBStd	30.72	16.98	15.00	15.53	14.69	10.77	7.43	6.93	7.23	8.08	10.26	13.41	17.09		
	HDD50	12035	2238	1848	1756	1133	508	67	12	47	273	801	1409	1943		
	HDD65	16967	2703	2268	2221	1583	968	405	216	365	705	1266	1859	2408		
	CDD50	569	0	0	0	0	5	114	280	152	18	0	0	0		
	CDD65	26	0	0	0	0	0	2	19	5	0	0	0	0		
	CDH74	438	0	0	0	0	0	89	267	82	0	0	0	0		
	CDH80	81	0	0	0	0	0	21	54	6	0	0	0	0		
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(15) Precipitation	PrecAvg	11.7	0.5	0.4	0.5	0.4	0.7	1.4	1.9	2.0	1.5	1.1	0.7	0.6		
	PrecMax	13.9	1.0	0.8	1.1	0.6	1.4	3.7	3.7	3.2	3.1	1.7	1.5	1.1		
	PrecMin	8.8	0.2	0.2	0.1	0.2	0.2	0.3	1.0	0.7	0.4	0.4	0.4	0.2		
	PrecStd	1.4	0.2	0.2	0.2	0.2	0.4	0.7	0.7	0.6	0.3	0.2	0.2	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	19.0	35.5	50.6	64.9	83.6	85.8	80.2	67.2	50.9	32.9	25.2		
		MCWB	21.8	18.1	32.2	41.2	53.0	62.7	65.7	61.8	55.3	45.6	32.1	24.7		
	2%	DB	14.9	15.2	27.9	45.0	60.0	75.7	80.1	76.5	62.4	41.2	30.0	20.8		
		MCWB	14.4	14.5	24.8	37.8	48.8	58.9	63.3	61.0	53.6	38.2	29.5	20.3		
	5%	DB	9.1	11.1	23.7	40.2	55.3	71.0	76.4	71.4	58.3	37.9	25.8	16.6		
		MCWB	8.6	10.3	22.0	34.8	45.2	56.8	60.8	59.1	52.0	36.2	25.1	16.2		
	10%	DB	3.5	7.0	19.2	35.7	51.0	67.2	73.5	67.2	53.4	35.5	22.4	11.6		
		MCWB	2.9	6.4	17.9	32.3	42.8	54.5	59.7	56.9	48.6	34.2	21.8	11.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.6	18.1	32.6	41.2	53.9	62.7	67.1	64.3	57.5	45.4	32.5	24.7		
		MCDB	22.4	18.8	35.0	50.0	63.6	81.4	80.9	72.8	63.0	50.1	32.7	25.7		
	2%	WB	14.2	14.7	25.1	38.1	49.7	60.0	64.8	62.2	54.7	39.2	29.3	20.2		
		MCDB	14.7	15.2	27.5	44.2	58.8	72.2	76.4	72.7	60.4	40.8	29.8	20.6		
	5%	WB	8.6	10.7	22.1	35.3	45.9	57.9	63.0	60.4	52.2	36.4	25.2	16.1		
		MCDB	9.1	11.5	23.9	39.5	54.3	68.5	72.3	70.0	57.5	37.6	25.7	16.5		
	10%	WB	3.1	6.6	18.0	32.3	42.9	55.8	61.2	58.3	49.6	34.4	21.7	11.1		
		MCDB	3.7	7.1	19.3	35.8	50.6	65.5	70.3	65.4	52.7	35.3	22.4	11.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.8	21.7	27.5	27.9	19.7	20.7	20.3	18.5	13.5	10.2	16.0	17.8		
		MCDBR	18.7	20.2	27.5	30.1	26.9	29.0	26.8	25.7	22.5	11.4	13.8	18.4		
		MCWBR	18.2	19.4	24.3	22.9	15.8	13.6	11.0	11.6	13.4	8.3	12.4	17.7		
	5% WB	MCDBR	17.8	20.1	26.9	28.4	25.8	26.4	22.5	23.0	19.9	10.5	11.9	17.9		
		MCWBR	17.2	19.3	23.9	22.0	15.6	13.0	10.4	11.2	12.3	8.0	11.8	17.9		
(40) Clear-Sky Solar Irradiance	taub		0.160	0.227	0.252	0.289	0.323	0.326	0.356	0.328	0.296	0.253	0.156	0.146		
	taud		1.949	2.216	2.261	2.222	2.376	2.495	2.420	2.514	2.575	2.379	1.952	1.937		
	Ebn at Noon		142	228	271	282	282	283	269	269	257	216	138	65		
	Edh at Noon		8	17	25	34	32	30	31	26	20	15	7	3		
(44) All-Sky Solar Radiation	RadAvg		61	308	893	1611	1902	1918	1667	1222	705	234	62	20		
	RadStd		4	16	37	80	141	158	92	92	63	28	11	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page