

PEACE RIVER, AB, Canada

WMO: 710680

Lat: 56.230N

Lon: 117.450W

Elev: 571

StdP: 94.65

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.4	-30.7	-39.1	0.1	-34.4	-35.4	0.1	-30.5	11.0	2.4	9.8	-0.3	1.6	220	0.694

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	27.5	17.0	25.7	16.0	24.0	15.1	18.3	25.4	17.2	23.6	16.2	22.3	4.1	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	11.9	21.1	14.5	11.1	19.8	13.5	10.3	18.8	54.0	25.8	50.4	23.6	47.3	22.4	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.3	7.5	DB	-37.8	30.5	4.2	1.7	-40.8	31.7	-43.2	32.7	-45.6	33.6	-48.6	34.9	(4)
(5)			WB	-37.9	20.0	4.1	1.5	-40.8	21.0	-43.2	21.9	-45.6	22.7	-48.5	23.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.7	-14.6	-11.9	-6.2	3.1	10.2	14.4	16.4	15.0	10.1	3.0	-7.0	-13.1	(6)	
	DBStd	12.80	9.66	8.08	7.79	5.20	4.43	3.08	2.76	3.35	4.20	4.71	7.06	8.50	(7)	
	HDD10.0	3645	762	614	503	210	52	3	1	3	49	220	511	716	(8)	
	HDD18.3	6102	1020	848	762	456	254	122	71	111	248	475	761	974	(9)	
	CDD10.0	612	0	0	0	4	57	136	201	159	51	4	0	0	(10)	
	CDD18.3	27	0	0	0	0	1	4	13	9	1	0	0	0	(11)	
	CDH23.3	499	0	0	0	2	33	92	197	151	23	0	0	0	(12)	
	CDH26.7	87	0	0	0	0	5	12	34	34	2	0	0	0	(13)	
(14) Wind	WSAvg	3.2	2.9	2.9	3.3	3.7	3.8	3.4	3.1	3.1	3.3	3.4	3.0	2.9	(14)	
(15) Precipitation	PrecAvg	412	24	22	16	17	33	67	64	55	43	23	25	21	(15)	
	PrecMax	660	60	65	37	61	123	150	143	121	151	51	49	58	(16)	
	PrecMin	211	4	1	1	1	3	9	15	8	11	3	0	4	(17)	
	PrecStd	89	14	17	10	13	29	41	34	31	30	12	14	13	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	5.5	10.1	21.3	26.7	28.4	29.7	30.0	26.2	20.1	10.0	6.6	(19)	
		MCWB	2.8	2.2	5.1	10.4	14.0	16.5	18.7	18.1	16.0	12.0	5.7	3.0	(20)	
	2%	DB	4.1	3.6	7.2	16.8	23.6	25.9	27.4	27.1	23.1	15.1	6.1	3.9	(21)	
		MCWB	1.4	0.8	3.0	8.0	12.4	15.2	17.5	17.5	14.5	8.8	2.9	1.2	(22)	
	5%	DB	1.8	1.7	5.2	14.0	21.3	24.0	25.6	24.7	20.4	12.4	3.8	1.6	(23)	
		MCWB	-0.3	-0.7	1.7	6.5	11.4	14.4	16.8	16.1	13.1	7.0	1.4	-0.6	(24)	
	10%	DB	-0.8	-0.6	3.7	11.7	19.1	22.0	23.7	22.7	18.1	10.4	1.8	-1.0	(25)	
		MCWB	-2.6	-2.6	0.7	5.3	10.3	13.6	15.8	15.1	11.7	5.9	-0.1	-2.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	2.5	5.2	10.8	14.9	18.0	20.2	19.5	16.9	12.4	5.8	3.1	(27)	
		MCDB	5.8	4.9	9.7	20.1	24.2	25.8	27.0	27.0	24.4	19.4	9.7	6.5	(28)	
	2%	WB	1.6	1.0	3.2	8.4	13.3	16.4	18.7	18.1	15.1	9.3	3.3	1.2	(29)	
		MCDB	3.9	3.4	6.6	16.2	21.7	23.5	25.3	25.5	22.0	14.0	5.8	3.7	(30)	
	5%	WB	-0.1	-0.6	2.0	6.9	12.0	15.3	17.5	16.9	13.7	7.5	1.5	-0.5	(31)	
		MCDB	1.8	1.7	4.9	13.2	19.9	22.2	23.9	23.3	19.6	11.5	3.5	1.4	(32)	
	10%	WB	-2.7	-2.6	0.8	5.5	10.8	14.2	16.5	15.7	12.2	6.2	0.0	-2.5	(33)	
		MCDB	-0.9	-0.6	3.5	11.1	18.1	20.5	22.4	21.4	17.2	10.1	1.6	-1.0	(34)	
(35) Mean Daily Temperature Range	MDBR		8.8	9.8	10.2	11.0	12.6	11.5	11.9	12.3	12.0	9.6	7.9	8.6	(35)	
	5% DB	MCDBR	10.8	11.2	10.8	15.7	16.4	15.4	15.6	16.0	16.3	13.3	9.7	10.3	(36)	
		MCWBR	8.9	9.2	7.7	9.2	8.4	7.4	7.6	7.9	9.0	8.5	7.5	8.6	(37)	
	5% WB	MCDBR	10.6	11.1	10.4	14.5	15.0	13.4	14.0	14.3	15.6	12.6	9.3	10.1	(38)	
		MCWBR	8.9	9.2	7.5	8.7	7.9	6.9	7.4	7.6	8.9	8.3	7.4	8.6	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.241	0.247	0.291	0.327	0.340	0.352	0.353	0.349	0.311	0.283	0.242	0.224	(40)	
	taud		2.258	2.341	2.310	2.374	2.409	2.397	2.414	2.409	2.525	2.558	2.418	2.218	(41)	
	Ebn at Noon		688	848	879	894	900	890	882	861	856	801	704	612	(42)	
	Edh at Noon		50	69	94	103	106	109	105	99	77	57	43	40	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.70	1.68	3.23	4.67	5.62	5.98	5.82	4.72	3.23	1.72	0.75	0.47	(44)	
	RadStd		0.07	0.15	0.27	0.30	0.43	0.48	0.38	0.40	0.26	0.22	0.07	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page