

THUNDER BAY, ON, Canada

WMO: 710720

Lat: 48.3694N

Lon: 89.3272W

Elev: 654

StdP: 14.35

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.1	-16.1	-29.8	1.1	-20.0	-25.0	1.4	-15.2	22.9	9.5	20.8	10.8	6.1	250	0.650

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.3	84.1	68.7	80.9	66.6	77.9	65.0	71.3	80.7	69.0	77.5	66.9	74.8	10.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.8	104.8	76.8	65.8	97.6	73.7	63.8	90.9	71.1	35.5	81.2	33.5	77.6	31.9	75.0	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.7	18.9	16.7	-29.1	90.2	6.9	3.5	-34.1	92.7	-38.1	94.7	-42.0	96.7	-47.0	99.2		
			-29.3	75.5	6.8	2.0	-34.2	77.0	-38.3	78.2	-42.1	79.3	-47.1	80.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.2	8.0	11.6	23.4	36.6	48.5	58.7	64.6	63.1	55.1	42.4	29.0	15.5
	DBStd	21.73	13.50	12.65	11.96	8.09	7.06	6.16	5.41	5.65	7.66	7.84	10.34	12.63
	HDD50	5728	1303	1076	825	406	114	6	0	0	36	261	632	1069
	HDD65	9926	1768	1496	1290	851	513	205	75	104	309	700	1081	1534
	CDD50	1412	0	0	1	4	66	267	452	407	187	27	1	0
	CDD65	135	0	0	0	0	1	16	62	45	11	0	0	0
	CDH74	1658	0	0	0	2	70	266	720	494	104	2	0	0
	CDH80	363	0	0	0	0	13	58	174	99	19	0	0	0
	WSAvg	7.3	7.5	7.6	7.6	8.2	8.2	7.1	6.7	6.4	6.5	7.5	7.5	7.3
	PrecAvg	28.8	1.3	1.0	1.6	2.0	2.9	3.3	3.4	3.5	3.4	2.5	2.1	1.7
(15) Precipitation	PrecMax	41.9	3.3	2.5	4.1	5.7	7.1	6.9	8.8	6.9	11.4	6.8	4.6	4.0
	PrecMin	20.4	0.3	0.2	0.4	0.2	0.4	1.3	0.3	1.1	1.0	0.4	0.4	0.5
	PrecStd	5.8	0.7	0.7	0.9	1.1	1.4	1.4	1.9	1.5	2.1	1.5	1.1	0.9
	PrecStd	5.8	0.7	0.7	0.9	1.1	1.4	1.4	1.9	1.5	2.1	1.5	1.1	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.7	43.0	56.7	70.3	81.5	86.1	88.5	86.8	82.6	71.8	58.1	42.0
		MCWB	35.6	37.6	46.8	52.2	60.4	69.1	71.0	71.8	68.0	59.9	49.3	37.3
	2%	DB	34.9	37.4	47.7	61.5	74.4	80.5	84.6	82.8	76.6	65.5	50.5	38.2
		MCWB	33.0	34.0	40.3	47.0	56.8	64.3	69.3	68.7	65.7	56.1	44.7	35.7
	5%	DB	32.3	34.4	42.5	56.3	67.9	76.6	81.3	79.3	72.6	60.3	46.9	35.7
		MCWB	30.9	32.1	37.4	44.3	54.6	62.4	67.5	66.8	63.2	53.5	42.9	34.0
	10%	DB	28.6	31.0	38.7	51.3	62.9	72.6	78.0	76.2	68.7	55.6	43.3	33.4
		MCWB	26.9	28.5	34.9	41.8	51.7	60.5	65.6	65.1	61.1	50.6	40.2	31.8
	0.4%	WB	36.0	38.3	48.6	53.6	63.9	71.7	74.8	74.0	70.8	62.7	50.6	38.9
		MCDB	38.0	42.0	54.9	66.8	76.1	84.0	85.3	84.0	79.4	68.5	55.7	40.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	33.3	34.8	41.6	48.7	59.2	66.8	71.5	71.0	67.5	57.7	46.3	35.9
		MCDB	34.6	36.7	46.2	59.3	69.0	76.3	81.1	79.8	73.4	63.7	49.5	37.3
	5%	WB	30.8	32.3	38.0	45.4	56.3	64.2	69.1	68.7	64.8	54.2	43.1	34.1
		MCDB	32.4	34.6	41.9	53.9	65.3	73.4	78.3	76.8	70.8	58.7	46.0	35.6
	10%	WB	26.9	28.6	35.3	42.5	53.4	61.9	66.9	66.6	62.4	51.2	40.2	31.7
		MCDB	28.6	30.7	38.6	50.3	61.4	70.1	75.5	73.8	67.3	55.1	43.2	33.3
(35) Mean Daily Temperature Range	5% DB	MDBR	19.0	21.2	20.5	21.1	22.8	22.1	22.3	22.6	21.6	17.8	15.2	16.4
		MCDBR	17.9	20.0	22.4	32.3	32.8	29.6	27.3	27.3	26.4	26.1	20.9	16.2
		MCWBR	16.6	17.0	16.0	19.4	18.0	15.8	14.4	15.2	16.3	17.6	15.6	14.2
	5% WB	MCDBR	16.9	18.6	19.8	28.8	27.2	25.3	25.1	25.0	22.7	22.6	18.3	14.9
		MCWBR	15.9	16.3	14.6	18.4	16.1	15.2	14.6	15.2	15.1	16.4	14.5	13.6
		MCWBR	15.9	16.3	14.6	18.4	16.1	15.2	14.6	15.2	15.1	16.4	14.5	13.6
(40) Clear-Sky Solar Irradiance	taub		0.262	0.272	0.306	0.346	0.362	0.382	0.398	0.380	0.357	0.316	0.290	0.265
	taud		2.399	2.367	2.378	2.369	2.404	2.371	2.373	2.424	2.477	2.557	2.524	2.444
	Ebn at Noon		262	284	290	287	285	279	272	273	269	266	250	246
	Edh at Noon		21	27	31	36	36	37	37	33	29	23	19	18
(44) All-Sky Solar Radiation	RadAvg		342	665	1075	1498	1736	1867	1881	1618	1160	685	362	279
	RadStd		41	70	93	153	115	129	104	121	81	86	36	27

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page