

URANIUM CITY, SK, Canada

WMO: 710760

Lat: 59.562N

Lon: 108.478W

Elev: 1044

StdP: 14.15

Time Zone: -6.00 (W06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.6	-36.4	-46.5	0.4	-39.1	-42.7	0.5	-35.5	15.1	-0.4	13.6	-1.8	3.7	70	0.680

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	79.8	61.1	76.8	60.1	73.6	58.8	64.1	74.4	62.3	71.9	60.6	69.9	5.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.3	81.3	66.7	58.5	76.0	65.6	56.6	71.0	64.3	29.9	74.7	28.5	71.8	27.4	70.2	70.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.0	13.9	12.1	-45.5	85.3	4.3	3.3	-48.7	87.7	-51.2	89.6	-53.6	91.5	-56.8	93.9		
(5)			-44.4	67.0	4.0	1.5	-47.3	68.1	-49.6	68.9	-51.9	69.8	-54.8	70.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	-10.5	-4.7	7.5	26.2	42.8	56.9	61.5	57.6	47.1	32.3	13.0	-3.1		
	DBStd	27.66	15.33	14.28	15.62	13.07	9.97	7.42	5.62	6.09	7.73	8.30	12.29	15.44		
	HDD50	9192	1876	1531	1319	715	264	24	1	11	145	551	1109	1646		
	HDD65	13784	2341	1951	1784	1164	689	257	137	239	537	1015	1559	2111		
	CDD50	935	0	0	0	1	41	231	357	246	58	1	0	0		
	CDD65	53	0	0	0	0	1	14	29	9	0	0	0	0		
	CDH74	596	0	0	0	0	17	179	301	92	7	0	0	0		
	CDH80	74	0	0	0	0	2	22	39	11	0	0	0	0		
	WSAvg	5.4	4.2	4.7	5.5	6.1	6.3	5.9	5.3	5.3	5.6	5.8	5.5	4.3		
	PrecAvg	14.9	0.9	0.6	0.8	0.9	0.9	1.6	2.2	2.2	1.6	1.5	1.2	0.9		
(15) Precipitation	PrecMax	19.6	1.5	1.3	1.4	3.6	2.2	4.3	4.3	4.9	3.5	3.5	2.6	2.3		
	PrecMin	7.7	0.2	0.1	0.3	0.0	0.2	0.6	0.2	0.7	0.6	0.2	0.4	0.3		
	PrecStd	2.6	0.4	0.3	0.4	0.7	0.6	0.8	1.1	1.1	0.8	0.8	0.6	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	30.6	44.6	61.4	76.2	82.7	83.9	80.7	73.3	58.3	39.4	29.7		
		MCWB	27.0	28.4	36.2	46.4	55.0	60.5	63.8	63.2	59.2	50.0	36.4	28.9		
	2%	DB	21.1	24.9	39.1	53.9	70.1	78.9	80.4	76.4	67.5	51.2	34.7	25.1		
		MCWB	20.6	23.7	33.3	42.0	52.2	59.2	62.0	61.6	56.2	44.7	33.0	24.4		
	5%	DB	16.1	20.7	34.3	49.2	65.3	75.4	77.5	72.7	63.2	47.1	32.2	21.9		
		MCWB	15.3	19.6	30.4	39.7	49.8	57.9	61.1	60.1	54.3	42.8	31.1	21.3		
	10%	DB	11.3	15.9	30.1	44.8	60.1	71.6	74.3	69.4	59.4	43.8	29.5	17.7		
		MCWB	10.6	14.9	27.1	37.3	47.0	56.2	59.9	58.5	52.3	40.6	28.4	17.0		
	0.4%	WB	27.7	28.8	37.4	47.3	57.0	63.8	66.6	66.2	60.6	51.2	36.7	29.1		
		MCDB	28.1	29.7	43.9	60.0	71.3	75.8	78.9	76.5	71.8	57.5	38.7	29.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	20.6	23.7	33.8	43.0	53.5	61.2	64.7	63.6	57.5	45.5	33.3	24.5		
		MCDB	21.0	24.8	38.1	52.7	67.2	73.6	75.6	72.8	65.1	49.4	34.3	25.1		
	5%	WB	15.5	19.6	30.6	40.2	50.8	59.4	62.9	61.7	55.3	43.1	31.2	21.3		
		MCDB	16.1	20.7	34.4	48.5	63.3	71.2	72.8	69.8	61.7	46.9	32.2	21.9		
	10%	WB	10.7	14.9	26.8	37.5	48.1	57.7	61.3	59.8	53.3	40.7	28.4	17.0		
		MCDB	11.4	15.9	30.0	44.3	58.6	69.1	70.7	66.9	58.8	43.6	29.4	17.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.8	19.3	23.4	21.4	20.8	20.3	19.2	17.3	15.8	10.9	11.6	14.8		
		MCDBR	16.8	19.6	25.1	25.1	28.4	25.8	25.2	23.5	22.3	16.6	12.7	15.4		
		MCWBR	16.6	18.4	19.8	15.4	14.6	10.8	10.4	11.2	12.7	11.5	11.4	15.0		
		MCDBR	16.8	19.2	23.9	24.0	25.9	21.6	20.5	20.2	20.2	15.6	12.2	15.3		
	5% WB	MCWBR	16.6	18.1	18.9	14.8	13.7	9.9	9.7	10.6	12.0	11.3	11.2	15.0		
(40) Clear-Sky Solar Irradiance	taub		0.211	0.257	0.262	0.317	0.331	0.356	0.385	0.347	0.305	0.276	0.244	0.175		
	taud		2.153	2.204	2.300	2.308	2.453	2.401	2.363	2.462	2.596	2.516	2.103	2.065		
	Ebn at Noon		198	243	282	281	285	278	266	270	267	241	168	169		
	Edh at Noon		13	22	28	34	31	34	35	29	22	17	14	9		
(44) All-Sky Solar Radiation	RadAvg		113	350	849	1393	1721	1941	1743	1350	863	386	126	62		
	RadStd		17	36	65	104	147	133	109	75	77	40	16	5		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page