

CLYDE RIVER, NU, Canada

WMO: 710900

Lat: 70.486N

Lon: 68.517W

Elev: 87

StdP: 14.65

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-39.4	-36.0	-47.1	0.4	-38.9	-44.1	0.4	-35.9	42.9	-5.8	38.7	-6.9	3.4	260	1.083

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	56.7	49.4	52.8	47.1	49.2	44.7	50.0	56.0	47.4	52.2	44.9	48.6	10.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
45.8	45.7	52.4	43.6	42.0	49.3	41.8	39.2	46.6	20.3	56.2	18.9	52.4	17.7	48.9	59.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.0	29.5	25.2	DB	-43.0	63.9	4.7	3.7	-46.4	66.6	-49.1	68.8	-51.8	70.9	-55.2	73.6	(4)
(5)			WB	-43.1	54.0	4.6	2.4	-46.4	55.8	-49.0	57.2	-51.6	58.6	-54.9	60.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-17.0	-19.2	-15.1	-0.4	19.4	34.0	41.2	40.9	33.3	20.7	4.7	-8.8
	DBStd	23.81	10.75	10.89	11.16	9.72	8.17	4.64	5.62	4.33	4.85	6.95	10.23	10.78
	HDD50	14133	2078	1938	2019	1511	950	479	280	285	502	909	1359	1823
	HDD65	19599	2543	2358	2484	1961	1415	929	738	748	952	1374	1809	2288
	CDD50	9	0	0	0	0	0	0	7	2	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.2	11.0	10.7	9.8	9.3	9.3	9.7	9.3	9.5	9.9	11.2	11.9	11.1
Precipitation	PrecAvg	9.4	0.4	0.3	0.3	0.5	0.7	0.6	0.9	1.3	1.3	1.3	0.7	0.5
	PrecMax	15.1	1.3	1.0	1.4	5.6	1.9	2.0	4.1	4.7	3.9	4.4	4.1	2.4
	PrecMin	3.4	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.2	0.3	0.3	0.3	0.9	0.5	0.4	0.8	1.1	0.8	0.9	0.7	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.6	12.8	20.5	27.4	38.1	51.3	63.7	60.7	48.1	36.1	30.2	22.3
		MCWB	17.2	11.9	19.5	25.3	34.9	44.9	52.9	50.4	42.2	33.3	28.8	20.5
	2%	DB	8.6	4.8	11.4	22.8	33.9	46.8	58.9	55.3	44.3	33.9	26.8	15.2
		MCWB	7.9	3.9	10.5	21.4	31.6	42.0	50.8	48.8	40.2	32.4	25.5	14.1
	5%	DB	3.3	0.3	5.7	18.6	31.9	44.0	55.0	51.5	41.7	32.2	23.3	11.1
		MCWB	2.6	-0.5	4.9	17.5	30.5	40.1	48.5	46.2	38.7	31.1	22.1	10.2
	10%	DB	-1.3	-3.2	0.9	14.2	30.0	41.4	51.3	48.0	39.6	30.5	19.4	6.9
		MCWB	-2.0	-4.0	0.0	13.2	28.8	38.4	46.2	44.4	37.3	29.3	18.5	6.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.4	11.7	19.3	25.8	35.1	45.8	53.9	52.0	43.4	34.5	29.0	20.9
		MCDB	17.7	12.6	20.6	26.8	37.5	50.6	61.8	58.7	46.9	35.4	30.0	21.9
	2%	WB	8.0	3.9	10.7	21.3	32.2	42.5	51.2	49.3	40.9	32.8	25.5	14.1
		MCDB	8.5	4.7	11.4	22.6	33.4	46.1	58.1	54.5	43.5	33.5	26.6	14.9
	5%	WB	2.6	-0.5	4.9	17.5	30.5	40.4	48.8	46.7	39.1	31.2	22.1	10.2
		MCDB	3.2	0.1	5.6	18.5	31.6	43.6	54.3	50.9	41.1	32.0	23.2	11.0
	10%	WB	-2.0	-3.9	0.1	13.2	28.8	38.5	46.4	44.6	37.7	29.4	18.5	6.0
		MCDB	-1.4	-3.2	0.9	14.1	29.9	41.2	51.0	47.5	39.3	30.4	19.4	6.7
Mean Daily Temperature Range	5% DB	MDBR	11.4	11.6	13.4	14.8	10.8	8.0	11.6	9.5	7.1	9.4	11.1	11.9
		MCDBR	10.6	13.4	15.8	15.7	10.3	13.2	19.1	16.9	10.5	8.5	13.0	14.7
		MCWBR	10.6	13.1	15.3	14.7	9.2	9.4	12.1	10.9	7.4	7.6	12.6	13.8
	5% WB	MCDBR	10.7	13.2	15.6	15.2	10.0	12.9	18.5	15.4	9.5	7.6	12.7	14.3
		MCWBR	10.7	13.0	15.2	14.4	9.0	9.5	12.2	10.3	7.1	7.2	12.3	13.7
Clear-Sky Solar Irradiance	taub	N/A	0.180	0.242	0.296	0.323	0.320	0.332	0.324	0.286	0.210	N/A	N/A	
	taud	N/A	2.017	2.140	2.026	2.052	2.225	2.382	2.465	2.435	2.104	N/A	N/A	
	Ebn at Noon	0	180	244	260	267	274	267	256	233	156	0	0	
	Edh at Noon	0	11	23	37	41	36	30	24	18	10	0	0	
All-Sky Solar Radiation	RadAvg	0	114	622	1446	2118	2250	1735	1083	577	178	0	0	
	RadStd	0	8	25	40	69	122	125	52	36	10	0	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.31	+2.66	+2.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page