

CLYDE RIVER, NU, Canada

WMO: 710900

Lat: 70.486N

Lon: 68.517W

Elev: 27

StdP: 101.01

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-39.7	-37.8	-44.0	0.1	-39.4	-42.3	0.1	-37.7	19.2	-21.0	17.3	-21.6	1.5	260	1.083

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	13.7	9.7	11.6	8.4	9.5	7.1	10.0	13.3	8.6	11.2	7.2	9.2	4.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.7	6.5	11.3	6.5	6.0	9.6	5.5	5.6	8.1	29.4	13.4	26.2	11.3	23.2	9.4	15.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.7	13.2	11.3	DB	-41.7	17.7	2.6	2.1	-43.5	19.2	-45.1	20.5	-46.5	21.6	-48.4	23.1	(4)
(5)			WB	-41.7	12.2	2.5	1.4	-43.5	13.2	-45.0	14.0	-46.4	14.8	-48.3	15.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	-11.5	-27.2	-28.5	-26.2	-18.0	-7.0	1.1	5.1	4.9	0.7	-6.3	-15.2	-22.7	
	DBStd	13.23	5.97	6.05	6.20	5.40	4.54	2.58	3.12	2.40	2.69	3.86	5.69	5.99	
	HDD10.0	7852	1154	1077	1122	839	528	266	156	158	279	505	755	1013	
	HDD18.3	10888	1413	1310	1380	1089	786	516	410	416	529	763	1005	1271	
	CDD10.0	5	0	0	0	0	0	0	4	1	0	0	0	0	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	4.6	4.9	4.8	4.4	4.2	4.2	4.3	4.1	4.3	4.4	5.0	5.3	5.0	
Precipitation	PrecAvg	239	10	8	8	13	17	16	23	32	33	33	19	13	
	PrecMax	383	33	25	36	141	49	50	105	119	100	113	104	62	
	PrecMin	86	0	0	0	0	2	0	1	1	1	1	1	0	
	PrecStd	81	8	8	8	22	13	11	21	28	21	22	18	12	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.0	-10.7	-6.4	-2.6	3.4	10.7	17.6	15.9	8.9	2.3	-1.0	-5.4	
		MCWB	-8.2	-11.1	-6.9	-3.7	1.6	7.2	11.6	10.2	5.7	0.7	-1.8	-6.4	
	2%	DB	-13.0	-15.1	-11.5	-5.1	1.0	8.2	14.9	12.9	6.8	1.0	-2.9	-9.3	
		MCWB	-13.4	-15.6	-11.9	-5.9	-0.2	5.6	10.4	9.3	4.6	0.2	-3.6	-10.0	
	5%	DB	-15.9	-17.6	-14.6	-7.5	-0.1	6.6	12.8	10.8	5.4	0.1	-4.8	-11.6	
		MCWB	-16.3	-18.1	-15.1	-8.1	-0.8	4.5	9.2	7.9	3.7	-0.5	-5.5	-12.1	
	10%	DB	-18.5	-19.6	-17.3	-9.9	-1.1	5.2	10.7	8.9	4.2	-0.8	-7.0	-14.0	
		MCWB	-18.9	-20.0	-17.8	-10.5	-1.8	3.5	7.9	6.9	3.0	-1.5	-7.5	-14.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.1	-11.3	-7.1	-3.4	1.7	7.7	12.2	11.1	6.4	1.4	-1.7	-6.2
			MCDB	-8.0	-10.8	-6.3	-2.9	3.0	10.3	16.6	14.9	8.3	1.9	-1.1	-5.6
2%		WB	-13.4	-15.6	-11.8	-5.9	0.1	5.8	10.6	9.6	4.9	0.5	-3.6	-9.9	
		MCDB	-13.0	-15.2	-11.5	-5.2	0.8	7.8	14.5	12.5	6.4	0.8	-3.0	-9.5	
5%		WB	-16.3	-18.1	-15.1	-8.1	-0.8	4.7	9.3	8.2	4.0	-0.5	-5.5	-12.1	
		MCDB	-16.0	-17.7	-14.6	-7.5	-0.2	6.5	12.4	10.5	5.1	0.0	-4.9	-11.6	
10%		WB	-18.9	-20.0	-17.7	-10.4	-1.8	3.6	8.0	7.0	3.2	-1.5	-7.5	-14.4	
		MCDB	-18.5	-19.6	-17.3	-9.9	-1.2	5.1	10.6	8.6	4.0	-0.9	-7.0	-14.1	
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.4	7.4	8.2	6.0	4.5	6.4	5.3	4.0	5.2	6.2	6.6	
		MCDBR	5.9	7.4	8.8	8.7	5.7	7.3	10.6	9.4	5.8	4.7	7.2	8.2	
		MCWBR	5.9	7.3	8.5	8.2	5.1	5.2	6.7	6.0	4.1	4.2	7.0	7.7	
	5% WB	MCDBR	6.0	7.4	8.7	8.5	5.5	7.1	10.3	8.5	5.3	4.2	7.0	7.9	
		MCWBR	6.0	7.2	8.4	8.0	5.0	5.3	6.8	5.7	3.9	4.0	6.9	7.6	
Clear-Sky Solar Irradiance	taub	N/A	0.180	0.242	0.296	0.323	0.320	0.332	0.324	0.286	0.210	N/A	N/A		
	taud	N/A	2.017	2.140	2.026	2.052	2.225	2.382	2.465	2.435	2.104	N/A	N/A		
	Ebn at Noon	0	569	769	820	843	865	843	807	733	493	0	0		
	Edh at Noon	0	36	73	116	130	113	94	77	57	32	0	0		
All-Sky Solar Radiation	RadAvg	0.00	0.36	1.96	4.56	6.68	7.09	5.47	3.42	1.82	0.56	0.00	0.00		
	RadStd	0.00	0.03	0.08	0.12	0.22	0.39	0.40	0.16	0.11	0.03	0.00	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.73	+1.48	+1.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page