

CAPE HOOPER, NU, Canada

WMO: 710930

Lat: 68.472N

Lon: 66.798W

Elev: 390

StdP: 96.73

Time Zone: -5.00 (NAE)

Period: 82-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-35.4	-33.8	-38.9	0.1	-35.3	-38.0	0.1	-34.5	23.4	-25.5	21.5	-26.9	7.6	260	1.157

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.9	14.0	9.6	12.1	7.7	10.4	6.9	9.2	13.0	7.8	11.1	6.5	9.4	4.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.4	6.2	10.2	5.2	5.7	9.1	4.1	5.3	8.1	28.4	13.1	25.2	11.2	22.4	9.4	17.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	19.1	16.4	DB	-36.0	16.0	2.8	1.9	-38.0	17.4	-39.6	18.5	-41.1	19.6	-43.1	21.0	(4)
(5)			WB	-36.6	11.4	0.9	2.9	-37.2	13.5	-37.7	15.1	-38.2	16.8	-38.9	18.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-11.0	-25.0	-26.3	-23.7	-16.8	-8.0	0.5	5.3	3.8	-1.0	-6.6	-14.0	-20.8
	DBStd	11.98	5.01	5.01	5.76	5.32	4.40	3.67	4.32	3.56	2.85	3.60	5.18	5.42
	HDD10.0	7662	1084	1016	1044	805	557	284	158	195	331	514	721	955
	HDD18.3	10690	1342	1249	1302	1055	816	534	406	450	581	772	971	1213
	CDD10.0	13	0	0	0	0	0	0	11	3	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.4	7.0	6.6	6.5	6.1	5.8	4.9	4.7	5.3	6.9	8.0	7.9	7.3
Precipitation	PrecAvg	265	7	9	7	16	24	20	29	35	38	36	29	11
	PrecMax	500	24	53	24	61	82	78	84	93	106	79	91	33
	PrecMin	115	0	0	0	0	0	0	4	2	6	12	3	1
	PrecStd	86	7	14	7	13	19	17	21	23	22	16	20	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-7.5	-9.1	-5.2	-1.8	5.2	11.7	17.1	15.1	8.3	3.8	-1.9	-2.7
		MCWB	-8.3	-9.1	-5.5	-2.6	3.5	7.1	12.4	8.9	6.0	3.8	-2.2	-4.1
	2%	DB	-12.9	-14.5	-9.9	-4.6	2.3	9.7	15.1	12.5	6.3	0.4	-3.8	-7.9
		MCWB	-13.2	-15.0	-10.5	-5.1	1.5	6.0	10.2	8.4	4.6	0.2	-4.1	-8.3
	5%	DB	-15.8	-17.3	-13.2	-7.0	-0.4	8.1	13.5	10.9	4.8	-1.3	-5.2	-10.9
		MCWB	-16.2	-17.7	-13.6	-7.4	-1.0	4.6	9.1	7.5	3.2	-1.7	-5.6	-11.4
	10%	DB	-18.1	-19.5	-15.7	-9.4	-2.3	6.2	11.8	9.4	3.2	-2.3	-7.0	-13.6
		MCWB	-18.4	-19.9	-16.1	-9.9	-2.6	3.8	7.5	6.6	1.7	-2.6	-7.3	-14.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-12.0	-5.3	-9.0	-3.7	3.2	7.9	13.4	9.2	6.8	4.4	-3.9	-7.3
		MCDB	-11.6	-4.9	-8.5	-3.4	3.9	10.0	14.8	11.1	8.4	5.4	-3.7	-6.7
	2%	WB	-15.5	-15.7	-11.7	-6.4	1.5	6.3	10.3	7.6	4.9	-0.9	-5.5	-10.9
		MCDB	-15.2	-15.3	-11.0	-6.0	2.5	9.0	14.8	10.5	6.4	-0.8	-5.3	-10.5
	5%	WB	-18.2	-18.6	-15.3	-8.6	-0.6	5.3	8.9	6.4	3.4	-2.4	-7.2	-14.0
		MCDB	-17.9	-18.3	-15.0	-8.2	0.0	8.1	12.9	8.5	4.7	-2.2	-6.9	-13.7
	10%	WB	-20.5	-20.7	-19.0	-10.8	-2.7	4.2	7.7	5.4	1.6	-3.7	-9.2	-16.2
		MCDB	-20.2	-20.3	-18.8	-10.3	-2.4	6.4	11.2	7.4	2.6	-3.5	-8.9	-15.8
Mean Daily Temperature Range	5% DB	MDBR	3.6	3.7	4.2	4.0	3.5	3.8	4.9	4.0	2.5	2.7	3.6	3.8
		MCDBR	5.7	6.3	6.8	6.4	5.3	6.2	6.1	5.7	4.8	3.7	4.8	6.4
		MCWBR	6.4	6.8	7.0	6.1	4.6	4.1	4.6	4.1	3.5	3.7	4.9	7.2
	5% WB	MCDBR	5.9	6.1	6.8	5.8	5.2	5.1	5.6	4.7	4.3	3.5	4.9	5.6
		MCWBR	5.7	6.0	6.7	5.7	4.8	4.2	4.7	4.1	3.6	3.4	4.9	5.5
Clear-Sky Solar Irradiance	taub	0.145	0.188	0.234	0.281	0.305	0.313	0.321	0.316	0.283	0.226	N/A	N/A	
	taud	1.866	2.079	2.175	2.070	2.096	2.207	2.362	2.478	2.475	2.210	N/A	N/A	
	Ebn at Noon	120	650	819	859	877	882	865	832	770	572	N/A	0	
	Edh at Noon	7	43	76	115	127	118	98	79	59	37	N/A	0	
All-Sky Solar Radiation	RadAvg	0.03	0.52	2.19	4.62	6.52	6.57	5.41	3.60	2.02	0.70	0.08	0.00	
	RadStd	0.00	0.02	0.09	0.16	0.24	0.50	0.36	0.18	0.13	0.04	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		+0.83	+1.43	N/A	N/A	N/A	N/A	-294	-294	N/A	N/A		
(47) Regional (3 neighbors)		+0.71	+1.40	N/A	N/A	N/A	N/A	-255	-262	N/A	N/A		

Nomenclature: See separate page