

CAPE DYER, NU, Canada

WMO: 710940

Lat: 66.665N

Lon: 61.358W

Elev: 2379

StdP: 13.48

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-28.3	-24.8	N/A	N/A	N/A	N/A	N/A	N/A	55.0	1.7	49.0	-1.8	8.8	0	1.138

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	54.2	N/A	51.1	N/A	48.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.7	39.0	33.1	DB	-30.9	58.5	2.8	4.2	-32.9	61.5	-34.6	63.9	-36.1	66.3	-38.1	69.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	-8.0	-8.3	-4.8	5.6	20.0	32.0	40.7	38.3	28.0	19.0	9.5	-0.6	
	DBStd	19.04	9.55	10.96	11.35	10.11	8.25	6.62	6.28	6.03	5.04	5.59	7.63	9.74	
	HDD50	12996	1798	1632	1698	1333	930	542	296	364	660	960	1216	1567	
	HDD65	18460	2263	2052	2163	1783	1395	991	753	827	1110	1425	1666	2032	
	CDD50	11	0	0	0	0	0	1	8	2	0	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	13.3	14.5	13.9	13.6	13.4	11.8	12.4	11.0	11.8	13.8	13.8	15.5	14.2	
Precipitation	PrecAvg	22.6	1.8	1.2	1.0	1.1	1.4	1.4	1.6	2.5	3.0	3.0	2.3	2.3	
	PrecMax	31.1	4.1	3.1	2.4	1.9	2.2	2.7	3.9	3.7	8.1	5.0	6.2	5.5	
	PrecMin	13.6	0.7	0.4	0.1	0.4	0.7	0.6	0.2	1.1	1.2	1.7	1.1	0.8	
	PrecStd	4.2	1.0	0.6	0.6	0.4	0.4	0.5	0.7	0.6	1.5	0.8	1.0	1.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.9	25.0	27.6	34.7	46.3	53.8	60.0	55.7	44.9	37.1	30.9	27.2	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	17.9	19.7	22.8	28.6	39.1	48.4	55.8	52.5	40.9	31.5	25.0	23.4	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	12.0	12.4	16.2	23.5	34.7	44.7	52.9	49.5	37.7	29.6	22.3	17.6	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	6.7	6.5	10.8	19.3	31.0	41.2	49.9	47.2	34.8	27.2	19.8	12.3	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	8.9	9.1	8.9	8.5	7.5	7.1	7.7	7.3	5.2	5.2	6.0	7.8	
		MCDBR	13.0	12.5	12.8	11.3	10.5	10.9	9.9	9.8	9.8	8.1	8.4	10.9	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.137	0.186	0.221	0.264	0.287	0.293	0.302	0.303	0.265	0.222	N/A	N/A		
	taud	1.873	2.148	2.204	2.115	2.123	2.248	2.424	2.485	2.490	2.300	N/A	N/A		
	Ebn at Noon	97	231	276	285	288	290	285	273	260	210	N/A	0		
	Edh at Noon	4	15	25	36	40	36	30	25	19	13	N/A	0		
All-Sky Solar Radiation	RadAvg	24	227	783	1507	2023	2110	1692	1124	650	251	40	0		
	RadStd	2	12	34	83	69	194	160	93	66	23	4	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	+1.10	+2.21	N/A	N/A	N/A	N/A	-414	-428	N/A	N/A

Nomenclature: See separate page