

CAPE DYER AP, NU, Canada

WMO: 710945

Lat: 66.596N

Lon: 61.581W

Elev: 1288

StdP: 14.02

Time Zone: -5.00 (NAE)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-39.3	-36.1	-46.6	0.4	-38.5	-43.9	0.5	-35.2	42.3	-0.1	36.9	-0.4	1.3	180	1.040

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	55.9	47.0	52.8	45.0	50.2	43.5	47.6	54.4	45.9	51.9	44.0	49.4	7.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
42.7	42.4	50.2	40.9	39.5	48.4	39.4	37.3	46.3	19.4	54.7	18.5	51.9	17.5	49.6	55.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.0	28.7	23.6	-43.9	61.5	4.9	2.7	-47.4	63.4	-50.2	65.0	-53.0	66.5	-56.5	68.4		
(5)			-43.2	51.5	5.2	1.9	-46.9	52.8	-50.0	53.9	-52.9	54.9	-56.7	56.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	-14.4	-15.9	-10.8	2.0	18.4	33.8	42.8	39.6	30.3	17.8	5.3	-7.4		
	DBStd	22.79	13.16	14.20	10.73	11.09	8.20	6.28	5.50	4.93	5.98	7.21	10.57	12.87		
	HDD50	13902	1997	1845	1885	1440	981	487	232	324	592	997	1342	1780		
	HDD65	19366	2462	2265	2350	1890	1446	937	687	788	1042	1462	1792	2245		
	CDD50	12	0	0	0	0	0	0	10	2	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	7.4	7.4	7.3	7.3	6.3	8.0	6.0	6.1	6.9	7.7	8.3	9.0	8.1		
	PrecAvg	27.6	2.5	1.9	1.2	1.7	2.3	1.6	1.7	2.2	2.9	3.9	3.0	2.4		
(15) Precipitation	PrecMax	40.9	6.9	7.6	3.9	5.0	7.8	3.9	5.4	6.7	6.0	9.4	8.2	7.0		
	PrecMin	17.3	0.1	0.0	0.3	0.1	0.1	0.2	0.1	0.2	0.6	0.4	0.6	0.0		
	PrecStd	6.5	2.2	2.4	0.9	1.4	1.7	1.1	1.2	1.5	1.5	2.6	1.9	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	28.6	23.1	30.5	40.4	51.9	61.8	58.9	49.4	36.0	32.3	28.1		
		MCWB	21.8	27.4	21.2	26.8	34.4	43.1	50.4	49.2	44.6	34.6	31.4	25.2		
	2%	DB	15.3	21.8	15.3	26.8	36.6	49.2	57.6	53.6	43.5	32.4	26.5	23.4		
		MCWB	13.1	20.9	13.0	24.2	33.2	41.9	47.9	46.2	38.5	31.0	25.5	21.2		
	5%	DB	9.9	11.5	10.0	23.6	33.3	46.2	55.1	50.7	40.3	30.0	23.6	16.0		
		MCWB	8.4	9.5	8.5	21.7	31.1	40.2	46.3	44.6	36.9	28.9	22.7	14.2		
	10%	DB	5.0	5.1	4.7	19.2	30.6	43.6	52.2	47.9	37.9	28.0	20.4	9.9		
		MCWB	3.7	3.8	3.4	17.3	29.0	38.4	44.5	42.9	35.3	26.9	19.0	8.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	27.8	20.8	28.1	36.6	44.9	51.2	49.4	44.8	35.2	31.9	26.6		
		MCDB	24.8	28.8	22.5	29.7	38.3	49.6	60.4	57.1	48.9	35.8	32.3	27.3		
	2%	WB	13.3	20.8	13.6	24.8	33.6	42.3	48.5	47.0	39.9	31.4	25.8	21.0		
		MCDB	14.9	21.7	15.0	26.8	35.9	48.3	56.4	52.7	42.2	32.1	26.4	23.7		
	5%	WB	8.5	10.3	8.5	21.5	31.4	40.5	46.8	45.3	37.5	29.1	22.7	14.0		
		MCDB	10.1	11.4	9.8	23.9	33.1	45.6	53.8	50.2	39.2	29.9	23.3	15.9		
	10%	WB	3.8	3.9	3.5	17.1	29.1	38.7	45.1	43.1	35.6	27.0	19.0	8.5		
		MCDB	5.0	5.3	4.8	19.1	30.7	43.1	51.6	47.3	37.8	27.9	20.1	9.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	13.6	13.9	13.6	9.6	8.7	10.3	9.3	7.8	11.0	12.9	14.0		
		MCDBR	15.3	15.7	15.8	13.6	10.9	11.5	13.4	13.3	10.0	10.1	11.9	13.3		
		MCWBR	14.7	14.9	15.0	12.3	8.6	8.2	8.0	8.5	7.4	9.3	11.3	13.1		
		MCDBR	15.4	16.9	15.9	13.2	10.1	11.1	13.3	12.7	9.1	9.1	11.6	13.7		
	5% WB	MCWBR	14.9	16.4	15.1	12.1	8.1	8.1	8.6	8.8	7.2	8.7	11.2	13.3		
(40) Clear-Sky Solar Irradiance	taub		0.148	0.197	0.235	0.282	0.305	0.310	0.320	0.319	0.275	0.231	0.158	N/A		
	taud		1.862	2.123	2.177	2.073	2.083	2.205	2.359	2.412	2.430	2.240	1.925	N/A		
	Ebn at Noon		89	223	268	277	281	283	277	266	253	201	78	0		
	Edh at Noon		5	16	26	38	42	38	32	27	21	14	4	0		
(44) All-Sky Solar Radiation	RadAvg		24	230	787	1516	2034	2118	1707	1139	664	259	43	0		
	RadStd		2	12	33	80	69	188	157	92	65	23	4	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.85	+2.63	+3.20	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page