

CAPE DYER AP, NU, Canada

WMO: 710945

Lat: 66.596N

Lon: 61.581W

Elev: 393

StdP: 96.70

Time Zone: -5.00 (NAE)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-39.6	-37.8	-43.7	0.1	-39.2	-42.2	0.1	-37.3	18.9	-17.8	16.5	-18.0	0.6	180	1.040

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.7	13.3	8.3	11.5	7.2	10.1	6.4	8.7	12.5	7.7	11.0	6.6	9.7	3.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.9	6.1	10.1	5.0	5.6	9.1	4.1	5.3	7.9	27.3	12.6	25.1	11.1	22.7	9.8	12.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.6	12.8	10.5	DB	-42.2	16.4	2.7	1.5	-44.1	17.4	-45.7	18.3	-47.2	19.1	-49.2	20.2	(4)
(5)			WB	-41.8	10.8	2.9	1.0	-43.8	11.6	-45.5	12.2	-47.2	12.7	-49.3	13.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-11.1	-25.8	-26.6	-23.8	-16.7	-7.6	1.0	6.0	4.2	-1.0	-7.9	-14.9	-21.9	(6)
(7)		DBStd	12.66	7.31	7.89	5.96	6.16	4.55	3.49	3.06	2.74	3.32	4.00	5.87	7.15	(7)
(8)		HDD10.0	7723	1109	1025	1047	800	545	271	129	180	329	554	746	989	(8)
(9)		HDD18.3	10759	1368	1258	1306	1050	803	521	382	438	579	812	996	1247	(9)
(10)		CDD10.0	7	0	0	0	0	0	0	6	1	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.3	3.3	3.3	3.3	2.8	3.6	2.7	2.7	3.1	3.5	3.7	4.0	3.6	(14)
(15)	Precipitation	PrecAvg	700	64	49	31	44	59	41	44	55	74	100	75	60	(15)
(16)		PrecMax	1038	174	194	99	127	198	100	136	170	153	238	209	178	(16)
(17)		PrecMin	439	2	0	7	3	2	6	2	4	14	9	15	0	(17)
(18)		PrecStd	164	57	60	24	35	42	28	30	37	39	66	47	50	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.9	-1.9	-4.9	-0.8	4.7	11.1	16.5	14.9	9.7	2.2	0.1	-2.2	(19)
(20)			MCWB	-5.7	-2.5	-6.0	-2.9	1.3	6.2	10.2	9.5	7.0	1.5	-0.3	-3.8	(20)
(21)		2%	DB	-9.3	-5.7	-9.3	-2.9	2.5	9.6	14.2	12.0	6.4	0.2	-3.0	-4.8	(21)
(22)			MCWB	-10.5	-6.2	-10.6	-4.3	0.7	5.5	8.8	7.9	3.6	-0.6	-3.6	-6.0	(22)
(23)		5%	DB	-12.3	-11.4	-12.2	-4.7	0.7	7.9	12.8	10.4	4.6	-1.1	-4.7	-8.9	(23)
(24)			MCWB	-13.1	-12.5	-13.0	-5.7	-0.5	4.6	8.0	7.0	2.7	-1.7	-5.2	-9.9	(24)
(25)		10%	DB	-15.0	-14.9	-15.2	-7.1	-0.8	6.5	11.2	8.9	3.3	-2.2	-6.5	-12.3	(25)
(26)			MCWB	-15.7	-15.6	-15.9	-8.1	-1.6	3.6	6.9	6.0	1.8	-2.8	-7.2	-13.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.7	-2.3	-6.2	-2.2	2.6	7.2	10.7	9.6	7.1	1.8	-0.1	-3.0	(27)
(28)			MCDWB	-4.0	-1.8	-5.3	-1.3	3.5	9.8	15.8	13.9	9.4	2.1	0.2	-2.6	(28)
(29)		2%	WB	-10.4	-6.2	-10.2	-4.0	0.9	5.7	9.1	8.3	4.4	-0.3	-3.5	-6.1	(29)
(30)			MCDWB	-9.5	-5.7	-9.4	-2.9	2.2	9.1	13.5	11.5	5.7	0.1	-3.1	-4.6	(30)
(31)		5%	WB	-13.0	-12.1	-13.1	-5.8	-0.4	4.7	8.2	7.4	3.1	-1.6	-5.2	-10.0	(31)
(32)			MCDWB	-12.2	-11.4	-12.3	-4.5	0.6	7.6	12.1	10.1	4.0	-1.2	-4.8	-8.9	(32)
(33)		10%	WB	-15.7	-15.6	-15.8	-8.3	-1.6	3.7	7.3	6.2	2.0	-2.8	-7.2	-13.0	(33)
(34)			MCDWB	-15.0	-14.8	-15.1	-7.1	-0.7	6.2	10.9	8.5	3.2	-2.3	-6.6	-12.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.9	7.6	7.7	7.6	5.3	4.8	5.7	5.1	4.3	6.1	7.2	7.8	(35)
(36)			MCDBR	8.5	8.7	8.8	7.5	6.0	6.4	7.5	7.4	5.6	5.6	6.6	7.4	(36)
(37)			MCWBR	8.2	8.3	8.3	6.8	4.8	4.5	4.4	4.7	4.1	5.2	6.3	7.3	(37)
(38)		5% WB	MCDBR	8.6	9.4	8.8	7.3	5.6	6.2	7.4	7.0	5.1	5.0	6.4	7.6	(38)
(39)			MCWBR	8.3	9.1	8.4	6.7	4.5	4.5	4.8	4.9	4.0	4.8	6.2	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.148	0.197	0.235	0.282	0.305	0.310	0.320	0.319	0.275	0.231	0.158	N/A	(40)	
(41)		taud	1.862	2.123	2.177	2.073	2.083	2.205	2.359	2.412	2.430	2.240	1.925	N/A	(41)	
(42)		Ebn at Noon	279	702	845	874	887	893	874	837	799	633	246	0	(42)	
(43)		Edh at Noon	15	49	81	119	132	121	101	86	65	43	13	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.08	0.72	2.48	4.78	6.41	6.68	5.38	3.59	2.09	0.82	0.13	0.00	(44)	
(45)		RadStd	0.01	0.04	0.10	0.25	0.22	0.59	0.49	0.29	0.20	0.07	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.47	+1.46	+1.78	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page