

POND INLET, NU, Canada

WMO: 710950

Lat: 72.693N

Lon: 77.957W

Elev: 202

StdP: 14.59

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-43.5	-41.0	-49.2	0.3	-42.2	-48.2	0.3	-40.9	27.2	-9.3	18.8	-6.0	4.6	180	1.025

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	57.1	49.3	53.8	47.4	51.1	45.7	50.3	55.4	48.1	52.9	46.1	50.5	6.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
47.1	48.3	51.8	44.7	44.0	50.1	42.6	40.5	48.2	20.6	55.7	19.3	53.0	18.3	50.6	60.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.8	20.4	16.6	-46.0	62.4	3.1	4.0	-48.2	65.3	-50.1	67.7	-51.8	70.0	-54.1	72.9		
(5)			-46.0	53.5	2.8	2.7	-48.0	55.4	-49.7	56.9	-51.2	58.4	-53.3	60.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-25.0	-27.0	-20.7	-4.9	18.0	37.3	44.7	42.2	30.5	16.6	-3.2	-16.8	(6)
(7)		DBStd	27.54	10.74	9.95	11.30	10.35	9.76	5.31	4.62	5.08	6.01	8.48	12.51	12.14	(7)
(8)		HDD50	15399	2324	2156	2191	1646	993	382	176	247	585	1034	1595	2070	(8)
(9)		HDD65	20857	2789	2576	2656	2096	1458	831	630	707	1035	1499	2045	2535	(9)
(10)		CDD50	18	0	0	0	0	0	1	11	6	0	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.0	4.4	4.4	4.9	5.0	5.6	6.5	6.1	6.3	7.7	9.1	6.7	5.0	(14)
(15)	Precipitation	PrecAvg	7.6	0.2	0.1	0.2	0.5	0.4	0.6	1.2	1.5	0.7	0.9	0.4	0.3	(15)
(16)		PrecMax	15.1	0.6	0.6	1.1	2.1	1.5	3.0	3.0	3.7	1.7	2.6	1.5	1.2	(16)
(17)		PrecMin	4.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	2.6	0.2	0.1	0.3	0.5	0.4	0.7	0.8	1.0	0.4	0.6	0.4	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	9.1	20.6	26.4	37.8	55.4	63.3	59.4	45.2	36.5	28.6	19.5	(19)
(20)			MCWB	10.5	7.8	18.9	25.3	34.2	46.1	53.7	51.5	40.3	33.2	26.1	18.0	(20)
(21)		2%	DB	4.0	-1.0	7.8	19.2	34.8	50.6	59.0	55.2	42.3	32.6	24.8	13.4	(21)
(22)			MCWB	3.0	-1.8	7.0	17.9	31.8	43.8	50.3	49.0	38.7	30.5	22.6	12.4	(22)
(23)		5%	DB	-2.4	-6.3	0.2	15.0	32.7	47.3	55.8	52.4	40.4	30.4	20.1	7.8	(23)
(24)			MCWB	-3.2	-6.9	-0.6	13.9	30.3	41.7	48.5	47.1	37.4	28.6	18.5	7.0	(24)
(25)		10%	DB	-9.2	-12.0	-4.7	10.7	30.6	44.6	52.8	49.7	38.6	28.2	14.7	2.7	(25)
(26)			MCWB	-9.8	-12.5	-5.4	9.7	28.5	40.0	46.8	45.3	36.0	26.5	13.5	1.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	7.8	19.1	25.4	34.8	46.8	54.8	52.9	41.3	33.7	26.4	18.2	(27)
(28)			MCD B	12.3	9.0	21.1	26.3	37.4	53.4	60.8	57.8	43.8	35.5	28.3	19.3	(28)
(29)		2%	WB	3.0	-1.6	7.1	18.0	32.2	44.2	51.1	50.0	39.4	30.8	22.6	12.3	(29)
(30)			MCD B	3.9	-0.9	7.8	19.2	34.3	49.5	57.1	53.8	41.9	32.3	24.6	13.3	(30)
(31)		5%	WB	-3.2	-6.9	-0.6	14.0	30.5	42.2	49.2	47.7	37.8	28.8	18.5	7.0	(31)
(32)			MCD B	-2.4	-6.3	0.1	15.1	32.5	46.7	54.6	51.6	40.0	30.4	20.1	7.7	(32)
(33)		10%	WB	-9.8	-12.5	-5.3	9.7	28.5	40.3	47.2	45.7	36.1	26.6	13.4	1.9	(33)
(34)			MCD B	-9.2	-12.0	-4.6	10.7	30.6	44.3	52.2	49.3	38.2	27.9	14.5	2.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.6	9.9	11.3	12.4	10.6	8.5	11.6	9.2	7.8	8.8	11.0	10.7	(35)
(36)			MCDBR	15.9	15.3	16.4	14.5	9.7	12.5	15.9	12.5	9.0	9.2	16.2	15.7	(36)
(37)			MCWBR	15.2	14.9	16.0	13.7	7.9	8.1	9.5	8.1	6.8	8.3	14.8	15.2	(37)
(38)		5% WB	MCDBR	15.8	15.5	16.5	14.4	9.5	12.0	14.7	11.4	8.3	8.9	16.2	15.6	(38)
(39)			MCWBR	15.1	15.1	16.1	13.6	7.9	8.2	9.8	8.0	6.5	8.1	14.7	15.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.168	0.244	0.302	0.315	0.313	0.330	0.310	0.269	0.181	N/A	N/A	(40)	
(41)		taud	N/A	1.916	2.109	2.009	2.095	2.266	2.343	2.403	2.330	1.931	N/A	N/A	(41)	
(42)		Ebn at Noon	0	143	228	250	266	274	263	254	224	122	0	0	(42)	
(43)		Edh at Noon	0	9	22	36	38	34	30	24	18	8	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0	65	519	1366	2077	2154	1665	1084	506	123	0	0	(44)	
(45)		RadStd	0	5	26	42	69	184	100	92	39	11	0	0	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page