

BREVOORT ISLAND, NU, CanadaWMO: **710970**Lat: **63.340N**Lon: **64.157W**Elev: **1234**StdP: **14.05**Time Zone: **-5.00 (NAE)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-24.1	-21.2	N/A	N/A	N/A	N/A	N/A	N/A	58.4	-4.1	54.3	-1.7	11.0	270	1.121

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	58.6	N/A	55.0	N/A	51.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 48.7	42.1	36.2	DB	-25.9	62.7	4.2	4.1	-28.9	65.6	-31.4	68.0	-33.8	70.3	-36.8	73.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	-5.6	-7.4	-1.3	10.3	23.9	33.9	41.8	41.5	33.3	24.7	16.0	5.1
	DBStd	18.72	9.70	9.73	10.26	8.97	6.05	5.54	7.26	5.48	4.39	5.18	7.47	10.43
	HDD50	11650	1724	1608	1589	1191	810	482	277	273	501	785	1019	1391
	HDD65	17093	2189	2028	2054	1641	1274	932	720	729	951	1250	1469	1856
	CDD50	30	0	0	0	0	0	0	21	9	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.5	14.8	14.6	15.1	15.7	12.9	13.0	11.9	12.5	14.3	16.0	17.0	16.3
Precipitation	PrecAvg	23.7	1.4	0.9	0.9	1.1	1.3	1.7	2.3	3.1	3.2	3.2	2.5	2.1
	PrecMax	31.7	3.3	3.6	2.4	2.3	2.6	3.4	5.2	4.8	5.2	5.1	6.4	4.7
	PrecMin	13.1	0.4	0.3	0.2	0.2	0.4	0.8	0.8	1.3	0.8	1.8	0.9	0.6
	PrecStd	4.6	0.8	0.7	0.6	0.5	0.5	0.6	0.9	0.9	1.0	0.7	1.2	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.7	26.5	29.2	31.1	48.2	53.8	65.3	61.3	48.4	37.5	32.0	30.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	18.9	18.8	23.6	28.6	37.0	49.1	60.8	56.9	44.1	35.1	30.1	28.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	13.1	9.9	17.9	25.7	32.7	45.2	57.3	53.6	41.1	33.1	27.9	23.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	8.3	5.1	13.0	22.7	31.1	42.2	53.7	50.2	39.2	31.7	25.7	19.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.0	8.5	8.3	6.5	6.6	8.5	7.6	5.2	5.2	6.6	7.4
		MCDBR	11.9	12.7	12.9	9.6	8.3	11.3	11.6	11.9	8.7	6.3	7.5	8.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.163	0.208	0.245	0.295	0.314	0.318	0.326	0.327	0.291	0.254	0.177	0.152	
	taud	1.949	2.184	2.167	2.045	2.049	2.207	2.385	2.436	2.479	2.381	2.045	1.895	
	Ebn at Noon	161	246	275	279	283	285	280	270	259	223	151	87	
	Edh at Noon	10	18	29	41	45	39	32	28	22	16	8	4	
All-Sky Solar Radiation	RadAvg	71	344	912	1617	2079	2018	1698	1231	749	329	91	29	
	RadStd	5	20	40	57	94	143	160	120	62	30	7	2	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	+3.94	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page