

TRIPLE ISLAND, BC, Canada

WMO: 711000

Lat: 54.295N

Lon: 130.881W

Elev: 21

StdP: 101.08

Time Zone: -8.00 (NAP)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.2	-3.5	-12.0	1.3	-4.1	-9.2	1.7	-2.4	22.2	7.5	20.9	7.0	10.1	50	0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.8	16.0	14.3	15.2	13.9	14.7	13.5	14.7	15.5	14.2	15.0	13.8	14.5	5.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	10.2	15.0	13.8	9.8	14.6	13.3	9.6	14.2	41.2	15.6	39.8	15.1	38.7	14.6	17.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.6	16.2	13.9	DB	-5.9	17.6	2.6	1.5	-7.8	18.7	-9.4	19.6	-10.9	20.5	-12.8	21.6	
			WB	-7.5	15.3	2.7	0.8	-9.5	15.9	-11.1	16.4	-12.6	16.9	-14.6	17.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	4.1	4.8	5.4	7.2	9.1	11.2	12.9	13.4	12.1	9.4	6.7	4.8
	DBStd	3.87	3.46	2.72	2.01	1.49	1.61	1.19	1.05	1.00	1.29	1.68	2.65	3.35
	HDD10.0	888	183	146	142	84	37	3	0	0	2	31	101	161
	HDD18.3	3611	441	379	400	333	285	214	169	154	187	278	351	419
	CDD10.0	319	0	0	0	1	10	39	89	104	65	11	1	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.7	8.6	8.2	7.2	6.2	5.8	4.7	4.8	4.7	5.3	7.2	8.5	9.0
Precipitation	PrecAvg	2364	243	180	190	158	101	98	104	155	216	309	291	270
	PrecMax	3048	509	312	401	310	282	172	189	297	471	466	527	575
	PrecMin	1641	90	96	64	87	9	31	50	64	93	108	143	109
	PrecStd	380	85	64	72	56	63	35	38	70	95	100	86	100
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	10.8	11.2	13.4	15.6	15.0	17.2	17.1	15.7	14.2	11.4	10.5
		MCWB	7.5	8.4	8.3	9.1	11.5	13.0	14.7	14.9	13.6	11.4	9.4	7.8
	2%	DB	9.0	9.5	9.1	11.2	13.1	14.1	15.5	16.2	14.9	12.7	10.6	9.6
		MCWB	7.7	7.6	7.1	8.4	11.3	12.6	14.0	14.6	13.3	11.2	8.9	7.8
	5%	DB	8.4	8.7	8.4	9.8	12.0	13.4	14.8	15.6	14.3	12.1	10.0	8.8
		MCWB	7.1	7.0	6.8	7.8	10.8	12.1	13.5	14.3	13.0	10.7	8.4	7.5
	10%	DB	7.9	8.0	7.8	9.1	11.2	12.9	14.3	15.0	13.8	11.6	9.4	8.2
		MCWB	6.6	6.6	6.4	7.4	10.0	11.7	13.2	14.0	12.7	10.2	8.0	6.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	9.2	8.7	9.6	12.5	13.7	15.1	15.6	14.4	12.9	10.4	9.0
		MCDB	9.0	10.4	10.3	12.0	14.0	14.4	16.4	16.2	15.1	13.5	10.9	9.5
	2%	WB	8.0	8.2	7.9	8.9	11.6	12.9	14.3	15.0	13.8	11.6	9.4	8.3
		MCDB	8.6	9.1	8.6	10.5	12.5	13.7	15.1	15.7	14.3	12.2	10.1	9.0
	5%	WB	7.3	7.4	7.3	8.4	11.0	12.4	13.8	14.6	13.4	11.0	8.8	7.7
		MCDB	8.2	8.4	8.1	9.6	11.7	13.1	14.5	15.3	14.0	11.8	9.7	8.6
	10%	WB	6.7	6.6	6.7	7.8	10.3	11.9	13.4	14.1	12.9	10.4	8.2	7.1
		MCDB	7.8	7.7	7.7	8.8	11.0	12.6	14.1	14.9	13.6	11.4	9.1	8.1
Mean Daily Temperature Range	5% DB	MDBR	2.3	2.2	2.3	2.2	1.9	1.8	1.7	1.8	1.9	2.0	2.2	2.5
		MCDBR	2.6	2.4	2.9	3.3	3.1	2.6	2.4	2.4	2.6	2.3	2.5	2.7
		MCWBR	2.3	1.7	2.0	2.1	2.1	1.9	1.8	1.6	2.0	2.0	2.3	2.5
	5% WB	MCDBR	2.6	2.3	2.4	2.9	2.7	2.4	2.2	2.2	2.4	1.9	2.4	2.5
		MCWBR	2.5	2.3	2.0	2.2	2.0	1.9	1.8	1.6	2.1	2.1	2.5	2.5
Clear-Sky Solar Irradiance	taub	0.306	0.313	0.337	0.371	0.367	0.373	0.369	0.363	0.356	0.337	0.313	0.296	
	taud	2.398	2.504	2.455	2.356	2.434	2.438	2.495	2.532	2.522	2.482	2.368	2.323	
	Ebn at Noon	657	794	846	856	880	875	873	859	818	746	631	574	
	Edh at Noon	53	67	86	108	106	107	99	90	81	67	54	47	
All-Sky Solar Radiation	RadAvg	0.51	1.33	2.39	3.82	4.90	5.17	4.68	4.04	2.67	1.47	0.68	0.41	
	RadStd	0.07	0.23	0.29	0.23	0.45	0.39	0.53	0.36	0.30	0.21	0.09	0.07	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page