

AGASSIZ, BC, Canada

WMO: 711130

Lat: 49.2428N

Lon: 121.7597W

Elev: 69

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 19.8	(c) 23.9	(d) -1.3	(e) 5.1	(f) 23.1	(g) 4.9	(h) 7.1	(i) 28.4	(j) 29.6	(k) 30.3	(l) 27.2	(m) 30.7	(n) 16.0	(o) 50	(p) 0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 20.2	(c) 86.8	(d) 68.2	(e) 83.4	(f) 67.0	(g) 80.1	(h) 65.8	(i) 70.6	(j) 82.7	(k) 68.5	(l) 80.3	(m) 66.8	(n) 77.8	(o) 4.8	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.0	96.0	77.1	64.1	89.6	74.1	62.4	84.5	71.3	34.4	82.7	32.8	80.9	31.3	77.9	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.1	17.4	13.8	16.5	93.4	4.9	3.4	13.0	95.8	10.2	97.8	7.4	99.7	3.8	102.1
			12.9	74.0	4.6	2.9	9.6	76.1	6.9	77.8	4.2	79.4	0.9	81.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	38.6	41.1	44.9	50.5	57.2	61.3	66.2	66.1	61.0	51.9	43.4	38.0
	DBStd	11.58	6.76	5.83	5.71	5.57	6.29	5.71	5.21	4.77	5.38	4.67	6.02	5.99
	HDD50	1456	355	252	177	56	8	0	0	0	0	31	206	371
	HDD65	5069	820	670	624	437	255	142	44	43	144	406	648	836
	CDD50	2094	0	2	18	71	232	338	503	500	331	91	8	0
	CDD65	232	0	0	0	2	15	30	82	78	25	0	0	0
	CDH74	2538	0	0	1	17	155	334	943	824	263	1	0	0
	CDH80	727	0	0	0	2	31	99	301	235	59	0	0	0
(14) Wind	WSAvg	4.3	6.5	5.5	4.4	4.0	3.6	3.3	3.2	3.0	3.3	3.8	5.2	6.4
(15) Precipitation	PrecAvg	69.6	9.1	7.1	6.1	4.8	4.1	3.3	2.4	2.4	4.1	7.1	9.7	9.5
	PrecMax	93.6	16.4	14.1	11.4	8.9	7.6	9.1	9.7	5.8	9.6	15.8	23.1	20.8
	PrecMin	51.4	2.1	1.0	2.0	2.2	1.1	0.6	0.0	0.2	0.6	1.1	3.1	2.2
	PrecStd	9.9	4.1	3.3	2.2	1.7	1.6	1.8	1.9	1.5	2.1	3.8	4.1	4.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	57.5	67.4	75.9	84.0	88.8	92.3	89.9	85.4	71.1	58.8	51.6
		MCWB	48.8	46.6	52.9	58.3	62.6	68.7	71.6	67.6	65.6	58.6	52.9	47.8
	2%	DB	50.6	53.6	60.7	69.3	78.4	82.6	87.1	85.8	81.0	66.1	55.4	48.6
		MCWB	46.7	45.3	50.0	55.8	61.8	65.6	68.9	68.8	64.3	55.1	50.6	44.9
	5%	DB	48.4	51.0	56.2	64.6	73.6	77.4	83.0	82.3	76.5	62.4	52.9	46.8
		MCWB	44.8	44.7	47.7	52.9	59.9	63.9	68.0	67.5	63.5	54.4	49.0	43.5
	10%	DB	46.4	48.6	52.8	60.2	68.9	72.9	79.2	78.7	72.0	59.3	50.8	45.2
		MCWB	43.2	43.7	46.3	50.8	57.9	61.4	66.4	66.0	61.1	53.2	47.6	42.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.0	50.0	55.6	61.0	66.1	70.8	75.2	72.4	68.4	61.6	54.9	49.0
		MCDB	52.2	53.2	63.7	72.3	79.7	84.3	87.8	84.6	80.7	67.1	57.3	50.3
	2%	WB	48.0	47.9	51.5	57.0	63.2	67.1	71.3	70.1	66.3	58.4	52.0	46.5
		MCDB	49.8	51.1	58.2	66.8	75.0	80.1	83.2	82.5	77.3	62.1	54.1	47.9
	5%	WB	45.9	46.2	49.4	54.2	61.0	64.6	69.0	68.3	64.4	56.2	50.1	44.5
		MCDB	47.5	49.4	54.0	61.8	71.1	75.4	80.2	80.0	74.6	59.8	52.0	45.9
	10%	WB	44.1	44.6	47.6	51.9	58.8	62.3	66.9	66.5	62.3	54.4	48.3	42.9
		MCDB	45.8	47.8	51.7	58.4	67.0	71.5	77.5	77.2	70.0	57.9	50.1	44.5
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	10.7	12.7	15.3	16.9	16.4	20.2	20.6	17.8	12.3	8.6	7.3
		MCDBR	10.7	13.7	18.4	22.9	24.9	26.0	28.1	28.2	26.3	17.7	11.0	9.0
	5% WB	MCWBR	7.3	8.1	10.3	12.7	12.8	13.2	13.5	13.6	13.4	9.9	7.6	6.4
		MCWBR	9.4	11.6	15.6	20.7	22.6	24.3	26.3	26.4	24.5	15.2	9.9	8.4
(40) Clear-Sky Solar Irradiance	taub	0.301	0.301	0.316	0.360	0.393	0.371	0.364	0.368	0.350	0.361	0.315	0.296	0.296
		taud	2.350	2.378	2.369	2.307	2.307	2.398	2.445	2.456	2.496	2.409	2.464	2.369
	Ebn at Noon	237	270	285	281	275	282	282	276	271	243	233	223	223
		Edh at Noon	22	26	31	37	39	36	34	32	28	26	19	19
(44) All-Sky Solar Radiation	RadAvg	318	591	910	1378	1676	1781	2044	1741	1211	687	340	248	248
	RadStd	44	66	102	113	145	191	180	127	106	83	45	34	34

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (64 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page