

AGASSIZ, BC, Canada

WMO: 711130

Lat: 49.2428N

Lon: 121.7597W

Elev: 21

StdP: 101.07

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-6.8	-4.5	-18.5	0.7	-4.9	-15.1	1.0	-2.0	13.2	-1.0	12.2	-0.7	7.2	50	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	30.4	20.1	28.5	19.4	26.7	18.8	21.4	28.2	20.3	26.9	19.3	25.4	2.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.7	25.1	17.8	12.8	23.4	16.9	12.1	21.8	62.2	28.2	58.3	27.1	55.0	25.5	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.9	7.8	6.2	DB	-8.6	34.1	2.7	1.9	-10.5	35.5	-12.1	36.6	-13.7	37.6	-15.6	39.0
			WB	-10.6	23.4	2.6	1.6	-12.5	24.5	-14.0	25.4	-15.4	26.3	-17.3	27.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	3.6	5.0	7.1	10.3	14.0	16.3	19.0	19.0	16.1	11.1	6.3	3.4
	DBStd	6.43	3.75	3.24	3.17	3.09	3.49	3.17	2.90	2.65	2.99	2.60	3.35	3.33
	HDD10.0	809	197	140	98	31	4	0	0	0	0	17	114	206
	HDD18.3	2816	456	372	347	243	142	79	24	24	80	226	360	464
	CDD10.0	1163	0	1	10	39	129	188	279	278	184	51	4	0
	CDD18.3	129	0	0	0	1	8	17	46	43	14	0	0	0
	CDH23.3	1410	0	0	1	9	86	186	524	458	146	1	0	0
	CDH26.7	404	0	0	0	1	17	55	167	131	33	0	0	0
Wind	WSAvg	1.9	2.9	2.5	2.0	1.8	1.6	1.5	1.4	1.3	1.5	1.7	2.3	2.9
Precipitation	PrecAvg	1769	232	180	154	123	104	84	61	61	103	180	247	241
	PrecMax	2378	417	359	290	227	192	232	247	147	244	401	586	528
	PrecMin	1306	54	26	52	56	28	16	0	5	15	28	78	55
	PrecStd	252	103	85	56	43	41	45	47	39	53	97	105	103
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	14.2	19.7	24.4	28.9	31.6	33.5	32.2	29.7	21.7	14.9	10.9
		MCWB	9.3	8.1	11.6	14.6	17.0	20.4	22.0	19.8	18.7	14.8	11.6	8.8
	2%	DB	10.3	12.0	15.9	20.7	25.8	28.1	30.6	29.9	27.2	19.0	13.0	9.2
		MCWB	8.2	7.4	10.0	13.2	16.5	18.7	20.5	20.5	17.9	12.8	10.3	7.2
	5%	DB	9.1	10.6	13.5	18.1	23.1	25.2	28.3	27.9	24.7	16.9	11.6	8.2
		MCWB	7.1	7.0	8.7	11.6	15.5	17.7	20.0	19.7	17.5	12.4	9.4	6.4
	10%	DB	8.0	9.2	11.5	15.6	20.5	22.7	26.2	26.0	22.2	15.2	10.5	7.3
		MCWB	6.2	6.5	7.9	10.4	14.4	16.3	19.1	18.9	16.2	11.8	8.6	5.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	10.0	13.1	16.1	19.0	21.5	24.0	22.4	20.2	16.4	12.7	9.4
		MCDB	11.2	11.8	17.6	22.4	26.5	29.0	31.0	29.2	27.0	19.5	14.0	10.2
	2%	WB	8.9	8.9	10.8	13.9	17.4	19.5	21.8	21.2	19.1	14.7	11.1	8.0
		MCDB	9.9	10.6	14.5	19.3	23.9	26.7	28.4	28.0	25.2	16.7	12.3	8.8
	5%	WB	7.7	7.9	9.7	12.3	16.1	18.1	20.5	20.2	18.0	13.5	10.1	7.0
		MCDB	8.6	9.7	12.2	16.5	21.7	24.1	26.8	26.7	23.7	15.4	11.1	7.7
	10%	WB	6.7	7.0	8.7	11.1	14.9	16.9	19.4	19.2	16.8	12.5	9.1	6.1
		MCDB	7.7	8.8	11.0	14.6	19.5	21.9	25.3	25.1	21.1	14.4	10.1	7.0
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.9	7.1	8.5	9.4	9.1	11.2	11.4	9.9	6.8	4.8	4.0
		MCDBR	5.9	7.6	10.2	12.7	13.8	14.5	15.6	15.7	14.6	9.8	6.1	5.0
		MCWBR	4.1	4.5	5.7	7.0	7.1	7.3	7.5	7.6	7.5	5.5	4.2	3.5
	5% WB	MCDBR	5.2	6.4	8.7	11.5	12.5	13.5	14.6	14.7	13.6	8.5	5.5	4.7
		MCWBR	4.1	4.3	5.4	6.8	6.9	7.1	7.7	7.6	7.4	5.3	4.2	3.8
Clear-Sky Solar Irradiance	taub	0.301	0.301	0.316	0.360	0.393	0.371	0.364	0.368	0.350	0.361	0.315	0.296	
	taud	2.350	2.378	2.369	2.307	2.307	2.398	2.445	2.456	2.496	2.409	2.464	2.369	
	Ebn at Noon	748	851	897	886	867	889	890	870	853	766	734	702	
	Edh at Noon	68	83	99	118	124	114	107	101	88	82	61	59	
All-Sky Solar Radiation	RadAvg	1.00	1.86	2.87	4.34	5.28	5.61	6.44	5.49	3.82	2.17	1.07	0.78	
	RadStd	0.14	0.21	0.32	0.35	0.46	0.60	0.57	0.40	0.33	0.26	0.14	0.11	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (64 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page