

VERNON, BC, Canada

WMO: 711150

Lat: 50.2234N

Lon: 119.1937W

Elev: 1581

StdP: 13.88

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.8	8.3	-3.7	4.8	5.0	2.5	6.6	9.8	13.2	26.0	11.6	24.9	4.6	100	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.2	91.3	65.0	87.8	64.0	84.1	62.7	67.1	84.9	65.4	83.0	63.9	80.4	3.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.7	87.1	70.4	59.7	81.2	68.8	58.0	76.2	67.7	32.4	84.8	31.1	82.8	29.9	80.7	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
13.0	11.1	9.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-3.6	97.5	8.0	3.4	-9.4	99.9	-14.1	101.9	-18.6	103.8	-24.5	106.2
			-3.9	70.4	7.8	2.3	-9.5	72.0	-14.1	73.4	-18.5	74.7	-24.2	76.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.6	26.9	30.0	39.4	47.7	57.0	62.8	69.6	68.4	59.1	46.1	35.3	27.1	
	DBStd	16.63	8.62	7.96	7.04	5.59	6.58	6.20	6.08	5.81	6.28	5.85	7.69	8.09	
	HDD50	3033	715	559	330	109	13	1	0	0	5	149	443	709	
	HDD65	6757	1180	979	793	520	261	114	26	34	197	587	892	1174	
	CDD50	2137	0	0	2	39	229	385	607	570	278	27	0	0	
	CDD65	387	0	0	0	0	12	48	168	139	20	0	0	0	
	CDH74	4595	0	0	0	7	236	604	1959	1542	246	1	0	0	
	CDH80	1770	0	0	0	0	57	201	846	606	60	0	0	0	
Wind	WSAvg	3.9	3.3	3.7	4.6	4.8	4.1	3.6	3.6	3.7	3.6	3.7	4.0	3.6	
Precipitation	PrecAvg	17.8	1.4	1.1	1.0	1.1	1.7	2.0	1.5	1.6	1.6	1.2	1.6	1.9	
	PrecMax	23.7	3.1	3.2	2.4	2.5	3.5	3.8	3.7	4.9	3.9	3.5	3.0	4.3	
	PrecMin	11.7	0.2	0.2	0.0	0.2	0.6	0.3	0.2	0.2	0.2	0.2	0.6	0.9	
	PrecStd	3.3	0.6	0.7	0.4	0.6	0.8	1.0	0.8	0.9	1.0	0.7	0.6	0.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.5	48.4	62.0	73.7	85.9	91.9	96.6	94.3	86.8	67.9	54.2	45.4	
		MCWB	38.2	41.2	48.3	54.8	61.9	64.9	66.6	65.6	63.0	55.7	47.6	40.1	
	2%	DB	39.5	44.4	56.8	67.8	80.5	85.8	92.5	90.3	80.6	62.1	49.2	40.7	
		MCWB	36.4	38.7	45.4	51.4	59.1	62.9	65.8	64.7	61.4	52.3	44.7	37.3	
	5%	DB	36.9	41.3	53.0	63.4	75.5	80.8	88.9	86.7	75.9	58.5	46.5	37.7	
		MCWB	35.3	37.3	43.5	49.2	57.1	60.5	64.4	63.8	59.3	50.4	42.9	35.7	
	10%	DB	35.3	38.7	49.6	59.4	70.9	76.4	84.8	82.9	71.2	55.3	44.2	35.4	
		MCWB	34.4	35.9	41.7	47.3	55.3	59.4	63.2	62.5	57.3	49.0	41.6	34.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.3	42.7	49.5	56.6	63.3	67.5	70.5	69.0	65.5	57.5	48.7	41.0
			MCDB	42.7	45.8	59.1	70.7	80.6	84.6	88.8	88.1	79.6	64.2	51.9	43.2
2%		WB	37.1	39.8	46.7	53.1	60.6	64.5	67.6	66.5	62.7	54.6	46.0	38.1	
		MCDB	38.5	42.6	54.7	64.7	75.9	80.8	85.5	84.4	76.8	59.7	48.2	39.8	
5%		WB	35.6	38.0	44.7	50.6	58.6	62.5	65.8	64.9	60.6	51.8	43.9	35.9	
		MCDB	36.6	40.3	51.3	60.7	71.7	77.0	84.2	82.2	72.9	56.4	45.6	37.1	
10%		WB	34.4	36.3	42.6	48.4	56.7	60.6	64.2	63.5	58.7	49.6	41.9	34.3	
		MCDB	35.2	38.3	48.2	57.8	68.6	73.3	81.4	79.7	69.7	54.4	43.7	35.2	
Mean Daily Temperature Range		5% DB	MDBR	8.7	12.1	16.3	20.8	23.1	22.5	26.2	26.4	22.3	15.8	9.9	8.4
			MCDBR	9.6	13.9	21.3	27.7	30.8	30.4	32.4	32.2	28.9	20.5	12.9	10.1
	MCWBR		7.2	9.1	12.0	14.2	14.3	12.6	12.8	13.0	13.3	11.7	8.8	7.5	
	5% WB	MCDBR	8.6	12.1	19.5	24.5	26.3	26.6	29.3	29.1	26.1	17.6	11.3	9.0	
		MCWBR	6.6	8.3	11.6	13.3	13.0	12.1	12.3	12.3	12.7	10.9	8.3	7.1	
Clear-Sky Solar Irradiance	taub	0.296	0.286	0.313	0.340	0.365	0.364	0.362	0.374	0.342	0.331	0.303	0.275		
	taud	2.294	2.405	2.407	2.392	2.370	2.406	2.439	2.402	2.476	2.477	2.447	2.402		
	Ebn at Noon	233	274	285	287	283	283	282	273	271	253	233	228		
	Edh at Noon	22	25	30	34	36	36	34	34	28	23	19	17		
All-Sky Solar Radiation	RadAvg	280	593	966	1416	1700	1790	2034	1739	1201	669	299	213		
	RadStd	30	56	101	113	136	172	168	116	107	86	36	26		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page