

VERNON, BC, Canada

WMO: 711150

Lat: 50.2234N

Lon: 119.1937W

Elev: 482

StdP: 95.67

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.2	-13.2	-19.8	0.7	-15.0	-16.4	0.9	-12.3	5.9	-3.4	5.2	-3.9	2.0	100	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	33.0	18.3	31.0	17.8	29.0	17.0	19.5	29.4	18.6	28.3	17.7	26.9	1.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.5	12.4	21.3	15.4	11.6	20.4	14.4	10.9	19.8	57.5	29.3	54.4	28.2	51.7	27.0	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.8	5.0	4.3	DB	-19.8	36.4	4.5	1.9	-23.0	37.7	-25.6	38.8	-28.1	39.9	-31.4	41.2	(4)
(5)			WB	-19.9	21.3	4.3	1.3	-23.1	22.2	-25.6	23.0	-28.0	23.7	-31.2	24.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	-2.8	-1.1	4.1	8.7	13.9	17.1	20.9	20.2	15.1	7.8	1.8	-2.7	(6)	
	DBStd	9.24	4.79	4.42	3.91	3.11	3.66	3.45	3.38	3.23	3.49	3.25	4.27	4.49	(7)	
	HDD10.0	1685	397	311	183	61	7	1	0	0	3	83	246	394	(8)	
	HDD18.3	3754	656	544	441	289	145	63	14	19	109	326	496	652	(9)	
	CDD10.0	1187	0	0	1	22	127	214	337	317	154	15	0	0	(10)	
	CDD18.3	215	0	0	0	0	7	27	93	77	11	0	0	0	(11)	
	CDH23.3	2553	0	0	0	4	131	336	1088	857	137	1	0	0	(12)	
	CDH26.7	983	0	0	0	0	32	112	470	337	33	0	0	0	(13)	
(14) Wind	WSAvg	1.7	1.5	1.6	2.1	2.1	1.8	1.6	1.6	1.7	1.6	1.7	1.8	1.6	(14)	
(15) Precipitation	PrecAvg	452	36	29	26	27	42	51	39	41	41	30	41	48	(15)	
	PrecMax	601	79	81	62	63	88	96	95	124	99	88	77	108	(16)	
	PrecMin	298	4	6	1	6	15	8	6	6	6	6	14	24	(17)	
	PrecStd	83	16	17	11	14	20	25	20	23	25	18	16	19	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.9	9.1	16.7	23.2	30.0	33.3	35.9	34.6	30.4	20.0	12.3	7.4	(19)	
		MCWB	3.4	5.1	9.0	12.7	16.6	18.3	19.2	18.7	17.2	13.2	8.6	4.5	(20)	
	2%	DB	4.2	6.9	13.8	19.9	26.9	29.9	33.6	32.4	27.0	16.7	9.5	4.8	(21)	
		MCWB	2.5	3.7	7.4	10.8	15.1	17.1	18.8	18.2	16.3	11.3	7.1	2.9	(22)	
	5%	DB	2.7	5.2	11.6	17.4	24.2	27.1	31.6	30.4	24.4	14.7	8.1	3.2	(23)	
		MCWB	1.8	3.0	6.4	9.6	13.9	15.9	18.0	17.7	15.2	10.2	6.1	2.1	(24)	
	10%	DB	1.8	3.7	9.8	15.2	21.6	24.7	29.4	28.3	21.8	12.9	6.8	1.9	(25)	
		MCWB	1.3	2.1	5.4	8.5	12.9	15.2	17.3	16.9	14.0	9.4	5.3	1.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	5.9	9.7	13.6	17.4	19.7	21.4	20.5	18.6	14.2	9.3	5.0	(27)	
		MCDB	6.0	7.7	15.1	21.5	27.0	29.2	31.5	31.2	26.4	17.9	11.0	6.2	(28)	
	2%	WB	2.8	4.3	8.2	11.7	15.9	18.1	19.8	19.2	17.0	12.6	7.8	3.4	(29)	
		MCDB	3.6	5.9	12.6	18.2	24.4	27.1	29.7	29.1	24.9	15.4	9.0	4.3	(30)	
	5%	WB	2.0	3.3	7.1	10.3	14.8	16.9	18.8	18.3	15.9	11.0	6.6	2.2	(31)	
		MCDB	2.5	4.6	10.7	15.9	22.0	25.0	29.0	27.9	22.7	13.5	7.6	2.9	(32)	
	10%	WB	1.4	2.4	5.9	9.1	13.7	15.9	17.9	17.5	14.8	9.8	5.5	1.3	(33)	
		MCDB	1.8	3.5	9.0	14.4	20.3	23.0	27.4	26.5	21.0	12.5	6.5	1.8	(34)	
(35) Mean Daily Temperature Range	MDBR		4.9	6.7	9.0	11.5	12.8	12.5	14.6	14.6	12.4	8.8	5.5	4.7	(35)	
	5% DB	MCDBR	5.3	7.7	11.8	15.4	17.1	16.9	18.0	17.9	16.0	11.4	7.2	5.6	(36)	
		MCWBR	4.0	5.0	6.7	7.9	8.0	7.0	7.1	7.2	7.4	6.5	4.9	4.2	(37)	
	5% WB	MCDBR	4.8	6.7	10.8	13.6	14.6	14.8	16.3	16.2	14.5	9.8	6.3	5.0	(38)	
		MCWBR	3.7	4.6	6.5	7.4	7.2	6.7	6.8	6.8	7.1	6.0	4.6	3.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.296	0.286	0.313	0.340	0.365	0.364	0.362	0.374	0.342	0.331	0.303	0.275	(40)	
	taud		2.294	2.405	2.407	2.392	2.370	2.406	2.439	2.402	2.476	2.477	2.447	2.402	(41)	
	Ebn at Noon		733	864	897	905	891	893	889	860	855	797	733	720	(42)	
	Edh at Noon		68	79	95	108	115	112	107	106	88	74	60	54	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.88	1.87	3.05	4.46	5.36	5.64	6.41	5.48	3.79	2.11	0.94	0.67	(44)	
	RadStd		0.10	0.18	0.32	0.36	0.43	0.54	0.53	0.37	0.34	0.27	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (17 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page