

EASTEND CYPRESS, SK, Canada

WMO: 711310

Lat: 49.4378N

Lon: 108.9886W

Elev: 1080

StdP: 89.01

Time Zone: -6.00 (W06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.1	-26.2	-35.5	0.1	-28.2	-31.2	0.2	-25.7	17.0	-12.1	15.3	-8.6	4.1	300	0.749

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	30.3	16.0	28.4	15.5	26.5	15.0	18.1	25.4	17.0	24.7	16.1	23.7	5.1	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.7	12.7	20.8	14.4	11.7	19.6	13.2	10.8	18.5	55.5	25.3	52.0	24.5	49.0	23.6	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.4	11.7	10.3	-32.5	33.4	2.7	1.5	-34.5	34.5	-36.1	35.4	-37.6	36.2	-39.5	37.4		
			-32.4	20.1	2.9	1.4	-34.5	21.1	-36.2	21.9	-37.8	22.7	-39.9	23.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.9	-10.2	-9.3	-3.6	4.0	9.7	14.1	18.2	17.7	12.3	4.6	-3.1	-9.2
	DBStd	11.83	7.98	7.64	7.55	5.43	4.58	3.58	3.43	3.88	5.13	5.43	6.69	7.43
	HDD10.0	3045	625	542	422	189	61	6	1	1	32	179	393	594
	HDD18.3	5382	883	775	679	431	267	132	45	59	190	424	643	853
	CDD10.0	802	0	0	1	8	53	131	256	240	102	12	1	0
	CDD18.3	99	0	0	0	0	1	7	42	39	9	0	0	0
	CDH23.3	1279	0	0	0	2	36	95	499	511	134	2	0	0
	CDH26.7	374	0	0	0	0	3	18	151	169	33	0	0	0
Wind	WSAvg	4.9	5.1	4.7	5.0	5.3	5.5	5.0	4.4	4.3	4.5	4.8	4.8	4.9
Precipitation	PrecAvg	356	18	13	16	25	51	76	50	38	27	17	14	14
	PrecMax	534	51	23	38	59	116	177	111	131	89	92	28	42
	PrecMin	212	2	5	0	2	11	33	14	3	0	0	3	1
	PrecStd	75	12	5	9	15	27	32	28	33	22	17	7	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	7.5	15.8	22.0	26.8	28.9	32.3	32.7	29.9	22.5	13.8	6.5
		MCWB	2.1	3.2	7.7	10.1	13.3	16.0	16.8	15.9	14.5	11.8	6.8	2.1
	2%	DB	3.3	3.9	11.1	18.8	24.0	25.9	30.2	30.7	27.3	18.5	10.3	3.9
		MCWB	1.1	1.0	5.0	9.1	12.5	15.2	16.7	15.5	13.6	9.6	5.1	1.0
	5%	DB	1.9	1.9	8.1	15.9	21.2	23.7	28.3	28.5	24.3	15.3	7.5	1.9
		MCWB	0.1	-0.1	3.5	7.4	11.0	14.2	16.4	15.1	12.7	8.1	3.2	-0.3
	10%	DB	0.2	0.3	5.3	13.0	18.5	21.7	26.2	26.2	21.3	12.6	5.1	0.1
		MCWB	-1.4	-1.4	2.0	5.9	9.8	13.4	15.9	14.6	11.6	6.8	1.7	-1.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	3.6	7.9	11.3	14.5	18.5	20.2	18.5	16.5	12.2	7.7	2.9
		MCDB	4.6	6.7	14.2	20.2	23.3	24.3	27.6	26.2	25.5	20.5	13.1	5.8
	2%	WB	1.3	1.3	5.5	9.5	13.0	16.6	18.6	17.3	14.6	10.3	5.4	1.1
		MCDB	3.0	3.5	10.1	17.6	21.9	23.2	26.2	25.4	23.8	16.9	9.8	3.4
	5%	WB	0.1	0.0	3.7	8.0	11.8	15.3	17.6	16.5	13.3	8.7	3.6	-0.2
		MCDB	1.8	1.7	7.6	14.9	19.6	21.9	25.0	24.9	22.5	14.5	6.9	1.9
	10%	WB	-1.4	-1.4	2.2	6.5	10.6	14.1	16.6	15.5	12.1	7.2	2.1	-1.6
		MCDB	0.2	0.2	5.2	12.4	17.0	20.2	23.9	24.0	20.4	12.0	4.8	0.1
Mean Daily Temperature Range	5% DB	MDBR	8.6	8.8	9.3	11.4	11.8	12.9	13.4	12.4	11.2	9.3	8.3	
		MCDBR	9.2	9.6	12.9	16.1	15.9	14.3	15.7	16.7	16.3	14.8	12.0	9.9
		MCWBR	7.6	7.5	7.9	8.7	7.5	6.8	6.3	6.2	7.1	8.0	7.8	7.7
	5% WB	MCDBR	9.2	9.6	12.1	14.8	14.3	13.1	13.4	13.9	14.8	13.7	11.4	9.6
		MCWBR	7.8	7.7	8.0	8.4	7.2	6.9	6.3	5.9	6.8	7.7	7.7	7.7
Clear-Sky Solar Irradiance	taub	0.250	0.261	0.280	0.321	0.343	0.335	0.340	0.358	0.313	0.282	0.255	0.243	
	taud	2.421	2.439	2.480	2.387	2.366	2.448	2.442	2.360	2.460	2.535	2.506	2.421	
	Ebn at Noon	830	907	943	928	915	923	913	877	891	871	824	789	
	Edh at Noon	61	77	88	109	116	108	107	111	90	70	56	53	
All-Sky Solar Radiation	RadAvg	1.33	2.35	3.67	4.91	5.84	6.34	6.90	5.64	4.06	2.55	1.47	1.03	
	RadStd	0.12	0.16	0.22	0.32	0.41	0.40	0.43	0.39	0.34	0.25	0.11	0.08	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page