

BURGEO, NL, CanadaWMO: **711520**Lat: **47.613N**Lon: **57.610W**Elev: **35**StdP: **14.68**Time Zone: **-3.50 (NAF)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.4	10.0	-1.7	5.0	7.7	1.8	6.0	10.9	47.6	29.5	42.8	27.6	13.5	300	0.764

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.0	70.1	63.4	68.1	62.5	66.3	61.7	65.8	68.0	64.3	66.5	62.9	65.0	11.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.9	92.1	67.1	63.3	87.3	65.6	61.8	82.7	64.2	30.7	68.2	29.5	66.6	28.4	65.1	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.3	33.9	29.1	1.8	76.5	5.0	2.7	-1.8	78.4	-4.7	79.9	-7.5	81.4	-11.2	83.4		
(5)			1.0	68.9	4.7	3.0	-2.4	71.0	-5.2	72.7	-7.8	74.4	-11.3	76.5	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.5	24.9	23.8	28.0	35.4	43.4	50.5	58.3	61.7	55.3	46.6	38.5	30.7	
	DBStd	13.84	7.07	7.83	6.99	4.70	4.18	4.32	3.55	3.38	4.88	5.11	6.12	6.90	
	HDD50	3968	777	734	683	439	207	43	0	0	11	130	346	598	
	HDD65	8574	1242	1154	1148	889	668	435	208	111	291	570	795	1063	
	CDD50	883	0	0	0	0	4	59	259	363	171	25	2	0	
	CDD65	10	0	0	0	0	0	0	1	8	1	0	0	0	
	CDH74	9	0	0	0	0	0	0	3	5	1	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	12.7	16.2	15.9	14.9	13.9	11.1	9.6	8.4	8.8	10.7	12.6	14.4	15.9	
Precipitation	PrecAvg	71.6	6.6	5.5	5.4	5.5	5.1	6.0	5.7	5.6	5.4	6.3	7.2	7.3	
	PrecMax	88.2	11.5	10.6	9.8	10.5	8.8	11.6	10.2	13.3	8.6	10.4	10.5	12.0	
	PrecMin	59.1	3.5	1.6	2.2	1.9	1.0	1.2	1.5	2.6	2.6	2.5	3.9	3.0	
	PrecStd	7.5	2.3	2.2	2.2	2.6	1.8	3.0	2.0	2.6	1.7	2.2	2.0	2.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.9	43.5	44.2	50.9	60.3	67.9	71.9	73.8	70.6	61.8	54.3	48.2	
		MCWB	42.7	42.5	40.3	43.8	50.4	56.6	62.4	64.6	63.9	56.8	52.9	46.5	
	2%	DB	40.4	39.4	40.7	46.3	55.7	62.6	68.4	71.0	66.8	58.9	51.9	45.1	
		MCWB	39.3	37.8	37.7	41.7	48.4	54.6	61.1	64.5	61.6	55.9	50.8	43.7	
	5%	DB	37.7	36.7	38.5	43.8	52.7	59.6	66.1	69.2	64.7	56.7	50.1	43.0	
		MCWB	36.5	34.9	35.9	39.9	46.8	53.1	60.4	63.8	60.3	53.9	48.9	41.7	
	10%	DB	35.3	34.6	36.6	41.7	50.2	57.3	64.1	67.5	62.9	54.7	47.9	40.6	
		MCWB	34.0	33.1	34.3	38.6	45.5	52.3	59.8	63.1	59.4	52.0	46.5	39.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.9	42.3	41.4	45.0	52.3	59.3	65.6	68.7	65.6	59.3	53.4	46.9
			MCDB	43.6	43.0	43.8	48.3	57.6	64.9	68.3	71.1	67.8	60.4	54.2	48.0
2%		WB	39.6	37.9	38.4	42.5	49.8	56.7	63.6	66.9	63.3	56.7	51.1	44.1	
		MCDB	40.3	38.8	40.2	45.1	54.2	60.2	66.0	69.1	65.1	58.2	51.7	44.9	
5%		WB	36.7	35.0	36.4	40.6	47.8	54.8	62.1	65.5	61.6	54.6	49.2	41.8	
		MCDB	37.5	36.0	38.0	42.8	51.6	58.1	64.4	67.7	63.3	56.3	50.0	42.9	
10%		WB	34.3	33.0	34.7	39.2	46.0	53.1	60.7	64.2	60.0	52.6	46.8	39.3	
		MCDB	35.1	34.2	36.2	41.1	49.4	56.5	62.8	66.4	61.8	54.2	47.8	40.6	
Mean Daily Temperature Range		5% DB	MDBR	10.9	11.2	10.8	9.8	10.9	10.0	8.8	10.0	11.6	11.0	9.7	9.5
			MCDBR	13.2	12.0	11.0	12.7	15.6	15.2	13.1	12.8	13.0	12.2	10.2	10.5
	MCWBR		13.7	11.8	9.5	9.6	10.4	9.6	8.8	9.0	9.8	10.3	10.6	11.0	
	5% WB	MCDBR	13.3	12.5	10.2	10.8	13.4	12.6	10.1	10.6	10.6	10.9	10.0	11.0	
		MCWBR	13.9	12.8	9.5	9.5	8.9	9.6	8.8	7.8	8.5	9.1	10.3	10.8	11.7
Clear-Sky Solar Irradiance	taub	0.302	0.308	0.334	0.361	0.367	0.389	0.422	0.401	0.368	0.344	0.318	0.307		
	taud	2.331	2.355	2.340	2.357	2.424	2.388	2.340	2.391	2.477	2.491	2.484	2.346		
	Ebn at Noon	244	271	280	283	284	278	266	267	267	256	240	226		
	Edh at Noon	23	28	33	36	35	37	38	35	29	25	20	20		
All-Sky Solar Radiation	RadAvg	320	473	883	1311	1609	1624	1527	1393	1124	706	376	254		
	RadStd	24	57	79	119	138	177	126	87	67	48	42	28		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.68	N/A	N/A	N/A	N/A

Nomenclature: See separate page