

LITTLE CHICAGO, NT, Canada

WMO: 711640

Lat: 67.180N

Lon: 130.230W

Elev: 205

StdP: 14.59

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-47.8	-44.6	-56.7	0.2	-47.6	-52.9	0.2	-44.3	17.8	2.0	13.8	-3.3	1.2	0	0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	81.1	62.6	77.5	60.8	74.1	59.4	64.7	77.1	62.7	74.1	60.8	71.4	6.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.8	77.2	68.9	57.6	71.4	67.2	55.7	66.5	66.1	29.8	77.2	28.4	74.3	27.1	71.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.0	12.6	11.0	-50.5	87.0	3.2	3.4	-52.8	89.4	-54.7	91.3	-56.5	93.2	-58.8	95.6		
(5)			-50.5	68.0	3.0	2.7	-52.6	69.9	-54.3	71.5	-56.0	73.0	-58.2	75.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.9	-18.1	-12.6	-4.6	19.3	41.6	58.0	60.7	54.4	42.1	23.5	-1.4	-14.0		
	DBStd	31.17	16.52	14.59	14.02	13.32	11.65	8.38	6.99	7.77	7.65	9.49	12.67	13.47		
	HDD50	11464	2112	1752	1692	920	309	23	7	44	256	821	1543	1985		
	HDD65	16159	2577	2172	2157	1370	726	238	165	339	687	1285	1993	2450		
	CDD50	851	0	0	0	0	49	264	340	179	19	0	0	0		
	CDD65	72	0	0	0	0	1	29	33	9	0	0	0	0		
	CDH74	753	0	0	0	0	22	297	334	100	0	0	0	0		
	CDH80	141	0	0	0	0	3	63	61	14	0	0	0	0		
	WSAvg	4.5	2.7	3.4	4.3	5.1	6.0	6.0	5.6	5.4	5.2	4.4	3.1	2.6		
	PrecAvg	13.0	0.7	0.6	0.6	0.4	0.7	1.6	2.1	2.1	1.6	1.1	0.8	0.7		
(15) Precipitation	PrecMax	16.4	1.6	1.2	1.2	0.9	1.5	2.5	4.1	3.9	2.6	1.7	1.7	1.3		
	PrecMin	9.9	0.2	0.2	0.1	0.0	0.2	0.6	1.0	1.0	0.9	0.4	0.3	0.3		
	PrecStd	1.5	0.4	0.3	0.2	0.2	0.3	0.5	0.7	0.7	0.3	0.3	0.4	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.2	27.3	38.5	57.2	77.2	85.5	85.5	81.9	68.1	48.9	31.3	20.6		
		MCWB	27.1	25.2	33.2	45.4	55.6	64.0	65.5	64.6	55.6	42.7	30.0	19.4		
	2%	DB	15.8	16.4	29.7	50.2	70.6	81.3	81.1	76.5	63.5	41.8	23.4	12.9		
		MCWB	15.0	15.3	25.8	41.4	53.1	61.3	63.8	61.9	53.1	38.2	22.3	12.2		
	5%	DB	7.5	11.3	22.7	44.7	65.5	77.2	77.7	72.5	58.6	37.8	19.8	8.6		
		MCWB	6.9	10.4	20.1	37.5	50.5	58.9	62.1	59.8	50.5	35.2	18.8	7.9		
	10%	DB	2.8	7.4	16.5	40.0	60.6	73.3	74.3	68.2	54.4	34.9	16.0	4.4		
		MCWB	2.2	6.5	14.5	34.0	47.8	57.8	60.6	58.2	48.6	32.9	15.2	3.8		
	0.4%	WB	27.2	25.0	33.5	45.5	57.0	65.6	68.4	66.1	56.9	43.4	30.0	19.4		
		MCDB	29.2	27.1	38.1	56.9	75.3	82.8	80.9	78.1	65.8	47.6	31.5	20.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	15.0	15.4	25.9	41.9	53.7	62.7	65.5	63.4	53.8	38.5	22.4	12.3		
		MCDB	15.8	16.3	29.3	49.9	68.9	77.5	78.0	74.1	61.7	41.4	23.3	12.9		
	5%	WB	6.9	10.5	19.8	37.8	51.3	60.8	63.6	61.0	51.3	35.4	18.9	8.0		
		MCDB	7.3	11.3	22.5	44.2	64.7	74.3	74.8	70.5	57.5	37.5	19.7	8.6		
	10%	WB	2.2	6.6	14.3	34.1	48.4	58.8	61.7	58.7	48.8	33.1	15.3	3.8		
		MCDB	2.7	7.4	16.3	39.8	60.2	71.3	71.9	67.2	53.8	34.7	16.0	4.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	15.0	21.5	22.9	20.1	19.8	19.1	17.2	14.2	10.0	12.3	13.0		
		MCDBR	15.8	17.0	25.3	26.0	26.5	24.5	24.6	24.3	22.9	12.3	12.8	15.8		
		MCWBR	15.2	16.3	21.8	18.2	13.9	11.1	12.2	12.7	13.7	9.4	12.3	15.4		
		MCDBR	16.0	16.9	25.0	24.9	25.7	22.6	21.8	22.0	20.9	11.5	12.7	15.7		
	5% WB	MCWBR	15.4	16.2	21.6	17.4	13.8	10.9	11.7	12.2	13.0	9.0	12.3	15.4		
(40) Clear-Sky Solar Irradiance	taub		0.153	0.220	0.252	0.305	0.339	0.341	0.366	0.341	0.301	0.242	0.161	N/A		
	taud		1.935	2.184	2.245	2.176	2.336	2.450	2.400	2.482	2.541	2.318	1.938	N/A		
	Ebn at Noon		75	206	259	268	272	274	262	258	244	194	62	0		
	Edh at Noon		3	14	24	34	33	30	31	26	19	12	3	0		
(44) All-Sky Solar Radiation	RadAvg		22	216	779	1520	1853	1952	1620	1142	643	217	43	0		
	RadStd		2	13	29	54	174	154	122	101	65	21	4	0		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (4 neighbors)	+1.91	+3.74	+4.09	N/A	N/A	N/A	-787	-761	N/A	N/A	

Nomenclature: See separate page