

LITTLE CHICAGO, NT, Canada

WMO: 711640

Lat: 67.180N

Lon: 130.230W

Elev: 63

StdP: 100.58

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -44.3	(c) -42.5	(d) -49.3	(e) 0.0	(f) -44.2	(g) -47.2	(h) 0.0	(i) -42.4	(j) 7.9	(k) -16.7	(l) 6.2	(m) -19.6	(n) 0.6	(o) 0	(p) 0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	27.3	17.0	25.3	16.0	23.4	15.2	18.1	25.1	17.0	23.4	16.0	21.9	2.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.4	11.0	20.5	14.2	10.2	19.6	13.2	9.5	18.9	51.4	25.1	48.1	23.5	45.1	22.2	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.7	(b) 5.6	(c) 4.9	(e) -45.8	(f) 30.5	(g) 1.8	(h) 1.9	(i) -47.1	(j) 31.9	(k) -48.2	(l) 33.0	(m) -49.2	(n) 34.0	(o) -50.4	(p) 35.4		
(a) 6.7	(b) 5.6	(c) 4.9	(e) -45.8	(f) 20.0	(g) 1.7	(h) 1.5	(i) -47.0	(j) 21.1	(k) -48.0	(l) 21.9	(m) -48.9	(n) 22.8	(o) -50.1	(p) 23.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-6.2	-27.9	-24.8	-20.3	-7.0	5.3	14.5	16.0	12.4	5.6	-4.7	-18.6	-25.6		
	DBStd	17.31	9.18	8.11	7.79	7.40	6.47	4.65	3.88	4.32	4.25	5.27	7.04	7.48		
	HDD10.0	6369	1173	973	940	511	172	13	4	24	142	456	857	1103		
	HDD18.3	8977	1432	1207	1198	761	403	132	92	188	382	714	1107	1361		
	CDD10.0	473	0	0	0	0	27	147	189	99	11	0	0	0		
	CDD18.3	40	0	0	0	0	1	16	18	5	0	0	0	0		
	CDH23.3	418	0	0	0	0	12	165	186	56	0	0	0	0		
	CDH26.7	78	0	0	0	0	2	35	34	8	0	0	0	0		
(14) Wind	WSAvg	2.0	1.2	1.5	1.9	2.3	2.7	2.7	2.5	2.4	2.3	1.9	1.4	1.2		
(15) Precipitation	PrecAvg	330	19	16	14	11	19	40	53	53	40	27	21	17		
	PrecMax	416	40	30	30	24	39	63	104	100	65	44	44	32		
	PrecMin	252	6	4	3	1	5	15	26	25	23	10	7	7		
	PrecStd	39	9	7	6	6	7	12	17	17	8	8	9	6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.6	-2.6	3.6	14.0	25.1	29.7	29.7	27.7	20.1	9.4	-0.4	-6.3		
		MCWB	-2.7	-3.8	0.6	7.4	13.1	17.8	18.6	18.1	13.1	5.9	-1.1	-7.0		
	2%	DB	-9.0	-8.6	-1.3	10.1	21.4	27.4	27.3	24.7	17.5	5.4	-4.8	-10.6		
		MCWB	-9.5	-9.3	-3.5	5.2	11.7	16.3	17.7	16.6	11.7	3.5	-5.4	-11.0		
	5%	DB	-13.6	-11.5	-5.2	7.1	18.6	25.1	25.4	22.5	14.8	3.2	-6.8	-13.0		
		MCWB	-14.0	-12.0	-6.6	3.0	10.3	15.0	16.7	15.4	10.3	1.8	-7.3	-13.4		
	10%	DB	-16.2	-13.7	-8.6	4.5	15.9	23.0	23.5	20.1	12.5	1.6	-8.9	-15.3		
		MCWB	-16.6	-14.2	-9.7	1.1	8.8	14.3	15.9	14.5	9.2	0.5	-9.3	-15.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.7	-3.9	0.8	7.5	13.9	18.7	20.2	18.9	13.8	6.3	-1.1	-7.0		
		MCDB	-1.5	-2.7	3.4	13.8	24.1	28.2	27.2	25.6	18.8	8.7	-0.3	-6.5		
	2%	WB	-9.4	-9.2	-3.4	5.5	12.0	17.0	18.6	17.5	12.1	3.6	-5.3	-10.9		
		MCDB	-9.0	-8.7	-1.5	10.0	20.5	25.3	25.6	23.4	16.5	5.2	-4.9	-10.6		
	5%	WB	-13.9	-12.0	-6.8	3.2	10.7	16.0	17.5	16.1	10.7	1.9	-7.3	-13.3		
		MCDB	-13.7	-11.5	-5.3	6.8	18.2	23.5	23.8	21.4	14.2	3.1	-6.8	-13.0		
	10%	WB	-16.6	-14.1	-9.8	1.2	9.1	14.9	16.5	14.8	9.3	0.6	-9.3	-15.6		
		MCDB	-16.3	-13.6	-8.7	4.3	15.6	21.8	22.2	19.6	12.1	1.5	-8.9	-15.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	8.3	11.9	12.7	11.2	11.0	10.6	9.6	7.9	5.5	6.9	7.2		
		MCDBR	8.8	9.4	14.1	14.5	14.7	13.6	13.7	13.5	12.7	6.8	7.1	8.8		
	5% WB	MCWBR	8.5	9.0	12.1	10.1	7.7	6.1	6.8	7.0	7.6	5.2	6.8	8.6		
		MCWBR	8.9	9.4	13.9	13.8	14.3	12.5	12.1	11.6	6.4	7.1	8.7	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.153	0.220	0.252	0.305	0.339	0.341	0.366	0.341	0.301	0.242	0.161	N/A		
	taud		1.935	2.184	2.245	2.176	2.336	2.450	2.400	2.482	2.541	2.318	1.938	N/A		
	Ebn at Noon		238	649	817	846	856	865	825	813	769	612	194	0		
	Edh at Noon		11	45	75	107	103	95	97	81	59	39	10	0		
(44) All-Sky Solar Radiation	RadAvg		0.07	0.68	2.46	4.79	5.84	6.15	5.11	3.60	2.03	0.68	0.13	0.00		
	RadStd		0.01	0.04	0.09	0.17	0.55	0.49	0.39	0.32	0.20	0.07	0.01	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	+1.06	+2.08	+2.27	N/A	N/A	N/A	-437	-423	N/A	N/A

Nomenclature: See separate page