

PARRY SOUND, ON, Canada

WMO: 711720

Lat: 45.344N

Lon: 80.042W

Elev: 578

StdP: 14.39

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -13.0	(c) -6.9	(d) -20.5	(e) 1.8	(f) -12.4	(g) -13.8	(h) 2.7	(i) -5.9	(j) 24.1	(k) 26.9	(l) 22.1	(m) 25.8	(n) 2.8	(o) 330	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	82.8	70.1	80.3	69.0	78.0	67.6	73.2	79.0	71.5	76.8	70.0	75.3	8.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.4	118.4	75.9	69.7	111.6	74.6	68.1	105.4	73.6	37.2	79.0	35.7	76.6	34.4	75.2	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	18.0	15.4	-21.9	87.4	7.6	2.5	-27.4	89.2	-31.9	90.6	-36.1	92.0	-41.7	93.8
			-22.3	75.5	7.3	2.3	-27.6	77.2	-31.8	78.5	-35.9	79.8	-41.2	81.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	16.8	17.5	27.6	41.0	53.8	63.0	68.6	67.4	60.6	48.5	36.4	25.1	
	DBStd	20.40	13.31	11.24	11.83	8.35	8.12	6.13	4.76	4.83	7.03	8.26	9.03	10.44	
	HDD50	4294	1028	909	697	289	49	1	0	0	6	131	413	771	
	HDD65	7992	1493	1329	1158	719	360	106	20	31	167	514	859	1236	
	CDD50	2113	0	0	4	20	168	391	578	540	323	84	5	0	
	CDD65	337	0	0	0	0	14	47	133	106	35	2	0	0	
	CDH74	1726	0	0	0	5	103	273	696	488	155	6	0	0	
	CDH80	250	0	0	0	0	17	47	102	70	14	0	0	0	
Wind	WSAvg	6.1	5.7	6.0	5.9	6.2	5.6	5.5	6.0	5.5	5.7	7.1	6.7	7.3	
Precipitation	PrecAvg	39.0	2.9	2.1	2.2	3.2	3.5	3.3	3.3	3.7	3.9	4.3	3.5	3.0	
	PrecMax	46.1	4.7	4.4	5.5	5.8	6.1	5.6	5.4	6.6	7.6	7.0	5.4	6.1	
	PrecMin	31.9	1.5	0.8	0.3	1.2	1.3	1.1	1.5	1.9	1.5	1.9	1.6	1.3	
	PrecStd	3.8	0.8	0.9	1.1	1.1	1.2	1.1	1.1	1.1	1.4	1.4	1.0	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.3	43.9	62.8	72.5	82.1	84.6	86.2	85.4	81.9	74.0	61.9	49.5	
		MCWB	46.2	42.2	54.4	56.4	67.2	70.9	72.4	71.2	70.2	63.7	54.4	47.2	
	2%	DB	40.6	39.1	52.5	64.3	76.6	80.6	82.6	81.8	78.2	69.1	55.7	44.0	
		MCWB	39.4	36.7	44.6	52.6	64.0	69.2	70.5	69.8	68.1	62.2	51.0	41.7	
	5%	DB	37.5	35.7	47.2	59.2	71.9	76.9	80.3	78.9	75.1	65.0	52.2	40.9	
		MCWB	36.2	33.4	42.0	49.7	60.3	65.9	69.2	68.6	66.4	59.6	47.9	39.0	
	10%	DB	34.5	33.5	42.8	54.9	67.4	73.8	77.9	76.5	72.0	61.2	48.9	38.2	
		MCWB	32.9	31.5	38.4	46.7	57.9	63.9	67.8	67.4	65.3	56.3	46.0	36.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.7	42.5	55.6	59.3	69.2	74.9	76.2	75.3	72.5	67.6	55.7	47.6
			MCDB	47.1	43.2	61.3	67.9	77.3	81.8	82.0	80.7	78.8	71.8	58.9	49.1
2%		WB	39.9	37.2	47.0	55.4	66.4	71.8	73.4	72.2	70.6	63.5	51.6	42.3	
		MCDB	40.4	38.4	50.5	62.0	73.5	77.2	78.8	77.7	75.4	66.9	55.1	43.7	
5%		WB	36.3	33.9	42.5	51.4	63.3	68.6	71.6	70.8	68.7	60.2	48.6	39.2	
		MCDB	37.2	35.2	46.2	57.7	69.0	73.8	76.8	76.0	73.2	64.7	51.4	40.8	
10%		WB	33.3	31.8	39.0	47.5	59.5	66.3	70.0	69.2	66.3	56.8	46.1	36.5	
		MCDB	34.4	33.4	42.3	53.6	65.8	71.5	75.7	74.3	70.9	60.6	48.7	38.1	
Mean Daily Temperature Range	5% DB	MDBR	16.3	17.3	17.0	16.9	17.8	16.3	15.1	15.3	16.1	13.6	12.4	12.5	
		MCDBR	12.9	15.4	19.9	25.3	22.9	20.7	18.4	18.0	19.0	18.5	17.2	11.3	
		MCWBR	12.6	14.0	14.0	15.1	11.4	10.2	9.0	8.9	10.1	11.6	13.1	10.7	
	5% WB	MCDBR	12.2	14.1	18.1	21.7	19.1	16.8	14.8	14.9	15.6	16.3	15.1	11.1	
		MCWBR	12.3	13.5	13.9	15.3	11.6	10.2	8.7	8.9	10.0	12.2	13.1	10.9	
Clear-Sky Solar Irradiance	taub	0.284	0.290	0.315	0.347	0.372	0.401	0.405	0.399	0.367	0.347	0.313	0.282		
	taud	2.385	2.338	2.374	2.386	2.392	2.328	2.345	2.353	2.431	2.463	2.502	2.454		
	Ebn at Noon	263	284	292	290	285	275	272	270	270	260	252	253		
	Edh at Noon	23	30	33	36	37	39	38	36	31	26	21	20		
All-Sky Solar Radiation	RadAvg	390	673	1127	1450	1712	1871	1894	1618	1249	734	409	283		
	RadStd	48	75	114	128	164	141	110	90	120	82	58	31		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page