

PARRY SOUND, ON, Canada

WMO: 711720

Lat: 45.344N

Lon: 80.042W

Elev: 176

StdP: 99.22

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.0	-21.6	-29.2	0.3	-24.6	-25.4	0.4	-21.1	10.8	-2.9	9.9	-3.4	1.3	330	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	28.2	21.1	26.9	20.6	25.6	19.8	22.9	26.1	21.9	24.9	21.1	24.1	3.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	16.9	24.4	21.0	15.9	23.7	20.0	15.1	23.1	68.7	26.1	65.1	24.8	62.2	24.0	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.4	8.0	6.9	-30.0	30.8	4.2	1.4	-33.0	31.8	-35.5	32.6	-37.8	33.3	-40.9	34.3
			-30.2	24.2	4.0	1.3	-33.1	25.1	-35.5	25.8	-37.7	26.6	-40.7	27.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-8.4	-8.0	-2.4	5.0	12.1	17.2	20.4	19.7	15.9	9.2	2.4	-3.8
	DBStd	11.33	7.39	6.24	6.57	4.64	4.51	3.41	2.65	2.68	3.91	4.59	5.02	5.80
	HDD10.0	2386	571	505	387	161	27	1	0	0	3	73	229	428
	HDD18.3	4440	829	738	643	399	200	59	11	17	93	286	477	687
	CDD10.0	1174	0	0	2	11	93	217	321	300	179	47	3	0
	CDD18.3	187	0	0	0	0	8	26	74	59	19	1	0	0
	CDH23.3	959	0	0	0	3	57	152	387	271	86	3	0	0
	CDH26.7	139	0	0	0	0	9	26	57	39	8	0	0	0
Wind	WSAvg	2.7	2.6	2.7	2.6	2.8	2.5	2.5	2.7	2.4	2.6	3.2	3.0	3.3
Precipitation	PrecAvg	991	73	54	57	82	90	84	84	94	100	109	88	77
	PrecMax	1171	120	112	139	147	156	141	137	168	192	177	138	155
	PrecMin	811	38	20	8	31	33	29	38	47	38	48	41	33
	PrecStd	97	21	24	28	29	31	28	28	28	35	35	25	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	6.6	17.1	22.5	27.8	29.2	30.1	29.7	27.7	23.3	16.6	9.7
		MCWB	7.9	5.6	12.5	13.5	19.6	21.6	22.4	21.8	21.2	17.6	12.4	8.5
	2%	DB	4.8	4.0	11.4	18.0	24.8	27.0	28.1	27.7	25.7	20.6	13.2	6.7
		MCWB	4.1	2.6	7.0	11.5	17.8	20.6	21.4	21.0	20.0	16.8	10.5	5.4
	5%	DB	3.0	2.1	8.4	15.1	22.2	24.9	26.9	26.1	24.0	18.3	11.2	4.9
		MCWB	2.3	0.8	5.6	9.8	15.7	18.8	20.7	20.3	19.1	15.3	8.9	3.9
	10%	DB	1.4	0.8	6.0	12.7	19.7	23.2	25.5	24.7	22.2	16.2	9.4	3.5
		MCWB	0.5	-0.3	3.6	8.2	14.4	17.7	19.9	19.6	18.5	13.5	7.8	2.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	5.8	13.1	15.2	20.7	23.8	24.6	24.0	22.5	19.8	13.2	8.7
		MCDB	8.4	6.2	16.3	20.0	25.2	27.7	27.8	27.0	26.0	22.1	15.0	9.5
	2%	WB	4.4	2.9	8.3	13.0	19.1	22.1	23.0	22.3	21.5	17.5	10.9	5.7
		MCDB	4.7	3.5	10.3	16.6	23.1	25.1	26.0	25.4	24.1	19.4	12.8	6.5
	5%	WB	2.4	1.0	5.8	10.8	17.4	20.3	22.0	21.5	20.4	15.7	9.2	4.0
		MCDB	2.9	1.8	7.9	14.3	20.6	23.2	24.9	24.4	22.9	18.1	10.8	4.9
	10%	WB	0.7	-0.1	3.9	8.6	15.3	19.1	21.1	20.7	19.1	13.8	7.8	2.5
		MCDB	1.3	0.8	5.7	12.0	18.8	21.9	24.3	23.5	21.6	15.9	9.3	3.4
Mean Daily Temperature Range	5% DB	MDBR	9.0	9.6	9.5	9.4	9.9	9.1	8.4	8.5	8.9	7.5	6.9	7.0
		MCDBR	7.2	8.5	11.1	14.0	12.7	11.5	10.2	10.0	10.5	10.3	9.6	6.3
		MCWBR	7.0	7.8	7.8	8.4	6.4	5.7	5.0	4.9	5.6	6.5	7.3	6.0
	5% WB	MCDBR	6.8	7.8	10.1	12.0	10.6	9.3	8.2	8.3	8.7	9.1	8.4	6.2
		MCWBR	6.8	7.5	7.7	8.5	6.4	5.7	4.9	4.9	5.5	6.8	7.3	6.0
Clear-Sky Solar Irradiance	taub	0.284	0.290	0.315	0.347	0.372	0.401	0.405	0.399	0.367	0.347	0.313	0.282	
	taud	2.385	2.338	2.374	2.386	2.392	2.328	2.345	2.353	2.431	2.463	2.502	2.454	
	Ebn at Noon	830	895	919	913	897	868	859	850	851	819	794	799	
	Edh at Noon	73	93	104	112	116	124	121	115	98	83	67	62	
All-Sky Solar Radiation	RadAvg	1.23	2.12	3.55	4.57	5.40	5.90	5.97	5.10	3.94	2.31	1.29	0.89	
	RadStd	0.15	0.24	0.36	0.40	0.52	0.44	0.35	0.28	0.38	0.26	0.18	0.10	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page