

CAPE KIGLAPAIT, NL, Canada

WMO: 711770

Lat: 57.136N

Lon: 61.476W

Elev: 834

StdP: 91.70

Time Zone: -4.00 (NAA)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-31.2	-28.9	N/A	N/A	N/A	N/A	N/A	N/A	33.7	-22.0	32.6	-22.0	9.8	320	1.196

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	18.3	N/A	16.0	N/A	14.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.2	23.6	20.5	DB	-33.8	22.1	2.4	1.7	-35.5	23.4	-36.9	24.4	-38.2	25.4	-39.9	26.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.9	-18.1	-19.3	-16.5	-9.8	-2.9	3.2	7.4	7.7	2.1	-3.3	-8.7	-13.8	
	DBStd	10.65	6.32	6.15	6.21	5.12	4.83	4.99	4.34	4.22	4.00	3.90	4.14	6.15	
	HDD10.0	5876	872	821	822	593	401	213	107	97	240	412	561	737	
	HDD18.3	8854	1130	1054	1081	843	658	453	341	329	488	671	811	996	
	CDD10.0	63	0	0	0	0	1	9	24	26	2	0	0	0	
	CDD18.3	1	0	0	0	0	0	1	1	0	0	0	0	0	
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	8.6	9.8	10.0	9.3	9.5	8.4	7.7	7.1	6.9	7.8	8.6	8.4	9.2	
Precipitation	PrecAvg	964	86	75	65	61	54	72	113	90	89	95	83	81	
	PrecMax	1229	183	152	148	132	132	125	195	174	187	199	200	177	
	PrecMin	721	7	11	11	21	5	29	50	45	33	48	22	22	
	PrecStd	115	35	37	35	27	28	24	35	28	35	30	34	42	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.1	-0.3	0.7	5.3	14.9	20.8	21.1	20.5	15.2	9.7	3.6	0.5	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	-4.3	-2.2	-3.5	2.6	10.4	16.7	17.8	18.1	12.5	7.3	0.8	-1.5	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-6.1	-7.3	-5.6	-0.1	7.5	13.5	15.5	16.1	10.5	4.6	-1.2	-3.4	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-8.6	-11.3	-7.7	-2.1	4.7	10.6	13.7	14.1	8.4	2.1	-3.0	-5.5	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.3	5.6	5.4	5.6	5.5	5.5	5.4	5.0	3.9	4.0	5.0	
		MCDBR	6.5	5.3	8.2	7.2	9.0	9.0	7.1	8.0	8.1	7.3	6.3	5.3	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.203	0.221	0.246	0.285	0.317	0.317	0.327	0.314	0.291	0.263	0.221	0.203	
	taud		2.252	2.291	2.236	2.157	2.230	2.456	2.514	2.560	2.593	2.580	2.360	2.160	
	Ebn at Noon		738	873	927	931	918	924	907	899	877	821	707	608	
	Edh at Noon		46	69	97	125	126	102	95	85	70	54	41	37	
All-Sky Solar Radiation	RadAvg		0.57	1.56	3.08	4.70	5.71	5.30	4.59	3.96	2.82	1.43	0.63	0.34	
	RadStd		0.09	0.19	0.32	0.36	0.56	0.55	0.42	0.39	0.20	0.11	0.05	0.04	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page