

TUKIALIK BAY, NL, Canada

WMO: 711790

Lat: 54.716N

Lon: 58.358W

Elev: 2240

StdP: 13.54

Time Zone: -4.00 (NAA)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-23.9	-19.8	N/A	N/A	N/A	N/A	N/A	N/A	74.2	21.7	69.1	16.1	23.9	250	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.1	69.6	N/A	65.1	N/A	61.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	17.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 63.2	55.1	48.7	DB	-26.5	75.4	6.3	3.7	-31.0	78.1	-34.7	80.3	-38.2	82.4	-42.8	85.1	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.5	2.6	1.1	8.9	19.7	30.8	40.8	49.1	49.4	40.9	31.1	19.7	10.2	(6)	
	DBStd	19.33	12.19	12.99	12.43	8.90	7.55	9.99	8.35	7.52	7.38	8.26	8.10	11.13	(7)	
	HDD50	9181	1470	1369	1275	909	599	311	121	105	291	590	908	1233	(8)	
	HDD65	14425	1935	1789	1740	1359	1061	728	496	484	725	1052	1358	1698	(9)	
	CDD50	239	0	0	0	0	2	37	93	87	17	3	0	0	(10)	
	CDD65	7	0	0	0	0	0	3	3	1	0	0	0	0	(11)	
	CDH74	17	0	0	0	0	0	8	7	2	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	21.7	25.9	25.3	25.0	24.7	21.0	18.0	17.5	17.6	19.3	20.8	21.5	23.5	(14)	
(15) Precipitation	PrecAvg	38.0	3.4	3.2	3.0	2.6	2.6	2.8	3.7	3.8	3.1	3.4	3.4	3.2	(15)	
	PrecMax	46.4	5.9	5.7	5.0	4.7	5.1	5.8	5.2	6.5	5.3	5.7	6.1	5.5	(16)	
	PrecMin	33.9	1.1	0.6	1.0	1.4	0.6	1.4	2.4	2.0	1.5	1.6	0.9	1.4	(17)	
	PrecStd	2.9	1.1	1.1	0.9	0.8	1.0	0.9	0.8	1.0	1.0	1.1	1.1	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	34.7	33.3	45.0	59.3	74.7	74.6	72.5	64.9	57.5	41.8	36.0	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	28.4	32.1	30.9	38.7	53.2	67.7	69.5	67.7	60.3	52.6	37.5	31.0	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	25.1	26.7	29.0	34.5	47.3	61.0	64.9	64.0	56.7	47.6	32.6	28.2	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
	10%	DB	20.8	20.7	26.6	31.6	42.0	56.4	61.4	61.1	52.8	43.6	30.2	25.5	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	11.4	10.4	10.0	9.0	11.8	12.1	12.1	10.5	7.2	8.6	9.5	(35)	
		MCDBR	13.7	14.2	9.2	12.7	17.3	18.1	15.9	15.8	15.8	11.3	12.2	8.8	(36)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.225	0.241	0.264	0.311	0.334	0.340	0.356	0.337	0.310	0.284	0.242	0.227	(40)	
	taud		2.279	2.286	2.223	2.134	2.280	2.427	2.438	2.493	2.542	2.570	2.436	2.234	(41)	
	Ebn at Noon		241	276	292	289	288	288	280	280	275	260	235	209	(42)	
	Edh at Noon		17	24	33	42	39	34	33	30	24	19	15	14	(43)	
(44) All-Sky Solar Radiation	RadAvg		244	534	960	1420	1650	1591	1493	1261	932	489	245	163	(44)	
	RadStd		38	88	139	114	203	158	104	103	73	33	21	20	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page