

WRECKHOUSE, NL, Canada

WMO: 711800

Lat: 47.7136N

Lon: 59.3062W

Elev: 104

StdP: 14.64

Time Zone: -3.50 (NAF)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.8	11.6	1.6	6.0	9.3	5.1	7.2	12.1	61.7	31.4	55.5	33.0	19.7	280	0.804

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.4	74.5	67.2	72.1	66.0	70.2	65.0	69.1	73.0	67.5	71.1	66.1	69.5	13.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.6	101.7	71.6	66.1	96.4	70.2	64.6	91.5	68.8	33.3	73.2	32.1	71.2	30.9	69.5	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 50.1	42.2	36.1	DB	4.9	80.3	4.7	2.5	1.5	82.1	-1.3	83.6	-3.9	85.0	-7.4	86.8	(4)
(5)			WB	3.2	72.3	4.6	1.0	-0.1	73.0	-2.8	73.6	-5.4	74.1	-8.8	74.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.6	25.6	24.2	27.8	36.2	44.7	52.7	61.7	62.9	55.6	47.1	39.5	31.3
	DBStd	14.64	6.96	7.20	7.14	6.43	6.17	6.23	4.94	4.16	5.78	6.00	6.83	6.80
	HDD50	3860	758	723	687	416	188	39	0	0	16	130	322	581
	HDD65	8247	1223	1143	1152	864	629	371	126	89	285	555	764	1046
	CDD50	1144	0	0	0	2	25	121	363	401	184	40	8	0
	CDD65	54	0	0	0	0	0	2	24	25	3	0	0	0
	CDH74	89	0	0	0	0	0	7	50	32	0	0	0	0
	CDH80	4	0	0	0	0	0	1	2	1	0	0	0	0
Wind	WSAvg	15.4	20.4	19.9	17.7	16.0	12.6	12.1	10.7	10.6	12.7	15.1	17.4	20.0
Precipitation	PrecAvg	53.1	4.8	3.7	3.5	3.6	3.5	3.5	4.2	4.1	4.7	5.2	5.1	5.7
	PrecMax	68.7	7.2	8.2	6.9	6.5	6.0	6.2	7.9	7.6	9.6	8.9	7.9	14.1
	PrecMin	37.4	1.4	1.5	1.1	0.7	0.6	1.3	1.0	1.6	1.9	2.1	2.3	2.6
	PrecStd	8.3	1.7	1.4	1.7	1.6	1.5	1.4	1.5	1.6	1.8	1.9	1.6	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.1	46.2	48.0	59.3	67.1	74.2	78.3	77.7	72.2	66.3	59.9	53.0
		MCWB	49.3	45.2	45.7	51.2	58.4	63.6	69.2	69.4	66.6	61.4	57.9	51.0
	2%	DB	43.4	41.1	43.9	53.9	62.3	69.4	75.0	74.3	69.1	62.2	56.7	48.3
		MCWB	41.7	38.5	41.2	48.7	52.8	61.6	67.6	67.5	64.7	58.3	54.5	46.5
	5%	DB	38.5	37.3	40.7	49.8	58.8	66.3	72.5	72.0	67.0	59.4	54.0	44.8
		MCWB	36.9	35.4	37.5	45.8	51.8	59.6	66.0	66.5	63.4	56.2	52.1	42.7
	10%	DB	35.1	33.8	37.4	46.3	55.5	63.5	70.2	70.3	65.0	56.9	50.5	41.1
		MCWB	33.6	32.3	34.6	42.3	49.6	57.6	64.7	65.7	61.7	53.9	48.4	39.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	45.6	45.6	53.7	59.9	66.9	71.5	71.0	68.3	63.7	58.4	51.4
		MCDB	51.6	46.1	47.0	55.8	65.0	71.5	77.1	75.5	70.8	65.5	60.1	52.7
	2%	WB	42.3	39.6	41.7	48.9	55.7	63.5	69.2	69.3	65.6	59.0	55.0	46.6
		MCDB	43.5	40.6	43.2	51.7	59.3	67.3	73.6	72.8	68.4	61.0	56.4	48.3
	5%	WB	37.1	35.4	37.5	45.4	52.2	60.9	67.5	67.9	63.9	56.3	52.2	42.7
		MCDB	38.5	36.7	39.7	48.5	56.8	65.7	71.4	71.3	66.4	58.7	54.0	44.4
	10%	WB	33.8	32.4	34.7	42.1	49.2	58.2	65.9	66.6	61.8	53.5	48.5	39.2
		MCDB	34.9	33.6	36.8	45.4	54.2	62.8	69.5	69.8	64.3	56.1	50.1	40.9
Mean Daily Temperature Range	5% DB	MDBR	9.5	10.3	11.2	12.1	14.1	14.0	12.8	12.4	12.3	11.0	10.0	8.8
		MCDBR	15.2	15.4	14.9	17.5	19.1	18.2	15.8	14.2	12.9	13.9	14.3	14.2
		MCWBR	15.1	15.0	13.2	13.8	12.6	12.3	10.0	9.9	10.0	12.6	14.4	14.1
	5% WB	MCDBR	15.1	15.6	14.9	16.7	16.9	16.1	12.6	12.5	12.2	13.6	14.6	14.4
		MCWBR	15.2	15.5	13.9	14.3	12.8	11.7	8.6	9.4	10.2	13.0	14.8	14.4
Clear-Sky Solar Irradiance	taub	0.307	0.302	0.331	0.353	0.364	0.386	0.414	0.396	0.367	0.351	0.321	0.304	
	taud	2.352	2.400	2.342	2.392	2.438	2.397	2.361	2.415	2.473	2.453	2.460	2.381	
	Ebn at Noon	242	274	281	285	285	279	268	269	267	252	237	228	
	Edh at Noon	23	27	33	35	35	36	37	34	29	25	21	20	
All-Sky Solar Radiation	RadAvg	257	497	939	1317	1633	1672	1596	1455	1118	686	342	203	
	RadStd	24	55	99	106	134	182	130	92	75	45	40	22	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.52	N/A	N/A	N/A	N/A	

Nomenclature: See separate page