

POINTE CLAVEAU, QC, Canada

WMO: 711890

Lat: 48.261N

Lon: 70.115W

Elev: 13

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -13.7	(c) -9.7	(d) -22.6	(e) 1.6	(f) -12.7	(g) -18.5	(h) 2.0	(i) -8.9	(j) 46.8	(k) -4.3	(l) 43.1	(m) -0.7	(n) 19.0	(o) 280	(p) 0.711

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	79.8	65.4	76.4	64.0	73.5	63.0	68.4	74.9	66.6	72.5	65.0	70.5	10.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	96.5	70.8	64.4	90.6	69.4	62.7	85.4	67.9	32.6	75.6	31.3	72.3	30.0	70.5	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
37.1	32.6	28.4	-18.0	87.2	4.4	3.4	-21.1	89.6	-23.7	91.5	-26.1	93.4	-29.3	95.9
			-18.1	72.6	4.3	2.7	-21.2	74.6	-23.7	76.2	-26.1	77.7	-29.2	79.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.8	9.9	12.5	24.3	37.4	49.7	59.9	65.4	63.9	56.4	44.6	33.0	19.3
	DBStd	20.69	12.04	11.04	10.32	6.23	6.36	5.98	4.42	4.63	5.94	6.09	7.44	10.31
	HDD50	5224	1243	1051	796	380	85	3	0	0	12	189	512	953
	HDD65	9321	1708	1471	1261	829	476	173	50	76	266	632	961	1418
	CDD50	1511	0	0	0	1	75	301	477	432	202	22	1	0
	CDD65	133	0	0	0	0	1	21	62	42	7	0	0	0
	CDH74	581	0	0	0	0	31	129	240	150	31	0	0	0
	CDH80	92	0	0	0	0	6	22	39	21	4	0	0	0
Wind	WSAvg	11.5	15.2	14.2	13.5	12.0	9.7	9.4	8.5	8.6	9.2	11.2	12.8	14.4
Precipitation	PrecAvg	41.3	2.7	2.4	2.3	2.6	3.4	4.1	4.8	4.2	4.3	4.0	3.2	3.3
	PrecMax	47.5	5.0	4.9	4.3	4.4	6.3	6.3	10.9	8.9	9.3	6.6	5.4	6.1
	PrecMin	35.2	0.6	1.3	0.7	1.0	1.5	1.9	1.8	1.8	2.3	1.7	1.4	1.6
	PrecStd	3.5	1.0	1.0	1.0	0.9	1.2	1.2	1.9	1.6	1.3	1.3	0.9	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.9	39.4	47.7	59.8	78.2	82.9	84.5	82.7	78.1	66.3	56.8	41.7
		MCWB	37.7	36.5	39.6	46.4	59.7	65.1	68.6	67.0	66.3	57.5	52.2	39.0
	2%	DB	35.1	35.1	42.9	53.4	69.7	77.7	79.7	78.0	72.0	59.8	48.3	37.2
		MCWB	33.7	32.8	36.8	43.0	54.4	62.7	66.3	65.9	63.3	53.5	44.7	35.1
	5%	DB	31.7	32.4	39.6	48.8	64.4	73.5	76.3	74.6	68.2	56.1	44.8	35.0
		MCWB	30.1	30.6	35.1	40.8	53.2	60.9	64.7	64.0	60.7	51.1	41.9	33.4
	10%	DB	27.2	29.7	36.9	45.4	60.1	69.8	73.3	71.7	65.1	52.7	42.1	32.9
		MCWB	25.6	28.0	33.2	39.0	50.6	59.2	63.5	63.0	59.1	48.4	39.2	31.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.6	37.6	42.5	47.8	63.0	68.9	70.8	70.6	68.3	58.8	52.9	39.1
		MCDB	39.3	39.0	46.8	55.9	73.7	77.3	77.5	77.0	73.8	63.8	56.1	40.8
	2%	WB	33.8	33.2	37.9	44.3	58.0	65.8	68.6	68.0	64.7	55.0	45.4	35.7
		MCDB	35.0	34.7	41.3	51.0	65.3	72.4	74.9	74.8	70.4	58.7	47.4	37.0
	5%	WB	29.7	30.6	35.8	42.0	54.4	63.6	66.9	66.2	62.2	51.6	42.2	33.6
		MCDB	31.3	32.2	38.9	47.0	62.4	69.9	72.7	71.4	66.6	54.8	44.3	34.7
	10%	WB	25.3	27.8	33.7	40.1	51.5	61.3	65.1	64.5	59.8	48.9	39.4	31.5
		MCDB	26.7	29.5	36.8	44.2	58.3	67.8	70.8	69.4	63.8	52.0	41.8	32.9
Mean Daily Temperature Range	5% DB	MDBR	13.3	14.7	14.0	12.8	16.2	15.7	14.4	13.8	13.0	9.9	8.3	10.0
		MCDBR	15.5	13.4	15.4	19.6	25.1	22.9	19.6	18.7	18.2	16.0	12.3	10.9
		MCWBR	15.8	12.5	11.1	11.7	12.5	10.3	8.5	9.0	10.5	10.9	10.2	10.3
	5% WB	MCDBR	15.7	13.1	13.5	16.9	22.7	18.6	16.4	15.9	16.9	14.5	11.7	10.9
		MCWBR	15.5	12.1	10.4	11.3	12.9	10.6	8.9	8.8	11.0	10.8	10.6	10.5
Clear-Sky Solar Irradiance	taub	0.267	0.285	0.321	0.384	0.373	0.391	0.418	0.396	0.377	0.337	0.305	0.274	
	taud	2.289	2.239	2.190	2.175	2.358	2.358	2.301	2.365	2.404	2.495	2.441	2.315	
	Ebn at Noon	255	276	282	274	282	277	266	268	262	257	241	236	
	Edh at Noon	23	30	38	43	37	38	39	36	31	24	20	20	
All-Sky Solar Radiation	RadAvg	413	712	1094	1407	1630	1741	1678	1435	1104	639	349	275	
	RadStd	48	88	86	114	158	120	166	95	80	59	36	28	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page