

POINTE CLAVEAU, QC, Canada

WMO: 711890

Lat: 48.261N

Lon: 70.115W

Elev: 4

StdP: 101.28

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.4	-23.2	-30.3	0.2	-24.8	-28.0	0.3	-22.7	20.9	-20.1	19.2	-18.2	8.5	280	0.711

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	26.6	18.6	24.7	17.8	23.0	17.2	20.2	23.8	19.2	22.5	18.3	21.4	4.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	21.5	18.0	12.9	20.8	17.1	12.2	19.9	58.0	24.2	54.8	22.4	51.9	21.4	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.6	14.6	12.7	DB	-27.8	30.6	2.4	1.9	-29.5	32.0	-30.9	33.1	-32.3	34.1	-34.1	35.5	(4)
(5)			WB	-27.9	22.6	2.4	1.5	-29.6	23.7	-30.9	24.5	-32.3	25.4	-34.0	26.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.3	-12.3	-10.8	-4.3	3.0	9.8	15.5	18.5	17.7	13.5	7.0	0.5	-7.1
	DBStd	11.49	6.69	6.13	5.74	3.46	3.54	3.32	2.46	2.57	3.30	3.38	4.14	5.73
	HDD10.0	2902	691	584	442	211	47	2	0	0	7	105	284	529
	HDD18.3	5178	949	817	701	461	264	96	28	42	148	351	534	788
	CDD10.0	839	0	0	0	1	42	167	265	240	112	12	1	0
	CDD18.3	74	0	0	0	0	1	12	34	23	4	0	0	0
	CDH23.3	323	0	0	0	0	17	72	133	83	17	0	0	0
	CDH26.7	51	0	0	0	0	3	12	22	12	2	0	0	0
	Wind	WSAvg	5.2	6.8	6.4	6.0	5.4	4.4	4.2	3.8	4.1	5.0	5.7	6.4
(15) Precipitation	PrecAvg	1050	69	61	59	65	87	103	121	107	110	102	81	85
	PrecMax	1206	126	125	110	112	159	159	276	226	236	167	138	156
	PrecMin	894	15	32	19	26	37	48	46	46	59	44	35	40
	PrecStd	90	25	25	25	24	31	30	47	40	33	33	22	23
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.4	4.1	8.7	15.4	25.7	28.3	29.2	28.2	25.6	19.1	13.8	5.4
		MCWB	3.2	2.5	4.2	8.0	15.4	18.4	20.3	19.4	19.1	14.2	11.2	3.9
	2%	DB	1.7	1.7	6.0	11.9	21.0	25.4	26.5	25.6	22.2	15.5	9.0	2.9
		MCWB	0.9	0.5	2.6	6.1	12.5	17.1	19.1	18.8	17.4	11.9	7.1	1.7
	5%	DB	-0.2	0.2	4.2	9.3	18.0	23.0	24.6	23.7	20.1	13.4	7.1	1.7
		MCWB	-1.1	-0.8	1.7	4.9	11.8	16.1	18.2	17.8	15.9	10.6	5.5	0.8
	10%	DB	-2.6	-1.3	2.7	7.5	15.6	21.0	22.9	22.0	18.4	11.5	5.6	0.5
		MCWB	-3.6	-2.2	0.7	3.9	10.3	15.1	17.5	17.2	15.1	9.1	4.0	-0.3
	0.4%	WB	3.7	3.1	5.8	8.8	17.2	20.5	21.6	21.4	20.2	14.9	11.6	3.9
		MCDB	4.1	3.9	8.2	13.3	23.2	25.2	25.3	25.0	23.2	17.7	13.4	4.9
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	1.0	0.7	3.3	6.8	14.4	18.8	20.3	20.0	18.2	12.8	7.5	2.1
		MCDB	1.7	1.5	5.2	10.5	18.5	22.5	23.8	23.8	21.3	14.9	8.6	2.8
	5%	WB	-1.3	-0.8	2.1	5.5	12.4	17.5	19.4	19.0	16.8	10.9	5.6	0.9
		MCDB	-0.4	0.1	3.8	8.4	16.9	21.0	22.6	21.9	19.2	12.7	6.8	1.5
	10%	WB	-3.7	-2.4	1.0	4.5	10.8	16.3	18.4	18.1	15.4	9.4	4.1	-0.3
		MCDB	-2.9	-1.4	2.7	6.8	14.6	19.9	21.5	20.8	17.7	11.1	5.4	0.5
	5% DB	MDBR	7.4	8.2	7.8	7.1	9.0	8.7	8.0	7.7	7.2	5.5	4.6	5.5
		MCDBR	8.6	7.4	8.6	10.9	14.0	12.7	10.9	10.4	10.1	8.9	6.8	6.1
		MCWBR	8.8	7.0	6.1	6.5	6.9	5.7	4.7	5.0	5.8	6.1	5.6	5.7
		MCDBR	8.7	7.3	7.5	9.4	12.6	10.3	9.1	8.8	9.4	8.0	6.5	6.1
	5% WB	MCWBR	8.6	6.7	5.8	6.3	7.1	5.9	5.0	4.9	6.1	6.0	5.9	5.8
(40) Clear-Sky Solar Irradiance	taub		0.267	0.285	0.321	0.384	0.373	0.391	0.418	0.396	0.377	0.337	0.305	0.274
	taud		2.289	2.239	2.190	2.175	2.358	2.358	2.301	2.365	2.404	2.495	2.441	2.315
	Ebn at Noon		805	870	889	863	888	872	840	844	826	809	760	744
	Edh at Noon		72	96	120	136	118	119	124	112	98	76	64	63
	RadAvg		1.30	2.24	3.45	4.43	5.14	5.49	5.29	4.53	3.48	2.02	1.10	0.87
(45) All-Sky Solar Radiation	RadStd		0.15	0.28	0.27	0.36	0.50	0.38	0.52	0.30	0.25	0.19	0.11	0.09

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page