

POINTE DE L'ISLET, QC, Canada

WMO: 711900

Lat: 48.1356N

Lon: 69.7164W

Elev: 7

StdP: 101.24

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.6	-19.1	-26.0	0.4	-20.9	-23.8	0.4	-18.0	22.7	-16.0	21.0	-15.4	11.2	300	0.759

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	23.0	16.7	21.3	15.9	19.9	15.3	18.3	21.1	17.2	19.7	16.3	18.7	5.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	12.3	19.7	16.2	11.5	18.6	15.2	10.8	17.6	52.0	21.2	48.5	19.7	45.7	18.8	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
17.6	15.2	12.9	DB	-22.0	27.9	2.4	2.0	-23.7	29.3	-25.1	30.5	-26.5	31.6	-28.2	33.1	
			WB	-22.8	21.1	2.2	1.0	-24.4	21.8	-25.7	22.4	-26.9	23.0	-28.5	23.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.3	-9.1	-8.1	-3.4	2.7	8.9	13.8	16.0	15.6	12.0	6.8	1.1	-5.1
	DBStd	9.65	5.92	5.34	4.97	3.39	3.03	2.75	2.38	2.23	2.75	3.02	3.99	5.13
	HDD10.0	2651	592	508	414	219	58	3	0	0	11	108	268	469
	HDD18.3	5127	851	741	673	469	293	139	80	87	190	358	518	728
	CDD10.0	578	0	0	0	1	24	116	185	174	71	8	1	0
	CDD18.3	13	0	0	0	0	0	2	7	4	1	0	0	0
	CDH23.3	49	0	0	0	0	3	14	22	9	1	0	0	0
	CDH26.7	5	0	0	0	0	1	2	2	1	0	0	0	0
Wind	WSAvg	5.3	7.3	6.8	6.2	5.4	4.5	4.3	3.9	4.0	4.2	4.8	5.4	6.6
Precipitation	PrecAvg	1030	68	67	67	82	84	92	113	107	99	105	81	86
	PrecMax	1246	123	112	126	194	157	185	268	200	261	222	127	242
	PrecMin	805	5	36	31	14	30	36	53	48	51	33	44	26
	PrecStd	125	30	20	26	41	33	38	55	49	47	46	22	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.5	4.3	8.1	13.9	21.7	25.3	25.8	24.6	21.9	17.3	12.3	6.6
		MCWB	4.3	2.5	4.6	8.1	13.1	16.5	18.7	18.1	17.2	13.2	10.0	4.9
	2%	DB	2.9	2.2	5.4	10.2	17.8	21.8	23.2	22.1	19.3	14.2	9.0	4.1
		MCWB	2.0	1.0	2.9	5.6	11.3	14.6	17.2	16.9	15.4	11.2	6.8	2.7
	5%	DB	1.1	0.9	3.7	8.2	15.1	19.8	21.3	20.6	17.6	12.3	7.4	2.8
		MCWB	0.1	-0.1	1.5	4.5	10.2	14.0	16.2	16.0	14.1	9.8	5.7	1.6
	10%	DB	-0.8	-0.4	2.6	6.7	13.2	18.1	19.9	19.2	15.9	10.8	5.9	1.5
		MCWB	-1.9	-1.4	0.8	3.5	9.0	13.4	15.7	15.5	13.0	8.6	4.4	0.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	3.2	5.9	9.0	15.0	18.9	20.2	19.6	18.4	14.0	10.5	5.0
		MCDB	5.3	3.9	7.6	11.0	18.5	22.7	23.1	22.5	20.7	16.2	12.1	5.8
	2%	WB	2.1	1.2	3.4	6.5	12.4	16.7	18.6	17.9	16.1	11.7	7.2	3.0
		MCDB	2.8	1.9	4.8	9.2	15.5	19.5	21.4	20.3	18.4	13.7	8.4	3.9
	5%	WB	0.2	0.0	2.1	5.1	10.9	15.5	17.4	17.0	14.7	10.3	5.9	1.8
		MCDB	1.1	0.9	3.2	7.3	13.7	18.3	20.0	19.3	16.8	12.1	7.2	2.7
	10%	WB	-1.9	-1.5	1.0	4.1	9.5	14.2	16.4	16.1	13.5	8.9	4.5	0.6
		MCDB	-0.9	-0.4	2.3	5.9	12.1	17.0	18.8	18.5	15.4	10.6	5.9	1.4
Mean Daily Temperature Range	5% DB	MDBR	6.4	6.6	6.3	6.0	7.1	7.7	7.7	7.3	6.4	4.8	4.4	5.1
		MCDBR	8.1	6.4	7.0	8.8	11.3	10.7	10.0	9.3	8.9	7.5	6.3	5.9
		MCWBR	7.8	6.0	5.6	5.7	6.2	5.6	5.4	5.3	5.9	5.5	5.6	5.5
	5% WB	MCDBR	7.7	6.2	6.5	7.9	9.7	9.7	9.5	8.8	8.5	7.5	6.2	5.9
		MCWBR	7.6	6.0	5.7	5.8	6.4	6.4	6.3	6.0	6.4	6.0	5.7	5.6
Clear-Sky Solar Irradiance	taub	0.269	0.281	0.320	0.363	0.371	0.388	0.415	0.394	0.372	0.335	0.300	0.275	
	taud	2.318	2.279	2.229	2.265	2.344	2.360	2.360	2.308	2.371	2.422	2.501	2.456	2.342
	Ebn at Noon	808	880	892	886	891	875	843	847	832	813	770	749	
	Edh at Noon	71	93	116	124	120	119	123	111	96	76	63	62	
All-Sky Solar Radiation	RadAvg	1.29	2.22	3.40	4.42	5.12	5.48	5.39	4.63	3.57	2.09	1.14	0.87	
	RadStd	0.15	0.26	0.26	0.37	0.50	0.38	0.53	0.31	0.25	0.18	0.12	0.08	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page