

VICTORIA GONZALES, BC, Canada

WMO: 712000

Lat: 48.4133N

Lon: 123.3247W

Elev: 226

StdP: 14.58

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	27.4	30.9	12.8	10.6	31.7	18.6	14.2	34.5	35.5	45.1	30.4	45.2	10.4	30	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.6	76.0	62.1	72.0	60.5	68.9	59.2	63.4	73.1	61.8	69.7	60.4	66.9	6.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.8	77.4	65.4	58.5	73.8	64.2	57.4	71.0	62.8	28.9	73.7	27.7	69.8	26.8	67.1	73.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.1	23.2	20.3	DB	24.2	86.8	4.4	4.2	21.0	89.8	18.5	92.2	16.0	94.6	12.8	97.6	(4)
(5)			WB	21.1	66.9	4.5	2.2	17.9	68.5	15.2	69.8	12.7	71.0	9.4	72.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.0	42.1	42.8	45.6	49.5	54.2	57.9	60.8	61.1	58.4	51.7	45.7	41.7
	DBStd	8.20	4.84	4.39	4.11	3.97	4.14	4.05	3.73	3.56	3.78	3.44	4.49	4.75
	HDD50	1068	246	201	145	52	8	0	0	0	0	21	137	258
	HDD65	5148	710	620	601	465	336	223	143	133	203	413	579	722
	CDD50	1433	1	1	8	38	138	236	334	344	252	73	8	0
	CDD65	39	0	0	0	0	1	8	12	13	5	0	0	0
	CDH74	224	0	0	0	1	13	56	68	64	22	0	0	0
	CDH80	44	0	0	0	0	2	15	15	11	1	0	0	0
Wind	WSAvg	8.9	9.3	9.2	9.2	9.2	9.3	10.0	9.4	8.4	6.9	7.5	8.8	9.6
Precipitation	PrecAvg	25.4	4.2	2.9	1.9	1.3	1.0	0.7	0.6	0.8	1.3	2.4	3.9	4.4
	PrecMax	34.4	8.5	6.7	4.3	2.8	2.0	2.7	1.5	2.6	2.8	8.1	7.5	10.4
	PrecMin	15.3	0.6	0.4	0.5	0.7	0.2	0.1	0.0	0.0	0.2	0.2	0.6	0.4
	PrecStd	4.9	2.1	1.5	1.1	0.6	0.5	0.6	0.4	0.7	0.7	1.8	1.7	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.8	53.9	60.4	69.3	74.7	81.1	80.9	80.6	77.2	65.7	56.5	52.8
		MCWB	50.1	47.2	50.4	55.2	58.5	63.2	65.7	64.3	61.6	54.8	53.2	50.6
	2%	DB	50.6	51.3	55.7	61.9	67.7	72.6	74.5	74.6	71.5	61.3	54.0	50.2
		MCWB	48.6	47.0	48.9	52.2	56.2	59.8	62.7	62.1	60.1	54.1	51.8	48.3
	5%	DB	49.1	49.5	53.2	58.0	63.7	67.4	70.5	70.6	67.5	58.5	52.4	48.5
		MCWB	47.4	46.3	48.0	50.4	54.7	57.8	60.6	60.7	58.5	53.4	50.5	46.7
	10%	DB	47.6	48.1	51.1	55.3	60.6	64.3	67.4	67.5	64.6	56.3	51.0	47.2
		MCWB	46.2	45.5	47.2	49.2	53.5	56.4	59.2	59.6	57.6	52.6	49.3	45.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.4	50.3	52.9	56.5	60.1	63.8	66.8	65.4	63.4	59.0	54.5	51.4
		MCDB	51.8	51.4	56.0	66.1	69.8	78.3	78.6	76.5	73.4	61.9	55.4	52.1
	2%	WB	49.3	48.6	50.8	53.6	57.6	60.9	63.6	63.1	61.4	56.1	52.6	49.0
		MCDB	50.1	49.9	53.8	59.8	65.1	70.5	72.5	72.0	68.8	58.2	53.5	49.7
	5%	WB	47.8	47.3	49.2	51.8	55.7	58.8	61.6	61.6	59.8	54.6	51.1	47.3
		MCDB	48.6	48.6	52.0	56.2	61.7	65.8	68.8	68.8	65.6	56.6	51.9	48.1
	10%	WB	46.5	46.0	47.8	50.2	54.2	57.2	60.0	60.3	58.4	53.3	49.7	46.0
		MCDB	47.3	47.5	50.3	54.2	59.5	63.1	65.9	66.3	63.1	55.5	50.6	46.9
Mean Daily Temperature Range	5% DB	MDBR	6.2	7.9	9.6	11.2	12.5	13.0	13.8	13.6	12.4	8.9	6.9	6.1
		MCDBR	7.0	9.1	11.9	15.6	17.8	18.3	18.8	18.7	17.4	12.1	7.7	6.8
		MCWBR	5.4	6.0	7.2	8.3	8.7	8.6	8.9	8.8	8.5	6.9	5.9	5.6
	5% WB	MCDBR	6.3	7.7	10.7	13.4	15.3	16.5	17.2	16.3	14.9	9.9	6.8	6.3
		MCWBR	5.5	5.8	7.0	7.8	8.3	8.6	9.1	8.8	8.4	6.7	6.0	5.7
Clear-Sky Solar Irradiance	taub	0.317	0.317	0.330	0.357	0.377	0.355	0.348	0.353	0.338	0.331	0.325	0.314	
	taud	2.525	2.547	2.523	2.440	2.401	2.481	2.539	2.524	2.561	2.565	2.504	2.488	
	Ebn at Noon	241	270	283	284	281	287	288	282	277	260	234	225	
	Edh at Noon	19	23	28	33	36	33	31	30	26	23	20	18	
All-Sky Solar Radiation	RadAvg	296	576	899	1359	1736	1899	2076	1751	1249	688	354	238	
	RadStd	39	77	105	127	137	180	146	113	103	75	54	31	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-0.88	-1.17	N/A	N/A	N/A	N/A
(47) Regional (75 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page