

VICTORIA MARINE, BC, Canada

WMO: 712023

Lat: 48.370N

Lon: 123.750W

Elev: 104

StdP: 14.64

Time Zone: -8.00 (NAP)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.0	27.4	11.5	9.9	25.7	18.0	13.7	31.2	36.6	37.3	31.8	39.0	15.1	90	0.632

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.3	69.9	59.2	66.7	57.9	64.1	56.7	60.5	68.0	58.8	64.7	57.5	62.6	6.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.6	71.1	62.0	55.9	66.8	60.5	54.7	64.0	59.6	26.8	68.7	25.6	65.0	24.8	63.1	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 30.2	26.2	21.9		19.0	79.0	6.5	1.6	14.3	80.1	10.5	81.1	6.9	82.0	2.2	83.2	
(5)			DB	17.0	66.3	5.9	5.2	12.7	70.1	9.2	73.1	5.9	76.1	1.6	79.9	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.3	40.9	41.8	44.0	46.7	50.6	54.1	56.8	57.4	54.9	49.0	43.6	39.6
	DBStd	7.44	4.72	5.64	3.41	3.46	3.45	2.97	2.83	2.78	3.59	4.08	5.81	5.71
	HDD50	1435	282	232	187	112	30	2	0	0	3	67	197	323
	HDD65	6092	746	651	650	550	447	327	255	236	303	497	642	788
	CDD50	819	1	1	1	11	49	125	211	229	151	35	5	0
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH74	19	0	0	0	0	2	4	9	2	2	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.5	8.1	7.3	6.6	7.6	9.0	9.1	9.6	7.0	5.1	4.9	7.8	7.8
Precipitation	PrecAvg	49.8	7.9	5.8	4.3	3.1	1.8	1.2	0.9	1.1	2.2	4.9	8.3	8.0
	PrecMax	64.3	13.5	10.6	8.6	6.9	4.1	3.7	3.5	4.6	4.8	13.8	17.4	14.0
	PrecMin	32.8	0.9	2.2	2.4	1.1	0.2	0.2	0.0	0.0	0.1	1.0	2.2	0.5
	PrecStd	9.0	3.5	2.6	1.8	1.5	1.0	0.8	0.8	1.1	1.5	3.3	4.0	3.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.5	55.0	56.3	63.1	67.7	72.3	74.8	72.1	71.8	62.9	56.0	51.9
		MCWB	49.6	49.3	48.4	50.8	57.6	60.8	61.7	62.9	58.7	54.1	53.0	50.3
	2%	DB	50.1	52.1	53.2	58.1	62.2	65.8	68.4	69.0	66.9	59.1	53.7	49.3
		MCWB	47.3	48.0	47.5	50.1	54.4	57.5	58.7	60.0	57.5	54.8	51.0	46.8
	5%	DB	48.7	50.2	51.3	55.2	58.6	61.5	64.6	66.1	64.1	56.9	51.9	48.0
		MCWB	46.3	46.7	46.5	49.2	52.4	54.8	56.7	58.4	56.8	53.0	49.9	45.9
	10%	DB	47.2	48.6	49.9	53.0	56.2	59.3	62.1	63.4	61.5	55.0	50.3	46.8
		MCWB	44.9	45.8	45.8	48.1	51.0	53.5	55.6	57.0	55.8	51.7	48.3	44.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.0	51.0	51.0	52.7	58.1	60.4	61.7	65.5	61.9	57.7	53.9	50.7
		MCDB	53.6	53.4	53.7	60.1	65.0	70.2	72.8	68.5	66.5	60.3	55.3	51.8
	2%	WB	48.2	49.0	48.8	51.0	55.2	57.7	59.3	61.0	59.1	55.0	51.8	47.6
		MCDB	49.3	50.9	51.4	56.4	61.6	64.7	67.1	67.6	64.4	58.0	52.8	48.7
	5%	WB	46.8	47.6	47.6	49.8	53.1	55.7	57.6	59.0	57.6	53.6	50.1	46.4
		MCDB	48.2	49.4	50.2	54.1	57.4	60.5	63.2	64.3	62.4	56.1	51.5	47.6
	10%	WB	45.2	46.3	46.5	48.5	51.5	54.2	56.2	57.6	56.2	52.2	48.6	45.2
		MCDB	46.7	48.2	49.0	52.2	55.2	58.3	61.0	62.3	60.7	54.4	50.0	46.6
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.9	10.5	10.8	10.0	10.5	11.3	12.3	12.7	10.2	7.6	7.3
		MCDBR	8.1	10.1	12.7	15.5	14.6	15.3	16.4	17.3	16.3	12.0	7.5	6.3
		MCWBR	6.2	7.2	8.9	9.8	8.6	9.0	8.3	9.9	9.3	8.1	6.2	5.3
	5% WB	MCDBR	7.1	8.6	10.7	13.6	13.2	13.9	14.7	15.5	14.4	10.3	6.7	5.7
		MCWBR	6.1	6.8	8.1	9.2	8.4	9.0	8.5	9.7	9.3	7.4	6.0	5.3
Clear-Sky Solar Irradiance	taub	0.319	0.317	0.334	0.364	0.383	0.362	0.352	0.355	0.343	0.334	0.328	0.314	
	taud	2.509	2.542	2.504	2.409	2.376	2.451	2.522	2.511	2.544	2.554	2.487	2.485	
	Ebn at Noon	240	270	281	281	279	285	287	281	275	259	233	226	
	Edh at Noon	20	23	28	34	37	34	31	30	27	23	20	18	
All-Sky Solar Radiation	RadAvg	296	576	892	1351	1715	1875	2021	1703	1239	688	354	239	
	RadStd	40	78	104	125	134	174	139	117	101	78	54	32	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page