

SQUAMISH, BC, Canada

WMO: 712070

Lat: 49.780N

Lon: 123.160W

Elev: 54

StdP: 100.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-7.4	-5.2	-18.8	0.7	-4.0	-14.6	1.1	-0.7	8.9	-1.4	7.5	0.1	2.7	20	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	29.6	18.1	27.6	17.6	25.7	17.1	19.3	26.9	18.4	25.5	17.7	24.1	3.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	12.0	20.6	15.8	11.3	19.8	15.2	10.8	19.3	55.0	27.1	52.3	25.6	49.9	24.2	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.2	4.4	DB	-9.7	33.7	2.3	2.1	-11.4	35.2	-12.7	36.5	-14.0	37.6	-15.7	39.2	(4)
(5)			WB	-10.7	20.5	1.9	1.3	-12.1	21.4	-13.2	22.2	-14.3	22.9	-15.7	23.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	1.9	3.5	5.6	8.9	12.8	15.5	18.3	18.2	14.8	9.5	4.6	1.2
	DBStd	6.63	3.09	2.66	2.75	2.76	3.05	2.78	2.67	2.44	2.74	2.65	3.15	3.10
	HDD10.0	1109	251	183	138	52	9	0	0	0	1	42	162	271
	HDD18.3	3261	509	416	394	282	174	95	32	32	110	275	411	529
	CDD10.0	964	0	0	2	20	94	164	258	254	146	25	1	0
	CDD18.3	75	0	0	0	0	1	9	32	28	5	0	0	0
	CDH23.3	1043	0	0	1	8	53	151	415	336	79	0	0	0
	CDH26.7	273	0	0	0	1	7	44	121	84	14	0	0	0
Wind	WSAvg	1.6	1.4	1.6	1.7	1.8	1.8	1.9	1.9	1.7	1.4	1.3	1.4	1.4
Precipitation	PrecAvg	2059	289	198	215	122	78	69	51	65	107	241	324	294
	PrecMax	2797	558	491	410	269	157	148	111	234	257	563	683	486
	PrecMin	1546	113	9	47	17	20	26	13	9	30	0	117	121
	PrecStd	323	96	107	87	59	36	34	30	51	62	117	161	93
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	13.2	18.5	24.1	27.6	31.0	33.1	31.4	28.5	20.8	13.5	10.0
		MCWB	7.2	6.9	10.2	12.8	15.1	17.6	19.4	18.3	16.9	12.6	11.8	8.5
	2%	DB	8.1	10.5	14.6	20.0	24.6	27.5	29.8	29.0	25.7	18.0	11.4	7.6
		MCWB	6.7	6.6	8.6	11.5	14.7	16.8	18.9	18.3	16.3	12.0	9.8	6.8
	5%	DB	6.8	8.7	12.2	17.2	22.3	24.5	27.5	26.9	23.1	15.4	9.9	6.2
		MCWB	6.0	6.2	7.5	10.0	13.9	16.1	18.0	17.9	16.0	11.5	8.9	5.4
	10%	DB	5.7	7.3	10.1	14.7	19.7	22.0	25.4	25.0	20.7	13.7	8.8	5.0
		MCWB	5.0	5.4	7.0	9.2	13.2	15.3	17.5	17.4	15.1	11.4	7.9	4.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.4	11.3	14.0	16.6	18.8	21.0	20.1	18.6	15.3	12.4	9.2
		MCDB	9.1	10.6	15.9	22.8	24.3	27.5	28.9	27.3	25.4	18.0	13.1	9.8
	2%	WB	7.1	7.7	9.7	12.3	15.5	17.5	19.6	19.1	17.4	13.7	10.3	6.9
		MCDB	7.7	9.3	12.8	18.0	22.6	25.4	27.7	26.2	23.2	15.3	11.0	7.4
	5%	WB	6.1	6.8	8.5	11.1	14.6	16.5	18.6	18.4	16.5	12.6	9.2	5.7
		MCDB	6.7	8.1	11.0	15.7	20.7	23.1	25.9	25.2	21.6	14.4	9.8	6.1
	10%	WB	5.2	5.9	7.5	10.0	13.6	15.5	17.8	17.6	15.5	11.6	8.2	4.5
		MCDB	5.6	7.0	9.5	13.4	18.6	21.0	24.4	23.8	19.7	13.3	8.8	4.9
Mean Daily Temperature Range	5% DB	MDBR	4.8	6.9	8.1	10.0	10.9	10.1	11.5	11.5	10.5	7.7	5.3	4.2
		MCDBR	6.4	9.7	12.6	15.7	16.4	16.0	16.2	16.0	15.6	11.9	7.1	5.6
		MCWBR	4.8	6.0	6.8	7.9	7.7	6.9	6.5	6.6	7.1	6.5	5.2	4.6
	5% WB	MCDBR	5.4	7.4	10.0	12.8	13.4	13.8	14.3	13.8	13.0	8.7	5.4	5.2
		MCWBR	4.5	5.2	6.1	6.8	6.7	6.3	6.2	6.2	6.4	5.4	4.4	4.4
Clear-Sky Solar Irradiance	taub	0.311	0.305	0.331	0.370	0.385	0.379	0.375	0.377	0.355	0.340	0.315	0.297	
	taud	2.252	2.326	2.266	2.185	2.248	2.350	2.389	2.406	2.467	2.476	2.378	2.292	
	Ebn at Noon	714	836	872	871	872	879	878	858	843	790	715	678	
	Edh at Noon	73	86	109	133	130	119	113	106	90	75	65	61	
All-Sky Solar Radiation	RadAvg	0.84	1.70	2.49	3.95	5.21	5.39	6.06	5.21	3.57	1.97	0.96	0.67	
	RadStd	0.15	0.27	0.38	0.47	0.48	0.69	0.59	0.42	0.33	0.31	0.19	0.11	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page