

SANDHEADS, BC, Canada

WMO: 712090

Lat: 49.1058N

Lon: 123.3033W

Elev: 11

StdP: 101.19

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.0	-1.0	N/A	N/A	N/A	N/A	N/A	N/A	16.4	8.0	15.0	7.7	6.1	110	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.2	22.4	N/A	21.3	N/A	20.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.0	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	12.0	10.7	DB	-5.1	25.1	2.1	1.4	-6.7	26.2	-7.9	27.0	-9.1	27.8	-10.7	28.8	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	5.3	5.7	7.4	9.6	12.9	15.3	17.8	17.9	15.3	11.1	7.5	5.1
	DBStd	5.13	2.84	2.39	1.99	1.89	2.08	1.97	1.80	1.58	1.86	1.89	2.76	2.81
	HDD10.0	625	146	121	84	28	2	0	0	0	0	11	81	153
	HDD18.3	2732	404	354	340	261	168	94	31	27	92	223	326	411
	CDD10.0	970	1	1	2	17	92	159	242	246	159	45	6	1
	CDD18.3	34	0	0	0	0	0	3	16	14	2	0	0	0
	CDH23.3	12	0	0	0	0	0	1	8	2	1	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	5.1	5.3	5.3	5.5	5.1	4.7	4.7	4.9	4.5	4.8	5.0	5.7	5.8
Precipitation	PrecAvg	1782	251	162	171	120	86	70	45	58	86	201	273	260
	PrecMax	2221	426	325	319	247	137	129	99	254	190	364	494	383
	PrecMin	1407	135	17	45	38	14	15	8	11	14	35	124	151
	PrecStd	200	68	63	55	47	30	33	24	52	49	78	93	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	11.4	13.4	16.0	19.8	22.5	24.3	23.5	21.5	16.4	14.0	11.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	10.4	10.2	11.5	14.2	18.1	20.8	22.6	22.2	19.6	15.1	12.5	10.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	9.6	9.2	10.6	13.0	16.9	19.3	21.4	21.2	18.5	14.2	11.7	9.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	8.8	8.5	9.8	12.1	15.7	18.0	20.4	20.3	17.7	13.5	10.8	8.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.0	3.1	3.4	3.7	4.3	4.3	4.7	4.2	3.3	2.7	3.0	3.0
		MCDBR	3.6	3.6	4.1	4.6	5.6	5.9	5.8	5.3	4.3	3.4	3.7	3.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.320	0.313	0.331	0.361	0.382	0.360	0.355	0.359	0.343	0.335	0.321	0.309	
	taud	2.476	2.536	2.502	2.418	2.382	2.462	2.505	2.503	2.550	2.552	2.518	2.483	
	Ebn at Noon	741	848	886	887	878	900	899	880	864	809	736	704	
	Edh at Noon	62	73	88	106	115	107	101	97	84	71	59	55	
All-Sky Solar Radiation	RadAvg	0.87	1.73	2.61	4.05	5.28	5.68	6.33	5.36	3.73	2.05	1.02	0.69	
	RadStd	0.14	0.26	0.35	0.43	0.45	0.66	0.54	0.41	0.33	0.27	0.19	0.10	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (68 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page