

HOWE SOUND PAM ROCKS, BC, Canada

WMO: 712110

Lat: 49.488N

Lon: 123.300W

Elev: 23

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	27.5	30.8	11.1	9.7	31.2	15.9	12.3	34.9	48.6	29.4	43.4	35.8	29.9	20	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	76.4	65.9	73.6	64.7	71.5	63.9	67.6	73.5	66.1	71.7	64.8	70.1	7.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	93.2	71.5	63.6	88.1	69.8	62.3	84.1	68.6	32.0	73.6	30.8	71.8	29.8	70.3	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.0	35.1	29.9	DB	24.9	82.2	3.8	3.8	22.2	85.0	19.9	87.2	17.8	89.3	15.0	92.1	(4)
(5)			WB	21.2	69.8	4.1	1.9	18.3	71.2	15.9	72.3	13.6	73.3	10.6	74.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	41.4	42.6	45.2	50.1	56.6	61.1	65.7	65.9	60.7	52.2	45.2	40.7	(6)	
	DBStd	10.06	4.90	4.41	4.16	4.16	4.75	4.50	4.17	3.59	3.91	3.73	4.72	4.76	(7)	
	HDD50	1147	267	209	157	47	4	0	0	0	19	154	290		(8)	
	HDD65	4773	731	628	614	446	263	135	40	30	139	397	595	755	(9)	
	CDD50	1998	0	1	8	52	208	332	486	494	321	87	8	1	(10)	
	CDD65	148	0	0	0	0	2	17	61	59	9	0	0	0	(11)	
	CDH74	222	0	0	0	0	3	24	114	74	7	0	0	0	(12)	
	CDH80	23	0	0	0	0	0	1	12	10	0	0	0	0	(13)	
	WSAvg	11.3	15.6	14.7	12.9	10.4	9.3	8.5	7.6	7.6	8.2	10.5	14.2	16.4	(14)	
	PrecAvg	76.1	10.9	7.1	6.9	5.0	3.7	3.0	2.1	2.4	3.2	8.6	11.4	11.2	(15)	
(16) Precipitation	PrecMax	91.1	17.9	13.7	12.5	9.9	5.4	5.1	3.9	10.7	7.3	14.7	19.7	13.9	(16)	
	PrecMin	63.2	6.5	1.7	2.7	1.7	1.3	1.2	0.4	0.6	1.0	2.8	6.1	7.6	(17)	
	PrecStd	7.7	2.7	2.7	1.9	2.1	1.1	1.2	0.9	2.5	1.7	3.0	3.6	1.9	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	53.8	54.6	58.2	65.6	72.2	77.6	81.4	80.8	73.8	64.2	58.0	54.7		(19)	
	0.4% MCWB	49.9	49.4	50.5	53.9	58.8	62.9	67.6	68.0	64.6	56.3	54.0	51.1		(20)	
	2% DB	50.6	51.1	54.5	61.1	68.0	72.9	77.0	75.5	70.0	60.8	54.8	50.2		(21)	
	2% MCWB	47.3	46.3	48.8	53.1	58.6	62.1	67.1	66.1	62.6	55.4	51.3	46.5		(22)	
	5% DB	48.7	49.2	52.4	58.6	65.4	69.8	74.1	73.0	67.8	58.8	52.6	47.7		(23)	
	5% MCWB	45.9	45.1	47.3	51.8	57.7	61.2	65.5	64.9	61.3	54.2	49.5	44.7		(24)	
	10% DB	46.9	47.6	50.4	56.1	63.1	67.4	71.7	71.1	65.9	57.0	50.7	46.1		(25)	
	10% MCWB	44.5	44.2	46.0	50.2	56.4	60.0	64.5	64.2	60.2	53.0	47.8	43.5		(26)	
	0.4% WB	49.9	50.8	52.1	56.5	61.7	65.7	70.9	69.1	67.0	59.5	55.1	51.6		(27)	
	0.4% MCDB	51.4	53.3	55.7	61.3	67.6	73.4	77.5	76.3	71.6	62.4	57.0	55.2		(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	47.9	47.5	49.9	54.5	59.9	63.8	68.4	67.3	64.6	57.1	51.8	47.3		(29)	
	2% MCDB	49.4	49.6	53.4	59.5	65.4	70.4	74.6	73.0	68.6	59.7	53.9	49.5		(30)	
	5% WB	46.2	46.1	48.3	52.7	58.5	62.1	66.5	66.0	62.8	55.3	50.0	45.3		(31)	
	5% MCDB	47.9	48.2	51.4	57.3	63.9	68.3	72.5	71.3	66.6	57.6	51.9	47.2		(32)	
	10% WB	44.8	44.7	46.9	51.0	57.1	60.5	65.0	64.8	61.3	53.9	48.3	44.0		(33)	
	10% MCDB	46.4	46.9	49.9	55.3	62.1	66.4	70.8	69.8	65.1	56.3	50.0	45.7		(34)	
(36) Mean Daily Temperature Range	MDBR	5.4	6.5	7.5	8.8	9.2	9.4	10.2	9.4	8.3	6.5	5.6	5.0		(35)	
	5% DB MCDBR	7.8	8.2	9.7	12.2	12.5	13.4	14.2	12.5	10.7	8.6	8.3	7.9		(36)	
	5% DB MCWBR	5.4	5.3	6.4	7.8	8.1	7.9	7.8	7.5	7.3	5.8	6.2	5.6		(37)	
	5% WB MCDBR	7.1	7.0	8.5	10.1	10.5	11.2	12.4	11.0	9.7	7.5	8.2	7.9		(38)	
	5% WB MCWBR	5.4	5.0	6.2	7.3	7.7	7.6	7.7	7.2	7.0	5.5	6.3	6.0		(39)	
(40) Clear-Sky Solar Irradiance	taub	0.317	0.310	0.333	0.366	0.384	0.371	0.365	0.368	0.349	0.339	0.321	0.304		(40)	
	taud	2.367	2.443	2.401	2.349	2.357	2.422	2.460	2.468	2.524	2.530	2.476	2.404		(41)	
	Ebn at Noon	230	267	279	279	278	282	282	276	271	253	230	219		(42)	
	Edh at Noon	21	25	31	36	37	35	33	32	27	23	19	18		(43)	
(44) All-Sky Solar Radiation	RadAvg	263	532	783	1233	1631	1735	1960	1668	1142	626	307	209		(44)	
	RadStd	47	85	116	141	148	226	188	141	107	94	62	34		(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (61 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page