

OSOYOOS, BC, Canada

WMO: 712150

Lat: 49.0283N

Lon: 119.4411W

Elev: 936

StdP: 14.21

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	14.0	-1.2	5.3	12.9	3.9	7.0	17.5	16.9	24.2	14.6	25.7	5.1	140	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.1	95.4	66.5	92.0	65.5	88.6	64.1	69.3	89.6	67.3	86.6	65.6	84.0	4.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	88.6	75.0	60.7	82.2	72.5	58.8	76.5	71.2	33.9	90.1	32.2	86.7	30.9	84.4	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.8	12.8	11.2	DB	3.8	101.2	6.2	2.7	-0.6	103.2	-4.2	104.8	-7.7	106.3	-12.2	108.3	(4)
(5)			WB	2.9	74.0	6.1	2.4	-1.5	75.7	-5.1	77.1	-8.5	78.4	-13.0	80.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.2	30.5	34.1	42.8	51.1	60.1	66.4	74.0	72.2	62.8	50.1	38.6	30.6	(6)
(7)		DBStd	16.59	7.89	7.00	6.70	5.89	6.37	6.03	5.49	5.29	5.80	6.18	7.60	7.64	(7)
(8)		HDD50	2373	606	446	234	57	4	0	0	0	1	74	348	603	(8)
(9)		HDD65	5712	1071	866	687	417	177	52	5	8	107	461	793	1068	(9)
(10)		CDD50	2809	0	0	11	90	316	492	743	688	386	78	5	0	(10)
(11)		CDD65	676	0	0	0	0	25	94	283	232	42	0	0	0	(11)
(12)		CDH74	8568	0	0	0	37	483	1218	3470	2761	592	7	0	0	(12)
(13)		CDH80	3773	0	0	0	3	147	472	1708	1264	179	0	0	0	(13)
(14)	Wind	WSAvg	4.3	4.3	4.2	4.7	4.8	4.4	4.3	4.4	4.0	3.8	4.0	4.5	4.6	(14)
(15)	Precipitation	PrecAvg	17.0	1.7	1.0	1.0	1.2	1.8	2.2	1.3	1.0	0.8	1.1	1.6	2.1	(15)
(16)		PrecMax	20.8	2.5	2.0	2.4	2.2	4.2	3.4	4.0	2.3	2.4	1.7	2.6	3.7	(16)
(17)		PrecMin	12.0	0.8	0.4	0.4	0.5	0.4	0.7	0.0	0.2	0.1	0.4	0.4	0.9	(17)
(18)		PrecStd	2.7	0.5	0.4	0.4	0.5	0.9	0.8	0.9	0.6	0.6	0.4	0.6	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.0	53.8	67.5	78.9	89.6	96.7	100.1	98.6	89.9	73.6	58.7	49.5	(19)
MCWB			41.0	44.8	51.2	57.8	62.2	67.0	68.7	68.1	64.8	58.2	50.8	44.7	(20)	
2%		DB	43.7	49.6	62.0	73.2	84.3	90.3	96.3	94.3	85.1	68.4	54.8	45.3	(21)	
		MCWB	39.4	42.2	48.0	54.0	60.1	64.3	66.4	66.5	63.0	54.8	48.6	40.7	(22)	
5%		DB	41.1	46.6	58.4	68.6	79.4	85.1	93.2	90.7	80.9	64.5	51.8	42.1	(23)	
		MCWB	38.1	40.3	45.9	51.3	58.3	62.2	65.8	65.5	61.1	52.6	46.3	38.6	(24)	
10%		DB	39.1	43.8	55.1	64.5	74.9	80.9	89.6	87.4	76.5	61.3	49.4	39.4	(25)	
		MCWB	36.6	38.7	44.3	49.3	56.3	60.5	64.3	64.0	59.0	51.0	44.6	36.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	46.9	52.4	58.4	64.5	70.0	72.6	72.5	66.9	59.9	52.4	45.1	(27)
MCD B			45.8	51.6	64.0	75.7	83.8	90.4	93.1	91.9	84.6	70.0	57.3	48.4	(28)	
2%		WB	39.9	43.6	49.2	55.2	61.7	66.3	69.7	69.0	64.5	57.0	49.4	41.7	(29)	
		MCD B	42.9	48.0	59.5	70.2	79.2	85.0	90.3	89.2	81.3	65.0	53.5	44.4	(30)	
5%		WB	38.4	41.3	47.2	52.7	59.8	63.8	67.6	66.9	62.2	54.4	47.4	39.1	(31)	
		MCD B	40.8	45.3	56.3	66.0	75.8	81.0	87.3	85.8	77.6	61.9	51.0	41.5	(32)	
10%		WB	36.8	39.4	45.2	50.4	57.9	61.7	65.9	65.3	60.3	52.1	45.1	36.9	(33)	
		MCD B	38.9	43.1	53.4	62.0	72.1	77.2	84.7	83.4	73.6	59.7	48.8	39.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.8	14.4	19.7	23.4	24.7	24.4	28.1	28.6	26.1	19.8	12.1	8.6	(35)
MCDBR			11.1	18.3	25.8	30.9	33.8	33.5	35.1	35.3	33.9	24.6	14.7	11.6	(36)	
MCWBR			8.0	11.7	14.6	14.8	13.6	12.6	12.7	13.4	14.6	13.1	9.9	8.7	(37)	
5% WB		MCDBR	9.8	15.5	23.1	28.2	30.3	31.3	32.9	33.3	31.7	21.8	12.6	10.2	(38)	
		MCWBR	7.3	10.2	13.5	14.3	12.5	12.3	12.8	13.2	14.3	12.4	8.9	8.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.297	0.298	0.318	0.348	0.377	0.371	0.358	0.369	0.339	0.328	0.309	0.291	(40)	
taud		2.321	2.408	2.443	2.379	2.339	2.389	2.389	2.446	2.412	2.483	2.496	2.459	2.376	(41)	
Ebn at Noon		239	272	285	286	280	282	284	276	274	258	236	226	(42)		
Edh at Noon		22	26	30	35	38	36	34	34	28	24	20	19	(43)		
(44)	All-Sky Solar Radiation	RadAvg	330	644	1012	1481	1786	1902	2189	1848	1335	775	367	255	(44)	
(45)		RadStd	39	69	89	111	135	157	150	129	107	92	47	31	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	-1.24	N/A	N/A	N/A	N/A	N/A
(47)	Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page