

OSOYOOS, BC, Canada

WMO: 712150

Lat: 49.0283N

Lon: 119.4411W

Elev: 285

StdP: 97.94

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.3	-10.0	-18.5	0.8	-10.6	-15.6	1.0	-8.1	7.6	-4.4	6.5	-3.5	2.3	140	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	35.2	19.2	33.3	18.6	31.4	17.9	20.7	32.0	19.6	30.3	18.7	28.9	2.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	12.7	23.9	16.0	11.7	22.5	14.9	10.9	21.8	61.0	32.3	57.1	30.4	54.0	29.1	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.6	5.7	5.0	-15.7	38.5	3.4	1.5	-18.1	39.5	-20.1	40.4	-22.1	41.3	-24.5	42.4		
(5)			-16.2	23.3	3.4	1.3	-18.6	24.3	-20.6	25.1	-22.5	25.8	-25.0	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-0.9	1.2	6.0	10.6	15.6	19.1	23.3	22.3	17.1	10.1	3.6	-0.8	(6)	
	DBStd	9.22	4.38	3.89	3.72	3.27	3.54	3.35	3.05	2.94	3.22	3.43	4.22	4.25	(7)	
	HDD10.0	1318	337	248	130	32	2	0	0	0	1	41	193	335	(8)	
	HDD18.3	3173	595	481	382	232	98	29	3	4	59	256	441	593	(9)	
	CDD10.0	1561	0	0	6	50	176	273	413	382	214	43	3	0	(10)	
	CDD18.3	376	0	0	0	0	14	52	157	129	23	0	0	0	(11)	
	CDH23.3	4760	0	0	0	21	268	677	1928	1534	329	4	0	0	(12)	
	CDH26.7	2096	0	0	0	2	82	262	949	702	99	0	0	0	(13)	
(14) Wind	WSAvg	1.9	1.9	1.9	2.1	2.1	2.0	1.9	1.9	1.8	1.7	1.8	2.0	2.1	(14)	
(15) Precipitation	PrecAvg	432	42	25	26	31	46	56	34	25	20	28	40	53	(15)	
	PrecMax	528	64	52	60	57	107	87	102	59	61	44	65	93	(16)	
	PrecMin	305	21	9	11	12	10	19	1	4	2	9	10	22	(17)	
	PrecStd	69	12	11	11	13	24	20	24	16	16	10	16	17	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	12.1	19.7	26.0	32.0	35.9	37.8	37.0	32.1	23.1	14.8	9.7	(19)	
		MCWB	5.0	7.1	10.7	14.3	16.8	19.5	20.4	20.1	18.2	14.6	10.4	7.1	(20)	
	2%	DB	6.5	9.8	16.7	22.9	29.1	32.4	35.7	34.6	29.5	20.2	12.7	7.4	(21)	
		MCWB	4.1	5.7	8.9	12.2	15.6	18.0	19.1	19.2	17.2	12.7	9.2	4.8	(22)	
	5%	DB	5.0	8.1	14.7	20.3	26.3	29.5	34.0	32.6	27.1	18.1	11.0	5.6	(23)	
		MCWB	3.4	4.6	7.7	10.7	14.6	16.8	18.8	18.6	16.1	11.4	7.9	3.7	(24)	
	10%	DB	3.9	6.5	12.8	18.0	23.8	27.2	32.0	30.8	24.7	16.3	9.7	4.1	(25)	
		MCWB	2.6	3.7	6.8	9.6	13.5	15.8	17.9	17.8	15.0	10.6	7.0	2.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	8.3	11.3	14.7	18.0	21.1	22.6	22.5	19.4	15.5	11.4	7.3	(27)	
		MCDB	7.7	10.9	17.8	24.3	28.8	32.5	33.9	33.3	29.2	21.1	14.1	9.1	(28)	
	2%	WB	4.4	6.5	9.6	12.9	16.5	19.1	20.9	20.6	18.1	13.9	9.7	5.4	(29)	
		MCDB	6.1	8.9	15.3	21.2	26.2	29.4	32.4	31.8	27.4	18.3	11.9	6.9	(30)	
	5%	WB	3.6	5.2	8.4	11.5	15.4	17.7	19.8	19.4	16.8	12.4	8.6	3.9	(31)	
		MCDB	4.9	7.4	13.5	18.9	24.3	27.2	30.7	29.9	25.3	16.6	10.6	5.3	(32)	
	10%	WB	2.7	4.1	7.3	10.2	14.4	16.5	18.8	18.5	15.7	11.2	7.3	2.7	(33)	
		MCDB	3.8	6.2	11.9	16.7	22.3	25.1	29.3	28.5	23.1	15.4	9.3	4.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	8.0	10.9	13.0	13.7	13.5	15.6	15.9	14.5	11.0	6.7	4.8	(35)	
		MCDBR	6.2	10.2	14.4	17.2	18.8	18.6	19.5	19.6	18.9	13.7	8.2	6.5	(36)	
	5% WB	MCWBR	4.5	6.5	8.1	8.2	7.6	7.0	7.1	7.4	8.1	7.3	5.5	4.8	(37)	
		MCWBR	5.4	8.6	12.8	15.7	16.8	17.4	18.3	18.5	17.6	12.1	7.0	5.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.297	0.298	0.318	0.348	0.377	0.371	0.358	0.369	0.339	0.328	0.309	0.291	(40)	
		taud	2.321	2.408	2.443	2.379	2.339	2.389	2.446	2.412	2.483	2.496	2.459	2.376	(41)	
	Edn at Noon	Edn at Noon	754	858	899	901	883	888	896	869	865	813	745	714	(42)	
		Edh at Noon	70	81	93	110	120	115	107	106	89	75	62	59	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.04	2.03	3.19	4.67	5.63	6.00	6.90	5.83	4.21	2.44	1.16	0.80	(44)	
	RadStd	RadStd	0.12	0.22	0.28	0.35	0.42	0.50	0.47	0.41	0.34	0.29	0.15	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	-0.69	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page